

6 浄水場毎日試験

第2版:2017/2/3

(1)水道用水毎日検査

高蔵寺浄水場	2	豊田浄水場	5
尾張東部浄水場	2	幸田浄水場	5
上野浄水場	3	豊橋浄水場	6
知多浄水場	3	豊橋南部浄水場	6
犬山浄水場	4	豊川浄水場	7
尾張西部浄水場	4		

(2)工業用水毎日検査

尾張東部浄水場(東郷)	8
上野浄水場	8
知多浄水場	8
尾張西部浄水場	9
安城浄水場	9
豊橋南部浄水場	9
蒲郡浄水場	10

(1)水道用水毎日検査

高蔵寺浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (°C)	最大	22.8	29.1	27.5	33.3	33.6	26.9	24.3	19.8	20.2	12.5	15.7	18.6	33.6
	最小	9.0	18.5	18.5	20.0	24.3	19.4	15.7	8.7	6.2	0.0	2.3	4.0	0.0
	平均	16.5	23.2	23.7	27.6	29.3	24.4	20.6	15.4	10.3	6.3	7.2	12.2	18.1
原水水温 (°C)	最大	13.5	17.6	19.8	22.0	24.7	20.6	18.5	15.0	12.0	7.5	7.5	10.6	24.7
	最小	8.7	14.2	15.9	17.3	21.0	18.2	15.4	11.8	6.3	4.6	5.1	5.9	4.6
	平均	10.7	15.8	18.1	19.7	23.1	19.1	16.4	13.8	10.1	6.1	6.1	8.5	14.0
濁度 原水 (度)	最大	79.5	11.6	10.8	95.9	13.7	21.1	180.4	11.7	20.8	3.6	38.0	9.5	180.4
	最小	3.5	4.2	2.8	2.3	2.6	2.6	2.5	2.0	1.7	1.0	1.5	4.3	1.0
	平均	10.6	7.1	4.9	11.0	4.8	6.7	13.6	4.1	4.0	2.1	9.1	6.1	7.0
浄水 (度)	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
	最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
	平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 原水 (度)	最大	33.0	7.0	9.0	34.0	10.1	15.0	60.0	11.0	12.0	3.0	18.0	10.0	60.0
	最小	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	2.0	2.0	2.0	4.0	2.0
	平均	6.0	4.9	4.9	6.5	5.6	5.9	7.1	5.1	4.1	2.6	5.9	6.8	5.5
浄水 (度)	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
	最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
	平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH 原水	最大	7.2	7.3	7.3	7.2	7.2	7.2	7.3	7.3	7.3	7.4	7.3	7.2	7.4
	最小	6.8	7.1	7.1	6.7	7.0	6.9	6.7	7.0	7.0	7.2	7.0	7.0	6.7
	平均	7.1	7.2	7.2	7.1	7.1	7.1	7.2	7.2	7.2	7.3	7.2	7.1	7.2
浄水	最大	7.2	7.2	7.3	7.2	7.1	7.2	7.2	7.2	7.2	7.2	7.3	7.4	7.4
	最小	7.0	7.1	7.1	7.0	7.0	7.0	7.0	7.1	7.0	7.0	7.1	7.2	7.0
	平均	7.1	7.2	7.2	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.2	7.3	7.1
アルカ度 原水 (mg/l)	最大	14.5	16.0	16.5	16.5	17.0	16.0	19.0	20.0	17.5	19.5	15.5	15.5	20.0
	最小	7.5	12.0	14.0	6.5	11.0	8.0	6.5	9.5	8.5	15.5	8.0	13.0	6.5
	平均	11.8	14.8	15.7	13.1	15.2	12.8	15.3	15.3	14.7	16.9	12.7	13.8	14.3
浄水 (mg/l)	最大	14.0	15.0	15.5	16.0	16.0	15.5	17.5	19.0	16.0	17.5	16.0	15.0	19.0
	最小	8.5	12.0	14.0	7.5	11.0	8.5	7.5	10.0	9.0	14.0	9.0	12.5	7.5
	平均	11.5	13.8	15.0	12.8	14.4	12.4	14.3	14.7	13.8	15.4	12.7	14.0	13.7
KMnO ₄ 消費量 原水 (mg/l)	最大	14.0	5.8	5.6	12.6	7.1	8.8	22.8	8.4	6.8	3.6	9.7	5.7	22.8
	最小	2.0	2.8	3.2	2.7	2.3	3.1	2.8	2.5	2.5	1.9	2.2	2.5	1.9
	平均	4.4	4.3	4.0	4.9	4.0	4.9	5.0	4.4	3.6	2.8	4.4	3.2	4.2
浄水 (mg/l)	最大	1.1	1.3	1.1	0.9	1.2	1.6	1.6	1.7	1.6	1.2	1.4	1.4	1.7
	最小	0.5	0.5	0.3	0.3	0.1	0.6	0.8	0.5	0.8	0.6	0.5	0.6	0.1
	平均	0.7	0.8	0.8	0.5	0.8	1.1	1.2	1.2	1.0	0.9	1.0	0.9	0.9
残留塩素 浄水 (mg/l)	最大	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.4	0.4	0.4	0.5	0.6
	最小	0.4	0.4	0.4	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
	平均	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.5

尾張東部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (°C)	最大	23.1	28.2	28.3	33.3	34.0	28.0	24.3	20.7	20.6	10.7	17.4	18.8	34.0
	最小	7.6	20.0	19.4	21.0	24.9	19.2	14.3	9.0	5.1	-0.4	3.1	3.4	-0.4
	平均	16.2	23.3	24.1	28.1	29.9	24.9	20.0	15.4	10.3	6.2	7.3	11.6	18.1
原水水温 (°C)	最大	16.0	19.5	21.5	24.0	26.0	24.0	20.5	16.5	13.0	9.0	7.5	11.0	26.0
	最小	10.5	16.0	19.5	20.0	24.0	21.0	17.0	13.5	9.0	6.0	6.0	7.0	6.0
	平均	12.4	17.9	20.2	21.9	25.1	21.8	18.5	15.4	10.8	7.4	6.6	9.2	15.6
濁度 原水 (度)	最大	15.0	9.1	5.3	15.0	4.5	8.8	35.1	6.2	5.9	3.6	11.4	6.4	35.1
	最小	4.2	4.7	2.6	2.7	2.0	2.8	2.7	2.0	2.1	2.0	2.1	4.2	2.0
	平均	7.2	6.4	4.2	5.9	3.6	4.5	6.4	3.5	3.2	2.3	5.4	5.1	4.8
浄水 (度)	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
	最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
	平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 原水 (度)	最大	4.6	5.5	6.2	7.9	8.3	9.8	10.2	6.4	4.9	3.5	20.0	5.6	20.0
	最小	2.5	4.1	4.3	4.8	4.3	4.1	3.5	3.3	3.0	2.2	1.7	3.4	1.7
	平均	3.5	4.7	5.1	6.4	6.1	6.4	5.0	4.6	3.9	2.7	4.6	4.5	4.8
浄水 (度)	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
	最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
	平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH 原水	最大	7.6	7.6	7.5	7.5	7.4	7.4	7.7	7.8	7.5	7.6	7.5	7.5	7.8
	最小	7.3	7.2	7.2	7.1	7.1	7.1	7.3	7.2	7.2	7.3	7.1	7.2	7.1
	平均	7.4	7.4	7.3	7.3	7.2	7.2	7.4	7.4	7.4	7.4	7.4	7.4	7.4
浄水	最大	7.2	7.3	7.3	7.2	7.1	7.1	7.2	7.2	7.2	7.3	7.3	7.2	7.3
	最小	7.1	7.1	7.1	7.0	7.0	6.9	7.0	7.0	7.1	7.1	7.0	7.1	6.9
	平均	7.1	7.2	7.2	7.1	7.0	7.0	7.1	7.1	7.1	7.2	7.1	7.2	7.1
アルカ度 原水 (mg/l)	最大	14.0	16.0	17.0	16.5	17.0	15.0	18.5	19.0	17.5	18.0	16.5	15.5	19.0
	最小	11.5	13.0	15.0	12.5	14.0	12.5	13.5	14.5	13.5	14.5	12.0	13.0	11.5
	平均	13.0	14.6	16.1	14.8	15.5	13.7	15.5	16.6	15.5	16.5	14.3	14.1	15.0
浄水 (mg/l)	最大	13.0	14.0	16.0	15.0	16.0	14.0	16.0	17.5	16.0	16.0	15.0	14.0	17.5
	最小	11.0	12.0	13.0	10.5	11.5	11.0	11.5	13.0	12.0	13.5	11.5	11.5	10.5
	平均	11.7	13.1	14.6	13.4	13.7	12.3	13.6	14.8	14.0	14.7	13.1	12.6	13.5
KMnO ₄ 消費量 原水 (mg/l)	最大	5.3	4.0	4.4	6.3	5.0	6.1	6.4	6.1	4.8	4.3	4.7	4.5	6.4
	最小	2.6	2.8	2.2	3.3	2.6	2.9	3.1	3.6	3.1	2.0	2.1	2.8	2.0
	平均	3.7	3.3	3.5	4.9	3.7	4.3	4.5	4.8	3.9	2.9	3.6	3.5	3.9
浄水 (mg/l)	最大	1.9	1.1	1.4	1.7	1.5	1.9	1.6	1.7	1.6	1.2	1.4	1.2	1.9
	最小	0.5	0.5	0.3	0.8	0.3	0.6	0.8	0.9	0.6	0.5	0.6	0.6	0.3
	平均	0.9	0.7	0.9	1.3	0.9	1.1	1.1	1.2	1.2	0.9	1.0	0.9	1.0
残留塩素 浄水 (mg/l)	最大	0.6	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.6	0.6	0.8
	最小	0.5	0.5	0.6	0.7	0.7	0.7	0.7	0.7	0.6	0.5	0.5	0.5	0.5
	平均	0.6	0.6	0.7	0.8	0.8	0.8	0.7	0.7	0.7	0.6	0.6	0.6	0.7

犬山浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	27.9	27.2	32.0	32.8	26.5	23.5	20.1	20.6	9.9	15.5	17.6	32.8	
	最小	8.2	18.2	17.6	19.3	23.2	19.1	14.5	8.4	5.5	-0.6	2.1	2.9	-0.6	
	平均	15.9	22.5	23.4	27.0	28.8	23.7	19.3	14.7	10.0	5.7	6.6	11.3	17.4	
原水水温 (°C)	最大	13.9	18.7	20.1	22.5	25.3	19.8	19.1	14.6	11.1	7.4	8.1	10.3	25.3	
	最小	9.0	14.4	16.9	18.0	19.5	18.6	15.0	10.8	7.5	4.6	4.9	5.7	4.6	
	平均	10.9	16.2	18.8	20.1	23.0	19.1	16.4	13.5	9.3	5.9	6.0	8.3	14.0	
濁度 (度)	原水	最大	117.0	8.3	9.6	149.0	27.0	24.5	159.0	11.8	14.9	4.7	38.0	29.0	159.0
		最小	3.1	3.2	2.8	2.7	2.3	1.7	1.2	1.6	1.9	1.2	1.3	2.7	1.2
		平均	10.6	4.4	4.2	11.9	6.1	5.8	11.6	4.0	4.4	2.2	7.8	5.1	6.5
(度)	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	70.0	5.5	9.1	35.4	17.6	10.9	57.4	10.2	8.3	4.3	22.9	12.8	70.0
		最小	2.9	2.8	3.2	3.1	3.3	2.9	2.5	3.7	2.8	1.7	2.3	3.2	1.7
		平均	6.5	3.6	4.8	6.1	5.9	4.8	7.0	5.4	4.2	2.5	5.0	5.0	5.1
(度)	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH	原水	最大	7.2	7.2	7.2	7.3	7.0	7.3	7.4	7.3	7.4	7.4	7.4	7.4	
		最小	6.7	7.0	7.0	6.9	6.9	6.9	7.0	7.1	7.2	7.2	7.0	7.1	6.7
		平均	7.0	7.1	7.1	7.1	7.0	7.2	7.2	7.2	7.2	7.3	7.3	7.2	7.2
(度)	浄水	最大	7.3	7.3	7.3	7.2	7.2	7.4	7.4	7.4	7.4	7.4	7.4	7.4	
		最小	7.3	7.3	7.2	7.2	7.1	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.1
		平均	7.3	7.3	7.3	7.2	7.2	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.3
アルカ度 (mg/l)	原水	最大	14.0	17.0	17.0	16.0	18.5	15.5	20.0	20.5	17.0	19.5	16.5	16.0	20.5
		最小	7.5	12.5	14.5	8.5	9.5	9.0	9.0	11.0	11.0	15.0	8.0	13.5	7.5
		平均	11.6	14.7	16.0	13.2	15.4	13.0	15.9	15.6	15.1	17.6	13.2	14.6	14.7
(mg/l)	浄水	最大	14.0	16.5	17.5	16.5	17.5	15.5	19.0	20.5	16.5	19.0	16.5	16.0	20.5
		最小	8.0	13.0	14.5	8.0	10.5	9.5	10.0	11.5	11.0	16.0	8.5	13.5	8.0
		平均	11.8	14.5	16.0	13.5	15.2	13.1	15.6	15.6	14.9	17.3	13.3	14.7	14.6
KMnO ₄ 消費量 (mg/l)	原水	最大	31.3	5.0	16.3	20.9	11.9	7.5	18.1	8.2	6.9	4.1	10.3	14.5	31.3
		最小	2.2	2.5	3.1	2.8	2.8	2.8	2.8	3.5	2.8	2.5	2.8	2.8	2.2
		平均	4.3	3.9	4.6	5.0	5.1	4.5	4.9	4.8	3.8	3.1	4.3	3.7	4.3
(mg/l)	浄水	最大	1.0	1.3	1.3	1.6	1.6	1.3	1.9	2.2	1.3	1.6	1.9	1.6	2.2
		最小	0.3	0.3	0.6	0.3	0.6	0.6	0.9	1.0	0.6	0.3	0.6	0.9	0.3
		平均	0.5	1.0	1.0	0.9	1.2	0.9	1.3	1.4	0.9	1.0	1.2	1.1	1.0
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.6	0.7	0.7	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.7
		最小	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.5	0.6	0.6	0.7	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.6

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	27.1	27.5	33.3	33.8	27.5	23.6	19.8	20.3	10.1	13.1	18.2	33.8	
	最小	9.5	16.9	18.8	19.6	22.6	19.2	15.6	10.4	6.0	-2.7	2.8	4.3	-2.7	
	平均	15.8	22.6	23.2	27.2	29.2	24.2	20.2	15.1	10.6	6.5	7.3	11.6	17.8	
原水水温 (°C)	最大	16.4	22.5	22.8	25.0	29.1	21.8	20.3	16.3	12.4	8.9	8.6	12.5	29.1	
	最小	10.0	16.0	19.0	18.8	20.8	19.3	15.7	12.4	8.2	4.6	5.4	6.7	4.6	
	平均	12.0	18.5	21.1	21.8	25.6	20.6	17.9	14.9	10.2	7.1	7.0	9.6	15.5	
濁度 (度)	原水	最大	47.0	7.2	8.9	69.0	30.0	20.0	83.0	8.6	13.8	5.7	51.5	7.5	83.0
		最小	3.4	3.2	3.1	4.2	4.0	2.5	1.8	1.5	1.6	1.0	1.5	2.6	1.0
		平均	9.0	4.4	4.9	11.4	7.8	7.2	10.2	3.7	4.1	2.1	7.8	3.8	6.4
(度)	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	16.4	7.8	7.7	16.8	13.4	8.9	33.0	11.3	7.7	8.1	22.8	7.7	33.0
		最小	3.2	3.4	4.2	4.3	4.3	1.2	3.8	3.6	2.9	2.0	2.8	3.4	1.2
		平均	5.3	4.6	5.4	6.8	6.2	5.4	6.7	5.5	4.4	3.3	6.0	4.9	5.4
(度)	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH	原水	最大	7.3	7.9	7.3	7.3	7.3	7.3	7.5	7.5	7.6	7.6	7.3	7.6	7.9
		最小	6.8	7.1	7.0	6.8	6.9	7.0	6.8	6.9	7.0	7.2	6.8	7.1	6.8
		平均	7.1	7.3	7.1	7.1	7.2	7.1	7.2	7.2	7.2	7.4	7.5	7.1	7.3
(度)	浄水	最大	7.5	7.4	7.4	7.4	7.3	7.4	7.3	7.4	7.3	7.3	7.4	7.4	7.5
		最小	7.2	7.1	7.3	7.0	7.2	7.2	7.3	7.1	7.1	7.2	7.3	7.3	7.0
		平均	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
アルカ度 (mg/l)	原水	最大	15.5	20.0	18.0	18.5	20.0	17.1	21.5	22.7	19.5	22.5	18.0	17.0	22.7
		最小	7.0	14.2	14.0	9.9	11.2	10.5	10.0	13.5	12.5	16.0	8.0	14.0	7.0
		平均	12.1	15.8	16.9	14.5	16.6	14.4	17.1	17.3	16.5	19.8	13.9	15.5	15.9
(mg/l)	浄水	最大	15.6	19.0	18.5	18.0	19.6	16.9	19.8	21.9	18.5	21.0	16.5	16.5	21.9
		最小	9.0	14.0	16.0	11.0	12.9	11.5	11.0	13.8	13.0	15.0	9.0	13.0	9.0
		平均	12.8	15.3	17.3	15.1	16.5	14.4	16.7	16.6	16.1	17.9	13.7	14.7	15.6
KMnO ₄ 消費量 (mg/l)	原水	最大	15.8	5.4	6.3	11.0	10.0	8.6	12.3	7.0	5.7	4.1	9.3	5.8	15.8
		最小	2.2	3.0	3.0	2.2	2.2	2.7	2.5	2.5	2.1	2.4	3.0	3.2	2.1
		平均	4.1	3.9	4.4	4.8	4.9	4.5	4.4	4.4	3.5	3.2	4.5	4.0	4.2
(mg/l)	浄水	最大	1.4	2.5	1.6	1.4	1.9	1.6	1.9	1.9	1.4	1.7	1.9	2.2	2.5
		最小	0.5	0.6	0.5	0.6	0.6	0.3	0.3	0.6	0.6	0.6	0.6	1.0	0.3
		平均	0.8	1.2	1.0	1.0	1.3	0.9	1.1	1.3	1.0	1.1	1.3	1.7	1.1
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.7	0.8	0.8	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.8
		最小	0.4	0.4	0.6	0.6	0.6	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4
		平均	0.5	0.5	0.7	0.7	0.7	0.5	0.6	0.5	0.5	0.4	0.4	0.5	0.5

豊田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	27.9	27.8	32.2	32.8	27.0	23.7	19.0	19.7	9.3	17.4	19.5	32.8	
	最小	7.6	19.3	19.0	20.1	24.1	19.1	14.7	8.4	4.0	-0.1	1.1	3.4	-0.1	
	平均	15.7	22.8	23.4	27.3	29.2	24.2	19.8	15.0	9.4	5.6	6.9	11.6	17.6	
原水水温 (°C)	最大	15.0	19.0	20.0	23.5	24.0	21.0	18.2	15.0	11.6	7.5	6.8	8.3	24.0	
	最小	8.0	14.5	16.5	16.0	21.0	18.5	13.9	11.0	7.0	4.0	4.0	4.9	4.0	
	平均	11.0	16.3	18.8	19.8	22.8	19.5	16.4	13.7	9.4	5.9	5.1	6.7	13.8	
濁度 (度)	原水	最大	31.0	11.2	8.4	23.7	74.5	12.0	7.4	11.1	5.1	15.1	24.1	5.7	74.5
		最小	2.3	1.8	2.0	2.3	1.5	1.8	1.1	1.5	1.7	1.4	1.6	1.7	1.1
		平均	4.9	3.2	3.2	5.9	6.3	4.8	2.6	2.8	2.8	2.4	4.0	2.6	3.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	28.3	9.2	9.4	17.2	81.5	12.3	8.0	10.8	6.6	16.3	23.0	6.3	81.5
		最小	2.8	3.0	3.1	4.7	3.8	4.2	3.4	3.5	3.1	2.1	3.4	2.6	2.1
		平均	5.2	4.0	4.8	7.3	8.9	6.7	4.6	5.5	5.1	3.5	5.1	3.6	5.4
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH	原水	最大	7.4	7.6	7.4	7.4	7.4	7.4	7.5	7.5	7.4	7.5	7.4	7.5	7.6
		最小	7.2	7.3	7.2	7.2	7.1	7.2	7.1	7.3	7.3	7.4	7.3	7.3	7.1
		平均	7.3	7.4	7.3	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.4	7.4	7.3
	浄水	最大	7.5	7.5	7.4	7.4	7.5	7.4	7.5	7.4	7.4	7.5	7.4	7.5	7.5
		最小	7.2	7.3	7.2	7.2	7.3	7.3	7.2	7.2	7.2	7.3	7.3	7.3	7.2
		平均	7.3	7.4	7.3	7.3	7.4	7.4	7.3	7.3	7.3	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	15.5	18.5	20.5	20.5	19.5	17.5	20.5	20.0	19.5	18.0	16.5	16.5	20.5
		最小	12.0	14.0	18.0	12.0	14.5	14.0	16.0	17.0	16.0	15.5	13.5	13.0	12.0
		平均	14.3	16.3	19.5	16.0	16.9	16.2	18.0	18.4	17.4	17.0	15.2	14.7	16.7
	浄水	最大	15.5	17.5	20.0	19.0	19.0	16.5	20.0	19.0	18.0	17.5	15.5	15.0	20.0
		最小	13.0	13.0	17.0	13.0	14.5	13.5	16.0	16.5	15.0	15.5	13.5	12.5	12.5
		平均	14.0	15.7	18.6	15.5	16.2	15.7	17.2	17.5	16.6	16.3	14.8	14.2	16.0
KMnO ₄ 消費量 (mg/l)	原水	最大	19.2	6.8	8.0	14.3	51.2	11.6	7.0	11.4	5.5	11.9	17.4	6.3	51.2
		最小	2.8	2.2	2.5	3.9	3.1	2.7	2.8	2.8	2.7	1.9	1.9	2.7	1.9
		平均	4.7	3.6	4.5	6.6	7.0	5.8	4.5	4.4	3.8	3.1	4.3	3.7	4.7
	浄水	最大	1.6	1.4	2.3	2.0	1.9	1.9	1.9	2.2	2.0	1.4	1.6	1.4	2.3
		最小	0.3	0.3	0.8	0.6	0.6	0.5	0.8	0.8	0.6	0.5	0.5	0.6	0.3
		平均	0.9	0.9	1.3	1.4	1.2	1.1	1.3	1.1	1.1	0.9	1.0	1.0	1.1
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.6	0.7	0.7	0.7	0.7	0.6	0.6	0.6	0.5	0.6	0.7
		最小	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.6	0.6	0.6	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.6

幸田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.7	28.4	28.4	33.5	33.3	28.4	23.7	21.2	22.1	11.1	16.5	18.9	33.5	
	最小	8.0	19.6	19.6	21.4	23.1	19.8	14.4	9.9	4.8	1.2	4.2	4.6	1.2	
	平均	17.0	23.5	24.0	28.0	29.8	25.2	20.0	15.5	10.7	6.5	7.9	11.9	18.3	
原水水温 (°C)	最大	18.0	23.0	24.0	26.0	28.0	23.5	19.5	16.5	12.5	8.5	9.5	12.5	28.0	
	最小	11.5	17.5	19.0	20.0	23.0	20.0	15.0	10.5	7.0	3.5	5.0	7.0	3.5	
	平均	13.9	19.8	21.4	23.0	25.9	21.6	17.5	14.6	10.0	6.0	6.8	10.2	15.9	
濁度 (度)	原水	最大	25.0	10.0	16.0	40.0	29.0	36.0	18.0	15.0	9.1	18.0	30.0	16.0	40.0
		最小	3.7	3.9	2.5	4.2	1.7	3.1	1.4	1.1	1.3	0.9	0.9	1.5	0.9
		平均	8.8	5.7	5.7	13.0	7.7	9.7	3.0	3.3	2.6	2.1	4.5	4.4	5.9
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	37.0	16.0	22.0	51.0	48.0	48.0	16.0	21.0	16.0	21.0	31.0	18.0	51.0
		最小	6.4	8.0	7.2	9.0	6.7	8.5	4.5	4.3	3.8	3.0	3.3	4.0	3.0
		平均	12.5	10.4	10.9	19.5	13.9	15.3	6.2	7.5	5.8	4.5	7.0	7.2	10.1
	浄水	最大	<0.5	<0.5	0.5	0.7	0.5	0.6	<0.5	<0.5	0.5	<0.5	<0.5	<0.5	0.7
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH	原水	最大	7.4	7.5	7.5	7.4	7.5	7.4	7.5	7.5	7.4	7.4	7.5	7.5	7.5
		最小	7.2	7.2	7.3	7.2	7.1	7.1	7.4	7.3	7.3	7.3	7.3	7.3	7.1
		平均	7.4	7.4	7.4	7.3	7.4	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4
	浄水	最大	7.4	7.5	7.4	7.5	7.5	7.4	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.4	7.4	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.4	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	19.0	20.0	22.5	22.0	20.0	17.5	20.0	21.0	21.0	21.0	20.0	19.0	22.5
		最小	12.0	14.5	17.5	11.5	12.5	11.5	16.0	18.5	13.5	17.0	12.5	13.0	11.5
		平均	17.2	18.6	20.6	16.6	17.9	15.9	18.8	20.0	19.5	19.7	17.8	17.7	18.4
	浄水	最大	18.0	19.0	21.5	21.5	19.0	17.0	19.0	20.0	20.0	19.5	19.0	18.5	21.5
		最小	12.5	14.0	17.0	12.0	14.0	13.0	14.0	17.5	15.5	16.5	13.0	13.5	12.0
		平均	16.5	17.7	19.7	16.4	17.2	15.2	17.7	19.0	18.8	19.0	16.9	16.6	17.6
KMnO ₄ 消費量 (mg/l)	原水	最大	16.0	12.4	16.8	26.0	25.2	19.8	9.4	13.8	13.7	10.3	10.8	12.0	26.0
		最小	4.5	3.8	5.2	5.8	3.5	5.7	3.2	2.7	2.9	2.5	2.3	3.2	2.3
		平均	7.4	6.7	7.6	12.6	9.3	9.1	4.4	5.6	4.5	3.6	4.4	4.9	6.7
	浄水	最大	1.9	1.9	2.2	2.2	2.4	1.6	2.1	1.9	2.1	1.9	1.7	1.8	2.4
		最小	0.8	0.8	0.9	0.8	0.8	0.6	0.8	0.8	0.6	0.8	0.5	0.5	0.5
		平均	1.3	1.3	1.4	1.4	1.3	1.2	1.1	1.2	1.1	1.0	0.9	1.0	1.2
残留塩素 (mg/l)	浄水	最大	0.6	0.8	0.8	0.9	0.9	0.8	0.7	0.8	0.7	0.6	0.6	0.6	0.9
		最小	0.5	0.6	0.6	0.7	0.6	0.7	0.6	0.6	0.5	0.5	0.5	0.4	0.4
		平均	0.6	0.6	0.7	0.8	0.8	0.7	0.7	0.7	0.6	0.5	0.5	0.5	0.6

(2)工業用水毎日検査

尾張東部浄水場(東郷)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	28.5	28.0	32.0	34.0	26.0	21.0	19.0	19.0	8.0	15.0	17.0	34.0	
	最小	6.0	16.0	18.0	19.0	22.0	17.0	12.0	6.0	3.0	-2.0	2.0	1.0	-2.0	
	平均	15.1	21.8	23.5	26.6	28.6	23.4	17.9	13.3	8.0	3.8	5.0	9.1	16.3	
原水水温 (°C)	最大	15.0	19.5	21.0	24.0	27.0	24.0	20.0	16.0	12.5	8.0	7.0	10.0	27.0	
	最小	9.5	15.0	19.0	20.0	24.0	20.5	16.5	13.0	8.0	5.0	5.5	6.5	5.0	
	平均	11.6	17.4	19.8	21.5	25.1	21.5	18.1	14.8	10.1	6.7	6.1	8.4	15.1	
濁度 (度)	原水	最大	7.0	5.0	4.0	38.0	6.0	10.0	15.0	5.0	6.0	2.0	8.0	6.0	38.0
		最小	3.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.0	2.0	3.0	1.0
		平均	3.0	3.0	3.0	6.0	3.0	4.0	5.0	3.0	3.0	1.0	3.0	3.0	3.3
	配水	最大	5.0	3.0	1.0	4.0	2.0	3.0	5.0	3.0	4.0	2.0	7.0	4.0	7.0
		最小	2.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	2.0	2.0	1.0
		平均	3.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	2.0	1.0	3.0	3.0	1.0
pH	原水	最大	7.5	7.5	7.4	7.4	7.2	7.4	7.7	7.6	7.5	7.6	7.5	7.6	7.7
		最小	7.3	7.3	7.2	7.1	7.0	7.0	7.2	7.2	7.3	7.4	7.5	7.3	7.0
		平均	7.4	7.4	7.3	7.2	7.1	7.2	7.4	7.5	7.4	7.5	7.2	7.4	7.3
	配水	最大	7.4	7.4	7.4	7.4	7.3	7.3	7.4	7.4	7.4	7.4	7.5	7.4	7.5
		最小	7.3	7.3	7.2	6.9	7.0	6.9	7.1	7.3	7.2	7.3	7.3	7.2	6.9
		平均	7.4	7.4	7.3	7.2	7.1	7.1	7.3	7.4	7.4	7.4	7.4	7.4	7.3
TSS (mg/l)	原水	最大	14.5	15.5	17.5	17.0	16.5	15.5	18.0	19.5	17.0	17.5	16.5	15.0	19.5
		最小	12.0	13.0	15.0	11.5	13.0	12.5	13.5	14.5	14.0	15.5	13.0	12.5	11.5
		平均	13.0	14.6	16.2	14.8	15.4	13.8	15.6	16.4	15.6	16.6	14.6	13.9	15.0
	配水	最大	15.5	15.5	17.5	17.0	16.5	15.0	17.5	19.0	16.5	17.0	16.0	14.5	19.0
		最小	11.0	12.5	15.0	10.0	12.5	11.5	12.0	13.5	13.5	15.0	12.0	12.0	10.0
		平均	12.6	14.3	16.1	14.4	14.9	12.9	14.8	16.0	15.0	15.9	14.1	13.3	14.5

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.5	27.0	27.5	32.0	33.0	27.5	25.0	21.0	19.5	10.5	15.5	18.5	33.0	
	最小	7.5	19.0	19.5	20.5	22.5	19.5	15.0	8.5	5.5	-1.0	3.0	3.5	-1.0	
	平均	16.1	22.6	23.4	27.4	29.0	24.1	19.7	15.2	10.2	5.9	7.0	10.9	17.6	
原水水温 (°C)	最大	15.5	20.0	21.5	24.0	27.0	24.0	20.5	16.0	12.5	8.5	7.5	11.0	27.0	
	最小	10.0	16.0	18.5	20.0	24.0	20.0	16.5	13.0	8.5	5.5	5.5	7.0	5.5	
	平均	12.1	17.8	20.0	22.1	25.3	21.7	18.2	15.0	10.5	7.0	6.6	9.0	15.4	
濁度 (度)	原水	最大	12.2	9.1	5.2	23.2	6.4	8.5	31.9	4.1	4.0	2.2	7.2	6.0	31.9
		最小	4.6	3.3	2.3	1.7	2.5	2.3	2.4	2.0	1.6	1.5	1.8	3.8	1.5
		平均	6.8	5.8	3.7	6.0	4.1	4.3	6.5	2.9	2.4	1.8	3.7	4.7	4.4
	配水	最大	3.8	2.8	2.1	4.2	2.7	3.5	4.8	2.2	2.8	1.5	4.2	2.8	4.8
		最小	0.8	0.9	1.2	1.3	1.3	1.4	0.9	0.9	1.2	1.0	1.0	1.5	0.8
		平均	2.4	1.9	1.7	2.4	1.9	2.2	1.9	1.6	1.7	1.2	2.3	2.1	1.9
pH	原水	最大	7.4	7.5	7.5	7.4	7.4	7.5	7.5	7.6	7.5	7.5	7.5	7.5	7.6
		最小	7.2	7.2	7.1	7.1	7.2	7.2	7.2	7.3	7.3	7.4	7.2	7.3	7.1
		平均	7.4	7.4	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.5	7.4	7.4	7.4
配水	最大	7.3	7.2	7.2	7.2	7.2	7.2	7.3	7.3	7.3	7.4	7.3	7.3	7.4	
	最小	7.1	7.1	7.1	6.9	7.1	7.1	6.9	7.2	7.2	7.2	7.1	7.1	6.9	
	平均	7.2	7.2	7.2	7.1	7.1	7.1	7.2	7.2	7.2	7.3	7.2	7.2	7.2	
TSS (mg/l)	原水	最大	13.0	15.0	16.5	16.0	16.0	14.5	16.5	18.5	16.0	17.0	16.0	14.0	18.5
		最小	11.5	12.0	14.5	11.0	12.5	12.0	12.0	14.0	13.0	14.5	12.0	12.0	11.0
		平均	12.2	13.9	15.3	13.9	14.5	13.2	14.1	15.8	14.6	15.7	13.9	13.1	14.2
	配水	最大	12.5	13.5	14.5	15.0	15.5	13.5	15.5	17.0	15.0	15.0	15.0	13.5	17.0
		最小	10.0	11.0	13.5	8.5	11.0	11.0	9.0	12.5	11.5	13.0	11.0	10.5	8.5
		平均	11.2	12.7	14.2	12.9	13.8	12.2	12.9	14.1	13.3	14.1	12.6	12.1	13.0

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.0	30.0	28.0	34.0	35.0	33.0	24.0	20.0	17.0	11.0	16.0	17.0	35.0	
	最小	7.0	19.0	19.0	22.0	22.0	18.0	15.0	7.0	5.0	-2.0	3.0	2.0	-2.0	
	平均	16.0	23.0	23.9	27.9	29.8	24.5	19.9	14.7	9.8	5.5	7.0	10.6	17.7	
原水水温 (°C)	最大	16.5	21.0	23.0	26.0	27.0	26.0	22.5	17.5	14.0	9.5	8.5	12.0	27.0	
	最小	11.0	17.0	21.0	22.0	26.0	23.0	18.0	14.0	9.5	6.0	6.5	7.5	6.0	
	平均	13.2	19.3	21.8	24.0	26.8	24.0	20.1	16.3	11.7	8.0	7.3	9.8	16.9	
濁度 (度)	原水	最大	7.8	6.9	4.9	5.8	6.3	5.9	6.7	4.7	3.7	3.7	4.9	5.9	7.8
		最小	5.0	2.2	2.1	2.0	1.9	2.4	2.5	2.4	2.3	2.2	2.1	3.1	1.9
		平均	6.0	4.0	2.6	2.8	3.1	3.3	3.7	3.0	3.0	2.5	3.1	4.3	3.5
	配水	最大	4.2	5.9	3.4	4.0	5.1	5.0	6.4	3.9	2.7	2.0	3.6	3.9	6.4
		最小	1.6	1.6	1.0	2.0	1.2	2.3	1.5	0.2	1.1	1.2	1.5	1.1	0.2
		平均	2.9	2.9	2.5	2.6	2.5	3.0	3.5	2.4	1.7	1.7	2.2	2.8	2.6
pH	原水	最大	7.5	7.4	7.2	7.2	7.3	7.3	7.4	7.6	7.7	7.7	7.6	7.6	7.7
		最小	7.4	7.1	7.1	7.0	6.9	7.1	7.2	7.3	7.5	7.5	7.4	7.4	6.9
		平均	7.4	7.1	7.1	7.1	7.1	7.2	7.3	7.4	7.5	7.6	7.5	7.5	7.3
	配水	最大	7.5	7.2	7.3	7.2	7.3	7.3	7.4	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.2	7.0	7.1	7.0	6.9	7.1	7.2	7.2	7.3	7.4	7.3	7.3	6.9
		平均	7.3	7.1	7.1	7.1	7.1	7.2	7.3	7.4	7.4	7.4	7.4	7.4	7.3
TSS (mg/l)	原水	最大	18.0	16.5	16.5	17.0	16.5	15.5	16.0	18.0	17.0	17.0	17.0	15.5	18.0
		最小	12.5	12.5	14.5	14.0	13.5	13.5	13.5	15.5	15.0	14.5	14.5	13.5	12.5
		平均	14.2	14.1	15.5	15.5	14.7	14.4	14.4	16.6	15.9	15.8	16.1	14.3	15.1
	配水	最大	15.0	20.5	22.0	17.0	17.0	15.5	16.0	17.5	16.5	16.5	17.0	15.0	22.0
		最小	12.0	12.0	14.5	14.5	13.5	13.0	13.5	15.0	14.5	14.5	14.0	13.0	12.0
		平均	13.5	14.4	15.9	15.6	14.8	14.4	14.4	16.5	15.4	15.4	15.7	13.9	15.0

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	27.1	27.5	33.3	33.8	27.5	23.6	19.8	20.3	10.1	13.1	18.2	33.8	
	最小	9.5	16.9	18.8	19.6	23.9	19.2	15.6	10.4	6.0	-2.7	2.8	4.3	-2.7	
	平均	15.8	22.6	23.2	27.2	29.2	24.2	20.2	15.1	10.6	6.5	7.3	11.6	17.8	
原水水温 (°C)	最大	16.3	22.3	22.7	25.1	28.7	21.3	19.8	18.5	11.5	8.5	8.5	12.2	28.7	
	最小	10.0	16.4	19.2	19.0	22.7	19.4	16.6	11.0	7.6	4.3	5.5	7.0	4.3	
	平均	12.1	18.5	21.0	21.8	25.8	20.3	17.7	14.3	9.7	6.9	6.8	9.4	15.4	
濁度 (度)	原水	最大	40.6	8.0	7.6	58.8	20.7	14.0	83.8	5.2	9.3	3.2	42.0	7.5	83.8
		最小	2.5	1.4	1.3	2.8	1.7	1.9	1.7	1.2	1.6	1.0	1.1	1.7	1.0
		平均	7.6	4.2	3.2	8.6	4.8	5.1	9.5	3.0	3.4	1.8	6.5	3.5	5.1
	配水	最大	0.9	0.3	0.2	0.4	0.4	0.4	0.5	0.2	0.5	0.4	0.7	0.7	0.9
		最小	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.3	0.1
		平均	0.3	0.2	0.2	0.2	0.2	0.3	0.3	0.2	0.3	0.2	0.3	0.4	0.3
pH	原水	最大	7.3	7.7	7.5	7.2	7.3	7.3	7.5	7.6	7.4	7.5	7.3	7.3	7.7
		最小	6.9	7.1	7.0	6.8	6.9	7.0	6.9	7.0	7.0	7.0	6.8	6.9	6.8
		平均	7.2	7.4	7.2	7.0	7.1	7.2	7.3	7.3	7.2	7.4	7.1	7.2	7.2
	配水	最大	7.3	7.4	7.3	7.1	7.3	7.2	7.4	7.4	7.3	7.4	7.3	7.4	7.4
		最小	7.0	7.1	7.0	6.9	7.0	7.0	7.1	7.0	7.1	7.2	7.1	7.1	6.9
		平均	7.2	7.2	7.1	7.1	7.1	7.1	7.2	7.2	7.2	7.3	7.2	7.2	7.2
ｱﾙｶﾘ度 (mg/l)	原水	最大	20.5	21.5	20.3	19.0	20.7	21.0	24.0	25.3	23.0	26.4	20.0	20.5	26.4
		最小	9.0	15.4	15.2	10.5	11.8	12.0	11.5	15.5	13.5	17.5	9.0	14.0	9.0
		平均	14.1	16.8	18.1	15.0	17.2	16.0	19.2	19.4	19.3	21.5	15.6	17.5	17.5
	配水	最大	17.0	18.0	18.0	17.0	18.5	18.0	20.0	21.0	21.0	19.0	18.5	18.0	21.0
		最小	8.5	13.0	14.5	10.0	12.0	11.0	12.0	12.0	12.0	15.5	8.5	14.0	8.5
		平均	12.6	14.9	16.1	14.1	15.3	13.8	16.6	16.3	16.0	17.2	14.3	15.7	15.2

安城浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.3	30.0	29.2	35.2	34.6	28.7	25.4	22.2	20.8	11.9	17.1	18.9	35.2	
	最小	8.3	19.8	19.9	21.5	22.6	20.0	15.3	10.5	5.8	1.2	5.2	5.3	1.2	
	平均	17.3	24.1	24.4	28.3	30.3	25.4	21.2	16.3	11.4	7.2	8.7	12.9	19.0	
原水水温 (°C)	最大	17.0	21.8	23.3	25.3	27.1	22.4	20.0	15.8	12.0	8.0	8.3	11.9	27.1	
	最小	9.5	16.8	19.3	18.2	22.5	19.5	15.9	11.8	8.0	4.2	5.5	7.2	4.2	
	平均	12.4	18.8	21.1	21.8	25.2	20.7	17.7	14.5	10.1	6.6	6.5	9.8	15.4	
濁度 (度)	原水	最大	20.0	9.0	8.0	26.0	19.0	26.0	14.0	5.0	5.0	6.0	19.0	34.0	34.0
		最小	2.0	3.0	3.0	3.0	2.0	3.0	1.0	1.0	1.0	1.0	1.0	2.0	1.0
		平均	6.0	6.0	5.0	9.0	6.0	8.0	3.0	2.0	2.0	2.0	4.0	5.0	4.8
	配水	最大	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		最小	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
pH	原水	最大	7.5	7.4	7.4	7.4	7.4	7.5	7.6	7.6	8.1	8.4	8.1	8.1	8.4
		最小	7.2	7.1	7.1	7.1	7.1	7.2	7.3	7.2	7.2	7.3	7.3	7.2	7.1
		平均	7.4	7.3	7.3	7.2	7.2	7.3	7.4	7.4	7.5	7.8	7.5	7.5	7.4
	配水	最大	7.1	7.1	7.0	7.0	7.1	7.0	7.1	7.1	7.2	7.2	7.2	7.2	7.2
		最小	6.9	6.9	6.8	6.7	6.7	6.8	6.9	6.9	6.9	7.0	7.0	7.0	6.7
		平均	7.0	7.0	6.9	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.1	7.1	7.0
ｱﾙｶﾘ度 (mg/l)	原水	最大	19.0	22.0	23.5	23.5	21.5	21.0	23.0	24.5	26.0	25.5	24.0	23.5	26.0
		最小	15.5	17.0	20.0	14.5	18.5	17.0	19.0	20.0	19.0	21.5	17.0	18.5	14.5
		平均	17.6	19.6	22.3	19.0	20.0	18.9	21.4	22.6	23.2	23.5	20.2	21.9	20.9
	配水	最大	17.0	17.5	19.0	19.0	17.5	16.5	19.0	21.0	21.0	21.5	20.0	20.0	21.5
		最小	13.0	13.5	16.0	11.0	14.0	13.0	15.0	16.0	16.0	17.5	14.5	15.0	11.0
		平均	14.7	15.9	17.9	14.9	15.6	14.8	17.3	18.4	18.9	19.5	17.3	18.1	16.9

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	27.1	26.2	32.4	32.4	28.3	23.6	21.1	21.8	11.4	17.2	18.2	32.4	
	最小	8.2	19.2	19.7	20.5	23.5	19.9	15.0	9.4	6.6	0.2	4.6	4.1	0.2	
	平均	16.2	22.4	23.2	26.7	28.7	24.4	20.2	15.9	11.0	6.8	7.9	11.8	17.9	
原水水温 (°C)	最大	14.6	19.1	21.0	23.2	24.5	24.6	22.0	18.0	14.5	10.0	9.2	11.1	24.6	
	最小	10.5	14.2	18.5	19.8	22.5	21.5	17.5	15.0	10.0	6.8	7.0	7.6	6.8	
	平均	12.5	17.0	19.5	21.3	23.3	23.5	19.2	17.1	12.7	8.7	7.9	9.5	16.0	
濁度 (度)	原水	最大	2.3	3.4	1.9	5.5	4.6	15.4	10.7	4.3	6.8	4.4	3.1	2.9	15.4
		最小	0.9	1.1	0.8	1.2	0.8	1.2	1.1	1.6	2.3	1.9	1.1	1.6	0.8
		平均	1.5	1.7	1.3	2.0	2.0	3.7	2.1	2.7	3.4	3.0	1.8	2.1	2.3
	配水	最大	0.3	0.3	0.4	0.5	0.4	0.4	0.4	0.3	0.1	0.1	0.2	0.3	0.5
		最小	0.0	0.1	0.1	0.0	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0
		平均	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.1
pH	原水	最大	7.5	7.5	7.6	7.5	7.5	7.4	8.4	8.2	8.1	7.9	7.6	7.6	8.4
		最小	7.2	7.1	7.2	7.0	7.0	7.1	7.3	7.5	7.5	7.5	7.3	7.2	7.0
		平均	7.4	7.3	7.4	7.2	7.3	7.2	7.6	7.8	7.8	7.7	7.5	7.4	7.5
	配水	最大	7.1	7.1	7.2	7.2	7.1	7.1	7.2	7.2	7.3	7.2	7.1	7.1	7.3
		最小	7.0	6.9	6.9	6.9	6.8	6.8	7.0	6.9	6.9	6.9	6.9	6.9	6.8
		平均	7.0	7.0	7.0	7.0	7.0	6.9	7.1	7.1	7.1	7.1	7.0	7.0	7.0
ｱﾙｶﾘ度 (mg/l)	原水	最大	20.0	18.0	27.5	29.5	20.0	18.5	22.0	20.0	21.0	20.0	18.5	19.0	29.5
		最小	15.0	14.5	15.0	14.5	12.5	15.0	16.0	15.5	14.5	15.0	12.5	15.0	12.5
		平均	17.8	16.2	19.2	17.9	16.3	16.5	18.4	17.6	17.9	17.9	16.3	16.8	17.4
	配水	最大	15.5	14.0	20.0	21.5	15.0	14.0	16.0	16.0	15.5	16.0	14.0	14.5	21.5
		最小	11.5	10.0	10.5	12.5	9.5	11.0	12.5	11.5	11.0	11.0	10.5	11.5	9.5
		平均	13.9	12.1	14.4	14.0	12.2	12.0	14.1	13.6	13.1	13.2	12.4	12.8	13.2

蒲郡浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	28.0	26.0	33.0	32.0	28.0	23.5	20.5	19.0	13.5	16.0	17.0	33.0	
	最小	11.0	19.5	20.0	21.0	23.5	21.0	16.0	11.5	9.0	2.0	7.0	7.0	2.0	
	平均	16.7	22.5	23.3	26.8	28.9	24.8	20.9	16.5	12.5	8.9	9.7	13.0	18.7	
原水水温 (°C)	最大	15.4	19.0	20.9	24.1	26.3	23.5	21.2	18.9	14.5	11.7	10.3	12.5	26.3	
	最小	12.0	15.0	17.5	19.9	22.1	20.5	17.3	14.6	11.3	7.3	7.8	8.8	7.3	
	平均	13.5	16.9	18.8	21.7	23.9	21.8	19.2	16.4	12.8	9.6	8.8	10.7	16.2	
濁度 (度)	原水	最大	3.6	4.7	5.8	11.0	13.7	12.3	6.0	4.5	2.5	3.7	1.7	1.6	13.7
		最小	0.4	0.4	0.7	0.5	0.8	0.5	0.6	0.6	0.3	0.4	0.4	0.5	0.3
		平均	0.9	1.5	2.3	2.2	2.6	2.1	1.0	1.3	1.0	0.9	0.8	0.9	1.5
	配水	最大	0.4	0.4	0.5	1.0	0.6	0.6	0.5	0.6	0.3	0.4	0.4	0.5	1.0
		最小	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	<0.1	<0.1	0.1	0.1	<0.1
		平均	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2
pH	原水	最大	7.3	7.3	7.6	7.6	7.2	7.3	7.3	7.4	7.5	7.5	7.4	7.4	7.6
		最小	7.2	7.2	7.2	7.1	7.0	7.0	7.2	7.2	7.3	7.3	7.2	7.2	7.0
		平均	7.3	7.2	7.3	7.3	7.2	7.1	7.3	7.3	7.4	7.4	7.3	7.3	7.3
	配水	最大	7.3	7.3	7.3	7.3	7.2	7.3	7.4	7.4	7.4	7.4	7.3	7.4	7.4
		最小	7.2	7.1	7.2	7.0	7.0	7.0	7.2	7.1	7.1	7.2	7.1	7.2	7.0
		平均	7.2	7.2	7.2	7.2	7.1	7.1	7.3	7.3	7.3	7.3	7.2	7.3	7.2
7%削減 (mg/l)	原水	最大	23.0	25.0	32.0	35.0	23.0	24.0	25.0	24.0	25.0	25.0	22.0	20.0	35.0
		最小	20.0	19.0	18.0	18.0	16.0	18.0	19.0	19.0	19.0	18.0	17.0	17.0	16.0
		平均	21.7	21.5	21.5	24.2	19.1	21.3	21.6	21.7	22.2	21.5	18.7	18.4	21.1
	配水	最大	21.0	23.0	27.0	31.0	21.0	23.0	22.0	22.0	21.0	21.0	20.0	18.0	31.0
		最小	19.0	16.0	16.0	16.0	16.0	17.0	19.0	19.0	17.0	17.0	15.0	16.0	15.0
		平均	20.1	19.1	19.3	21.9	17.7	20.1	20.6	20.1	19.6	19.2	16.7	16.9	19.3

変更履歴

第2版:2017/2/3	<ul style="list-style-type: none">・尾張東部浄水場(東郷)原水の2月のpH最小値を2.0から7.5に修正・同浄水場原水のpHの年度集計最小値を2.0から7.0に修正
--------------	--