

浄水場機械脱水処理状況調査（H11年度）

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	累計	平均
<b>高蔵寺浄水場</b>															
汚泥処理量	m <sup>3</sup>	499	439	634	648	513	415	471	531	204	612	714	711	6,391	533
汚泥平均濃度	%	5.3	4.7	4.4	9.4	10.5	7.8	10.9	5.1	3.3	3.7	3.4	4.6		6.1
乾燥発生土量	t	26.5	20.9	27.9	60.9	54.1	32.1	51.6	25.5	6.8	22.4	24.0	32.7	385.4	32.1
ケーキ重量	t	65.3	51.3	56.9	104.0	102.0	66.1	91.3	57.3	16.1	55.6	62.8	72.1	800.8	66.7
ケーキ含水率	%	64.4	62.2	56.5	42.9	44.8	49.5	41.4	56.3	59.4	58.3	61.8	56.4		54.5
平均ろ速	kg/m <sup>2</sup> ・h	1.3	1.1	1.1	2.6	3.1	2.3	3.7	1.6	1.0	1.1	1.0	1.3		1.76
<b>尾張東部浄水場（上水）</b>															
汚泥処理量	m <sup>3</sup>	511	1350	909	1848	1036	479	685	834	1107	746	1053	1144	11,702	975
汚泥平均濃度	%	2.6	3.0	3.8	5.4	6.9	6.9	6.5	4.4	4.4	3.9	4.5	3.7		4.7
乾燥発生土量	t	13.1	40.3	34.0	98.7	71.1	32.8	44.4	32.8	49.0	29.4	43.1	40.0	528.7	44.1
ケーキ重量	t	40.4	134.0	103.0	25.7	181.0	84.3	112.0	84.7	141.0	85.8	129.0	129.3	1,250.2	104
ケーキ含水率	%	65.3	67.2	64.3	58.6	56.3	56.2	55.3	57.7	60.5	62.9	60.6	65.6		60.9
平均ろ速	kg/m <sup>2</sup> ・h	0.2	0.3	0.4	0.6	0.6	0.7	0.6	0.3	0.3	0.3	0.2	0.2		0.40
<b>尾張東部浄水場（工水）</b>															
汚泥処理量	m <sup>3</sup>	64.8	19.9	3.6	174.0	82.3	0	0	0	0	149.0	130.0	168.0	792	99
汚泥平均濃度	%	10.2	10.3	10.5	10.6	9.2	0	0	0	0	9.7	8.1	9.1		6.5
乾燥発生土量	t	6.6	2.1	0.4	18.4	7.5	0	0	0	0	14.8	10.5	15.4	75.7	9.5
ケーキ重量	t	19.2	5.4	1.1	46.2	18.7	0	0	0	0	26.9	22.2	35.7	175.4	21.9
ケーキ含水率	%	66.9	61.8	59.6	58.7	61.2	0	0	0	0	57.5	56.5	60.0		40.2
平均ろ速	kg/m <sup>2</sup> ・h	3.9	4.0	3.9	4.8	4.7	0	0	0	0	5.3	3.3	3.8		2.8
<b>上野浄水場（1・2号機）</b>															
汚泥処理量	m <sup>3</sup>	1452	1204	1250	1603	1720	1029	1297	1237	987	1142	1531	1901	16,353	1,363
汚泥平均濃度	%	5.5	3.9	4.9	4.9	2.7	4.8	4.5	2.3	2.2	3.3	3.1	3.6		3.8
乾燥発生土量	t	78.0	42.6	51.0	77.1	45.2	39.6	56.3	27.5	21.8	36.5	45.6	68.2	589.4	49.1
ケーキ重量	t	166.0	101.0	120.0	162.0	107.0	81.0	119.0	70.0	60.0	93.0	151.0	208.3	1,438.3	119.9
ケーキ含水率	%	55.8	56.7	53.2	50.4	58.1	52.7	53.4	60.5	63.8	59.9	69.0	35.1		55.7
平均ろ速	kg/m <sup>2</sup> ・h	0.4	0.4	0.4	0.4	0.3	0.4	0.3	0.1	0.1	0.1	0.1	0.2		0.26
<b>上野浄水場（3号機）</b>															
汚泥処理量	m <sup>3</sup>	498	875	688	944	906	750	779	807	512	532	875	1159	9,325	777
汚泥平均濃度	%	5.7	3.8	5.0	5.0	2.8	4.5	4.2	2.2	2.2	3.3	3.0	3.7		3.8
乾燥発生土量	t	27.8	30.6	31.9	46.3	24.1	27.7	31.5	17.5	11.3	16.7	25.7	42.0	333.1	27.8
ケーキ重量	t	56.7	74.3	73.4	98.4	57.3	63.8	58.0	45.8	30.6	44.2	92.7	131.9	827.1	68.9
ケーキ含水率	%	55.6	57.4	53.9	50.5	57.4	52.8	53.6	60.1	64.4	59.6	66.7	65.2		58.1
平均ろ速	kg/m <sup>2</sup> ・h	0.5	0.4	0.4	0.5	0.3	0.4	0.3	0.1	0.1	0.1	0.1	0.2		0.28

浄水場機械脱水処理状況調査（H12年度）

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	累計	平均
<b>高蔵寺浄水場</b>															
汚泥処理量	m <sup>3</sup>	583	570	601	529	643	625	583	690	283	583	364	611	6,665	555
汚泥平均濃度	%	4.0	3.3	3.4	5.0	3.8	7.3	11.8	4.6	7.2	10.3	5.2	3.2		5.8
乾燥発生土量	t	23.2	19.0	20.4	26.4	24.0	45.0	68.6	31.1	19.8	60.3	19.0	19.6	376.4	31.4
ケーキ重量	t	55.8	45.6	46.6	51.6	52.2	77.8	115.5	58.3	34.9	114.5	38.8	46.6	738.2	61.5
ケーキ含水率	%	60.6	61.2	60.2	51.6	59.5	46.7	38.8	55.7	49.0	47.7	59.3	66.8		54.8
平均ろ速	kg/m <sup>2</sup> ・h	1.13	0.96	0.99	1.53	1.20	2.26	2.99	1.44	1.97	2.54	1.30	0.77		1.59
<b>尾張東部浄水場（上水）</b>															
汚泥処理量	m <sup>3</sup>	1,574	2,403	2,516	2,074	1,402	857	536	679	1,144	1,107	2,077	2,710	19,079	1,590
汚泥平均濃度	%	3.5	2.7	3.2	2.8	4.0	6.2	12.2	9.6	10.1	11.2	4.3	2.3		6.0
乾燥発生土量	t	50.8	64.3	78.8	55.4	56.5	50.6	64.8	62.7	95.9	121.3	84.8	59.8	845.7	70.5
ケーキ重量	t	167.5	206.7	234.3	167.7	154.0	119.2	149.4	157.7	235.6	294.6	256.4	220.8	2,363.9	197
ケーキ含水率	%	64.6	64.8	62.1	60.5	58.3	53.4	47.4	53.8	56.1	54.0	64.9	71.0		59.2
平均ろ速	kg/m <sup>2</sup> ・h	0.26	0.23	0.29	0.26	0.39	0.56	1.27	0.97	0.77	1.06	0.26	0.13		0.54
<b>尾張東部浄水場（工水）</b>															
汚泥処理量	m <sup>3</sup>	132.3	229.7	289.6	275.7	256.90	253.2	653.4	511.7	302.4	326.4	292.8	176.4	3,701	463
汚泥平均濃度	%	9.8	9.3	8.7	9.4	10.5	12.4	10.5	10.2	11.3	13.4	13.8	13.8		11.1
乾燥発生土量	t	13.0	21.3	25.2	26.0	27.1	31.5	68.5	51.9	34.2	43.9	40.2	24.3	407.1	50.9
ケーキ重量	t	30.4	50.4	55.5	57.0	61.0	55.9	90.5	116.8	73.8	92.4	83.9	52.5	820.1	102.5
ケーキ含水率	%	57.2	55.9	54.0	55.0	51.90	45.2	45.3	55.6	55.3	53.3	51.0	49.3		52.4
平均ろ速	kg/m <sup>2</sup> ・h	3.92	3.91	3.82	4.35	4.86	6.65	7.41	5.77	6.50	7.52	7.21	6.16		5.7
<b>上野浄水場（1号機）</b>															
汚泥処理量	m <sup>3</sup>	144	688	748	487	673	581	668	457	762	714	692	1,072	7,686	641
汚泥平均濃度	%	2.9	4.1	3.6	3.1	3.7	5.5	7.7	5.1	4.0	4.3	3.7	3.8		4.3
乾燥発生土量	t	4.1	27.3	24.9	14.7	24.2	30.7	50.7	21.7	29.4	30.0	24.5	39.5	321.7	26.8
ケーキ重量	t	10.0	69.0	60.0	35.0	57.0	64.0	103.0	48.0	67.0	67.0	61.0	103.0	744.0	62.0
ケーキ含水率	%	63.5	58.5	59.0	57.6	55.3	48.8	46.4	50.5	53.1	54.3	57.1	58.3		55.2
平均ろ速	kg/m <sup>2</sup> ・h	0.08	0.42	0.30	0.24	0.26	0.48	0.58	0.27	0.19	0.20	0.13	0.22		0.28
<b>上野浄水場（2号機）</b>															
汚泥処理量	m <sup>3</sup>	1,090	810	679	1,132	701	474	693	768	759	578	719	1,074	9,477	790
汚泥平均濃度	%	3.7	4.4	3.7	3.3	3.7	6.0	7.7	4.6	4.0	4.1	3.7	3.8		4.4
乾燥発生土量	t	36.5	34.0	23.8	36.8	25.2	27.9	52.6	32.7	29.8	23.3	25.6	40.0	388.2	32.4
ケーキ重量	t	87.0	85.0	56.0	91.0	62.0	59.0	109.0	73.0	68.0	52.0	61.0	102.0	905.0	75.4
ケーキ含水率	%	60.4	57.3	57.1	58.0	55.3	47.7	45.7	51.0	52.6	52.7	59.3	58.6		54.6
平均ろ速	kg/m <sup>2</sup> ・h	0.20	0.41	0.36	0.23	0.26	0.56	0.66	0.24	0.21	0.16	0.13	0.21		0.30
<b>上野浄水場（3号機）</b>															
汚泥処理量	m <sup>3</sup>	982	798	691	762	762	354	696	541	769	774	706	1053	8,888	741
汚泥平均濃度	%	3.8	4.4	3.5	3.5	3.6	6.1	7.7	4.8	4.0	4.3	3.7	3.7		4.4
乾燥発生土量	t	33.3	33.0	22.6	26.2	26.3	21.2	52.5	24.2	30.2	32.5	25.0	38.5	365.5	30.5
ケーキ重量	t	78.0	81.0	55.7	65.5	62.6	42.4	107.4	53.7	67.9	72.3	61.1	98.4	846.0	70.5
ケーキ含水率	%	60.9	58.0	59.0	58.3	56.5	47.6	46.5	51.1	52.2	52.4	57.6	59.0		54.9
平均ろ速	kg/m <sup>2</sup> ・h	0.18	0.33	0.26	0.24	0.24	0.59	0.60	0.24	0.20	0.19	0.13	0.20		0.28

浄水場機械脱水処理状況調査（H13年度）

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	累計	平均
<b>高蔵寺浄水場</b>															
汚泥処理量	m <sup>3</sup>	544.7	665.4	635.1	659.1	698.8	645.4	778.0	251.7	571.9	559.1	423.2	514.2	6,947	579
汚泥平均濃度	%	2.9	3.7	3.0	4.5	3.8	4.3	3.4	3.6	4.0	4.0	4.4	4.1		3.8
乾燥発生土量	t	16.08	24.72	18.98	29.51	26.87	27.92	26.49	9.09	22.99	22.11	18.71	20.82	264.3	22.0
ケーキ重量	t	34.09	50.80	38.28	54.82	56.89	57.70	56.46	19.09	48.14	55.95	47.70	46.61	566.5	47.2
ケーキ含水率	%	65.3	62.0	64.6	53.8	58.4	57.4	60.7	62.8	60.5	68.1	67.9	65.9		62.3
平均ろ速	kg/m <sup>2</sup> ・h	0.77	0.96	0.80	1.29	1.13	1.29	1.01	1.03	1.15	0.90	0.91	0.88		1.01
<b>尾張東部浄水場（上水）</b>															
汚泥処理量	m <sup>3</sup>	2,226.0	1,889.0	2,540.0	2,434.0	3,198.0	2,334.0	782.0	1,185.0	1,029.0	2,322.0	2,502.0	1,945.0	24,386	2,032
汚泥平均濃度	%	2.9	2.3	2.8	3.3	3.0	2.2	1.9	2.5	1.6	1.3	1.5	2.1		2.3
乾燥発生土量	t	61.42	43.23	71.80	74.54	91.75	50.32	15.11	28.66	16.45	30.18	34.91	40.98	559.4	46.6
ケーキ重量	t	220.60	178.81	254.59	223.03	301.97	157.22	46.49	95.54	60.04	117.95	131.63	150.49	1,938.4	162
ケーキ含水率	%	68.3	72.4	69.2	63.7	65.8	64.6	65.7	68.1	72.0	73.4	72.0	70.6		68.8
平均ろ速	kg/m <sup>2</sup> ・h	0.18	0.17	0.23	0.29	0.25	0.19	0.18	0.18	0.11	0.08	0.08	0.12		0.17
<b>尾張東部浄水場（工水）</b>															
汚泥処理量	m <sup>3</sup>	24.8	93.3	119.9	163.0	140.20	49.2	143.8	51.4	142.6	145.0	218.3	184.4	1,476	184
汚泥平均濃度	%	15.0	16.1	15.5	12.3	13.8	14.1	14.5	14.6	13.3	13.3	12.6	13.0		14.0
乾燥発生土量	t	3.78	15.06	18.57	20.13	19.38	6.99	20.96	7.53	18.91	19.28	27.52	23.92	202.0	25.3
ケーキ重量	t	7.53	29.83	34.97	47.07	39.77	13.40	42.96	15.76	46.44	44.28	59.19	51.33	432.5	54.1
ケーキ含水率	%	44.8	45.7	44.6	47.2	44.60	42.4	45.8	47.6	53.1	51.4	50.7	47.6		47.1
平均ろ速	kg/m <sup>2</sup> ・h	6.71	6.91	6.08	5.48	6.08	6.34	6.43	6.27	5.51	5.54	5.08	5.03		6.0
<b>上野浄水場（1号機）</b>															
汚泥処理量	m <sup>3</sup>	834.3	932.8	769.0	586.9	796.4	910.4	773.8	752.7	625.8	706.6	685.5	799.8	9,174	765
汚泥平均濃度	%	3.0	2.4	3.3	3.1	2.8	3.4	3.5	3.1	2.6	2.0	2.1	2.4		2.8
乾燥発生土量	t	23.78	21.86	23.34	18.03	21.93	28.73	25.43	22.13	16.16	14.04	14.34	19.08	248.9	20.7
ケーキ重量	t	64.30	61.56	57.80	41.08	51.69	66.87	64.49	57.64	44.69	42.18	42.86	54.05	649.2	54.1
ケーキ含水率	%	64.5	63.5	57.3	54.1	57.0	53.9	57.3	59.3	61.8	65.5	66.6	64.0		60.4
平均ろ速	kg/m <sup>2</sup> ・h	0.14	0.14	0.26	0.26	0.24	0.27	0.18	0.11	0.09	0.08	0.08	0.10		0.16
<b>上野浄水場（2号機）</b>															
汚泥処理量	m <sup>3</sup>	790.6	920.3	1,212.5	1,004.3	592.9	694.4	712.8	705.6	564.0	581.6	687.9	739.8	9,207	767
汚泥平均濃度	%	2.9	2.4	3.4	3.8	3.3	3.6	3.4	3.1	2.7	2.0	2.1	2.5		2.9
乾燥発生土量	t	22.10	21.63	38.47	36.66	17.93	22.96	22.61	20.67	14.91	11.38	14.41	17.88	261.6	21.8
ケーキ重量	t	59.52	62.10	94.50	79.41	41.87	52.03	55.12	53.69	40.00	34.49	43.25	50.20	666.2	55.5
ケーキ含水率	%	64.6	64.0	56.4	52.2	55.7	54.3	57.9	60.0	62.1	65.8	66.2	63.9		60.3
平均ろ速	kg/m <sup>2</sup> ・h	0.14	0.14	0.24	0.29	0.22	0.26	0.17	0.11	0.09	0.07	0.07	0.10		0.16
<b>上野浄水場（3号機）</b>															
汚泥処理量	m <sup>3</sup>	808.9	799.3	634.9	861.6	664.5	493.1	623.6	615.5	486.5	595.8	376.6	719.2	7,680	640
汚泥平均濃度	%	3.0	2.4	4.5	3.8	2.6	3.6	3.3	3.0	2.6	1.9	2.0	2.5		2.9
乾燥発生土量	t	22.94	18.54	23.34	31.59	16.80	16.17	19.54	17.28	12.48	11.56	7.65	17.38	215.3	17.9
ケーキ重量	t	59.49	53.34	52.97	67.89	41.06	37.07	49.75	45.04	30.99	34.11	21.15	49.77	542.6	45.2
ケーキ含水率	%	63.3	65.7	55.2	54.0	58.0	54.7	58.9	61.0	63.5	65.9	65.3	64.0		60.8
平均ろ速	kg/m <sup>2</sup> ・h	0.13	0.12	0.26	0.28	0.18	0.20	0.14	0.10	0.07	0.05	0.05	0.11		0.14

浄水場機械脱水処理状況調書（H14年度）

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	累計	平均
<b>高蔵寺浄水場</b>															
汚泥処理量	m <sup>3</sup>	615.1	633.2	545.3	544.5	557.1	473.9	710.9	614.7	120.0	458.9	524.3	394.0	6,192	516
汚泥平均濃度	%	4.0	4.3	4.2	3.8	5.0	4.2	3.9	3.3	3.2	3.0	2.7	2.3		3.7
乾燥発生土量	t	24.37	27.01	22.96	21.00	28.03	20.03	27.76	20.46	3.84	13.94	13.91	9.08	232.4	19.4
ケーキ重量	t	48.45	60.43	55.26	46.11	54.06	44.43	62.04	44.32	12.45	44.23	42.05	26.57	540.4	45.0
ケーキ含水率	%	62.6	62.3	63.5	60.5	53.8	61.3	63.6	66.1	67.6	68.0	68.5	67.1		63.7
平均ろ速	kg/m <sup>2</sup> ・h	0.99	1.22	1.08	1.00	1.32	1.11	1.00	0.78	0.69	0.63	0.53	0.50		0.90
<b>尾張東部浄水場（上水）</b>															
汚泥処理量	m <sup>3</sup>	1,716.0	1,623.0	2,152.0	2,886.0	2,009.0	1,599.0	1,680.0	1,446.0	1,646.0	2,032.0	1,555.0	1,554.0	21,898	1,825
汚泥平均濃度	%	2.5	2.6	2.3	2.1	2.4	2.7	2.4	2.2	1.6	1.6	1.5	2.4		2.2
乾燥発生土量	t	42.53	42.69	50.26	61.67	47.50	42.77	39.92	30.73	26.14	31.83	23.35	37.12	476.5	39.7
ケーキ重量	t	149.18	148.24	177.77	211.73	143.66	128.12	117.60	100.50	92.49	116.90	89.47	138.19	1,613.9	135
ケーキ含水率	%	69.6	70.1	70.3	68.6	64.3	64.6	64.1	68.0	70.6	72.4	73.0	72.7		69.0
平均ろ速	kg/m <sup>2</sup> ・h	0.15	0.19	0.21	0.20	0.20	0.24	0.23	0.16	0.10	0.09	0.09	0.12		0.17
<b>尾張東部浄水場（工水）</b>															
汚泥処理量	m <sup>3</sup>	92.5	158.8	131.7	170.7	80.6	23.6	29.2	66.8	69.4	111.7	69.7	29.9	1,035	129
汚泥平均濃度	%	14.1	15.0	14.4	11.4	6.6	5.4	11.8	9.8	6.2	6.0	5.9	2.7		9.1
乾燥発生土量	t	13.14	23.80	18.96	18.85	5.33	1.28	3.53	6.86	4.64	6.42	4.12	0.88	107.8	13.5
ケーキ重量	t	28.26	47.73	38.75	36.91	10.32	2.55	6.44	12.57	8.29	11.61	7.92	1.44	212.8	26.6
ケーキ含水率	%	47.6	43.6	44.1	44.7	44.5	43.2	41.0	42.1	42.6	44.0	44.4	44.4		43.9
平均ろ速	kg/m <sup>2</sup> ・h	5.65	5.99	5.71	4.78	3.46	3.27	5.40	5.19	4.32	3.50	3.43	2.41		4.4
<b>上野浄水場（1号機）</b>															
汚泥処理量	m <sup>3</sup>	768.7	965.9	930.9	933.8	886.0	580.4	1,005.2	682.4	711.5	364.0	710.3	799.9	9,339	778
汚泥平均濃度	%	2.8	3.0	3.3	3.2	3.7	3.7	4.5	2.9	2.6	3.3	2.6	1.7		3.1
乾燥発生土量	t	21.11	27.63	29.81	28.29	32.08	21.01	42.25	19.17	17.76	11.74	17.63	13.50	282.0	23.5
ケーキ重量	t	56.63	63.98	62.89	66.12	71.89	49.78	96.27	47.60	48.00	28.41	50.91	43.58	686.1	57.2
ケーキ含水率	%	62.6	61.7	56.9	54.4	56.4	55.7	53.3	60.4	61.2	59.7	65.8	71.1		59.9
平均ろ速	kg/m <sup>2</sup> ・h	0.15	0.21	0.22	0.25	0.25	0.28	0.28	0.13	0.11	0.13	0.10	0.08		0.18
<b>上野浄水場（2号機）</b>															
汚泥処理量	m <sup>3</sup>	774.0	1,014.0	983.2	866.5	667.5	597.6	643.5	558.8	551.3	367.8	435.4	827.9	8,288	691
汚泥平均濃度	%	2.8	3.0	3.0	3.2	3.5	3.7	4.7	3.1	2.4	2.5	2.3	1.7		3.0
乾燥発生土量	t	21.28	29.33	28.44	26.52	22.76	21.72	27.57	16.73	12.97	9.33	10.00	14.01	240.7	20.1
ケーキ重量	t	56.14	64.03	63.10	55.84	50.65	50.56	60.38	37.97	33.59	23.77	23.68	44.57	564.3	47.0
ケーキ含水率	%	63.0	61.0	58.6	54.1	58.0	55.6	52.6	59.2	62.0	62.3	65.0	70.1		60.1
平均ろ速	kg/m <sup>2</sup> ・h	0.15	0.22	0.20	0.24	0.18	0.20	0.24	0.12	0.09	0.07	0.06	0.07		0.15
<b>上野浄水場（3号機）</b>															
汚泥処理量	m <sup>3</sup>	763.9	932.5	901.2	803.9	802.5	874.4	990.9	563.6	607.0	545.0	708.4	777.3	9,271	773
汚泥平均濃度	%	2.8	3.0	3.0	3.4	3.8	3.7	4.5	2.7	2.5	3.1	2.6	1.7		3.1
乾燥発生土量	t	21.05	26.89	26.02	26.59	29.48	31.83	41.60	14.82	14.76	16.36	17.62	13.12	280.1	23.3
ケーキ重量	t	56.35	63.33	58.51	61.09	66.01	79.77	98.17	38.58	43.51	42.71	51.38	44.83	704.2	58.7
ケーキ含水率	%	64.3	63.4	59.6	53.8	55.6	55.9	52.9	60.2	61.3	61.5	65.4	70.3		60.4
平均ろ速	kg/m <sup>2</sup> ・h	0.15	0.21	0.21	0.25	0.28	0.27	0.30	0.14	0.11	0.12	0.10	0.09		0.19

浄水場機械脱水処理状況調査（H15年度）

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	累計	平均
<b>高蔵寺浄水場</b>															
汚泥処理量	m <sup>3</sup>	475.3	668.9	541.2	689.9	780.2	755.0	828.0	735.7	628.1	956.6	2178.4	825.8	10,063	839
汚泥平均濃度	%	2.5	4.3	5.1	4.0	4.9	5.4	2.3	1.7	1.5	3.2	1.9	2.8		3.3
乾燥発生土量	t	12.13	29.04	27.81	27.60	38.19	41.20	18.51	12.30	9.26	29.81	40.77	22.87	309.5	25.8
ケーキ重量	t	32.52	62.83	67.06	73.02	94.37	98.82	46.11	35.14	29.32	77.16	112.97	52.37	781.7	65.1
ケーキ含水率	%	65.5	56.3	60.2	63.1	60.0	59.4	64.9	70.1	69.3	61.7	68.7	62.1		63.4
平均ろ速	kg/m <sup>2</sup> ・h	0.56	1.16	1.46	1.06	1.59	1.77	0.81	0.57	0.50	0.84	0.51	0.84		0.97
<b>尾張東部浄水場（上水）</b>															
汚泥処理量	m <sup>3</sup>	1,598	2,835	2,127	2,334	2,340	2,269	1,944	1,144	1,779	1,290	1,157	1,235	22,052	1,838
汚泥平均濃度	%	2.2	2.7	2.9	2.4	2.3	2.6	2.4	1.9	1.5	1.8	1.7	2.2		2.2
乾燥発生土量	t	35.32	75.06	60.38	56.76	52.72	58.61	46.81	22.21	26.86	21.77	20.18	26.38	503.1	41.9
ケーキ重量	t	129.57	253.85	196.78	183.11	168.92	172.04	140.63	71.52	90.50	81.59	75.48	94.94	1,658.9	138
ケーキ含水率	%	72.3	67.5	68.0	67.1	67.1	64.1	66.3	69.3	71.2	73.0	72.7	71.4		69.2
平均ろ速	kg/m <sup>2</sup> ・h	0.15	0.22	0.24	0.19	0.17	0.19	0.16	0.12	0.08	0.08	0.09	0.11		0.15
<b>尾張東部浄水場（工水）</b>															
汚泥処理量	m <sup>3</sup>	23.1	118.7	51.7	82.1	101.90	102.4	53.0	0.0	99.8	81.6	121.5	125.1	961	120
汚泥平均濃度	%	2.6	5.3	8.0	7.6	5.1	8.4	7.7	脱	6.7	5.8	13.7	9.5		7.3
乾燥発生土量	t	0.60	5.91	4.16	6.09	5.18	8.66	4.07	水	6.79	4.74	16.06	11.36	73.6	9.2
ケーキ重量	t	1.07	12.68	9.05	13.52	10.80	16.97	7.05	機	12.50	9.40	30.34	20.67	144.1	18.0
ケーキ含水率	%	43.0	51.7	50.5	47.8	45.70	46.0	42.5	修	42.0	42.8	42.7	43.0		45.2
平均ろ速	kg/m <sup>2</sup> ・h	2.30	2.23	3.10	3.33	2.67	3.33	3.65	繕	3.39	3.02	5.46	4.27		3.3
<b>上野浄水場（1号機）</b>															
汚泥処理量	m <sup>3</sup>	903.1	835.2	674.6	698.9	688.0	821.2	613.3	613.3	265.5	345.7	446.5	759.6	7,665	639
汚泥平均濃度	%	2.0	3.2	2.9	2.8	3.0	4.3	2.4	2.7	2.6	7.4	2.3	4.6		3.4
乾燥発生土量	t	18.00	22.01	17.89	19.33	20.48	31.62	14.50	15.89	6.40	13.57	9.90	30.45	220.0	18.3
ケーキ重量	t	57.67	54.76	43.34	52.80	50.39	67.00	35.81	40.66	17.97	24.84	26.26	81.30	552.8	46.1
ケーキ含水率	%	67.8	60.9	59.1	63.1	59.6	54.7	60.6	62.7	63.4	48.3	65.1	61.4		60.6
平均ろ速	kg/m <sup>2</sup> ・h	0.11	0.17	0.18	0.16	0.20	0.28	0.14	0.13	0.10	0.31	0.08	0.18		0.17
<b>上野浄水場（2号機）</b>															
汚泥処理量	m <sup>3</sup>	929.0	727.7	977.3	764.6	684.7	808.4	562.2	609.0	193.9	328.1	583.8	732.3	7,901	658
汚泥平均濃度	%	2.0	3.4	3.4	2.7	3.0	4.1	2.8	2.7	2.7	7.4	2.4	4.9		3.5
乾燥発生土量	t	18.52	20.35	29.72	20.71	19.99	30.63	14.99	15.69	4.88	12.70	13.29	30.64	232.1	19.3
ケーキ重量	t	58.89	51.83	68.35	56.46	49.50	67.12	37.24	41.45	13.66	25.90	35.89	81.93	588.2	49.0
ケーキ含水率	%	66.8	60.3	57.2	62.0	59.3	54.1	59.3	61.6	63.1	48.2	64.2	61.9		59.8
平均ろ速	kg/m <sup>2</sup> ・h	0.10	0.12	0.20	0.16	0.21	0.30	0.16	0.13	0.11	0.38	0.09	0.19		0.18
<b>上野浄水場（3号機）</b>															
汚泥処理量	m <sup>3</sup>	863.6	865.2	946.8	748.6	561.0	769.2	585.2	604.2	178.7	233.9	574.1	678.7	7,609	634
汚泥平均濃度	%	2.0	3.3	3.6	2.8	3.0	4.5	2.7	2.7	3.6	8.2	2.4	4.4		3.6
乾燥発生土量	t	17.12	23.48	30.21	21.20	16.04	30.98	14.99	15.58	5.60	10.09	13.04	26.24	224.6	18.7
ケーキ重量	t	55.02	57.45	68.44	56.25	40.97	67.36	36.98	41.17	13.85	20.01	35.92	69.59	563.0	46.9
ケーキ含水率	%	66.8	59.4	56.0	61.9	59.2	53.8	59.5	62.0	58.2	47.7	62.8	62.8		59.2
平均ろ速	kg/m <sup>2</sup> ・h	0.10	0.16	0.22	0.17	0.21	0.31	0.15	0.13	0.16	0.43	0.10	0.17		0.19