

6 浄水場毎日検査

(1)水道用水毎日検査

上野浄水場	198
知多浄水場	198
高蔵寺浄水場	199
尾張東部浄水場	199
犬山浄水場	200
尾張西部浄水場	200

豊田浄水場	201
幸田浄水場	201
豊橋浄水場	202
豊橋南部浄水場	202
豊川浄水場	203

(2)工業用水毎日検査

上野浄水場	204
知多浄水場	204
尾張東部浄水場(東郷)	204
尾張西部浄水場	205
安城浄水場	205
豊橋南部浄水場	205
蒲郡浄水場(工水)	206

(1)水道用水毎日検査

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	28.0	28.0	32.5	33.5	32.5	27.0	19.5	13.5	13.5	12.5	16.5	33.5	
	最小	7.5	15.5	17.0	22.0	25.5	21.5	15.5	8.5	6.0	5.5	2.5	6.5	2.5	
	平均	15.1	21.7	24.1	26.6	30.3	28.0	21.6	14.8	9.5	8.1	7.6	10.9	18.2	
原水水温 (°C)	最大	15.0	19.0	22.0	23.0	26.0	24.0	23.0	17.5	11.5	8.5	8.0	11.0	26.0	
	最小	9.5	15.0	19.0	20.5	23.0	22.5	17.5	11.5	8.5	7.0	6.5	8.0	6.5	
	平均	12.6	17.4	20.2	21.2	24.8	23.2	20.4	14.4	9.6	7.8	7.3	9.3	15.7	
濁度 (度)	原水	最大	4.5	12.7	7.4	14.9	22.4	12.4	11.7	5.3	2.9	2.4	4.2	6.5	22.4
		最小	2.8	2.5	2.4	4.1	3.3	4.3	2.5	2.6	1.4	1.5	1.4	3.2	1.4
		平均	3.5	5.3	5.4	7.7	9.7	6.6	5.7	3.5	2.1	1.8	2.4	4.6	4.9
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	2.7	5.6	4.9	6.7	6.7	4.9	5.3	4.0	3.6	2.9	2.3	2.3	6.7
		最小	1.1	2.4	3.4	3.5	3.5	2.9	2.5	2.9	2.4	1.2	1.4	1.0	1.0
		平均	1.7	3.2	4.2	4.9	4.6	3.7	3.7	3.3	2.9	2.3	1.8	1.8	3.2
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	7.6	7.6	7.4	7.4	7.5	7.5	7.7	7.6	7.5	7.5	7.6	7.7
		最小	7.4	7.2	7.3	7.1	7.2	7.2	7.2	7.4	7.4	7.4	7.3	7.3	7.1
		平均	7.5	7.4	7.4	7.2	7.3	7.4	7.4	7.5	7.5	7.4	7.4	7.4	7.4
	浄水	最大	7.4	7.4	7.2	7.2	7.1	7.2	7.3	7.4	7.4	7.5	7.5	7.4	7.5
		最小	7.3	7.2	7.1	7.1	6.9	7.0	7.1	7.3	7.4	7.3	7.4	7.4	6.9
		平均	7.4	7.3	7.2	7.2	7.0	7.1	7.2	7.4	7.4	7.4	7.4	7.4	7.3
総アルカリ度 (mg/l)	原水	最大	19.0	17.5	16.5	15.5	16.5	17.5	18.0	19.0	19.0	18.0	18.0	16.5	19.0
		最小	17.0	15.0	15.0	13.0	12.0	11.5	14.5	13.0	17.5	16.5	15.0	15.0	11.5
		平均	17.9	16.4	15.9	13.8	13.5	14.5	16.6	17.1	18.6	17.8	16.9	15.8	16.2
	浄水	最大	18.0	17.0	15.0	14.5	14.0	15.5	16.5	18.5	18.5	18.0	17.0	16.0	18.5
		最小	16.5	14.0	14.0	12.0	10.5	10.5	14.5	14.0	17.0	16.0	14.5	14.5	10.5
		平均	17.3	15.4	14.5	13.1	12.1	12.9	15.5	16.4	17.8	16.9	16.1	15.2	15.3
KMnO ₄ 消費量 (mg/l)	原水	最大	3.7	6.2	4.6	6.1	6.8	5.4	5.2	5.4	4.4	3.6	3.6	4.1	6.8
		最小	2.5	2.9	3.5	3.8	3.5	3.3	3.0	3.4	2.8	2.5	2.4	2.5	2.4
		平均	3.1	3.7	4.0	4.8	4.8	4.1	4.1	4.0	3.6	3.0	2.8	3.3	3.8
	浄水	最大	1.3	1.4	1.3	1.6	1.3	1.1	1.3	1.3	1.1	1.1	1.1	1.1	1.6
		最小	0.8	0.6	0.6	0.8	0.8	0.6	0.6	0.6	0.8	0.8	0.8	0.6	0.6
		平均	1.0	1.1	1.0	1.1	1.0	1.0	1.0	1.0	0.9	0.9	0.9	0.9	1.0
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.6	0.6	0.7	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.7
		最小	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4
		平均	0.5	0.5	0.6	0.5	0.6	0.6	0.5	0.5	0.6	0.5	0.5	0.5	0.5

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	32.0	29.0	33.0	35.0	34.0	28.0	19.0	13.0	12.0	11.0	18.0	35.0	
	最小	7.0	16.0	20.0	21.0	24.0	21.0	15.0	8.0	5.0	4.0	2.0	7.0	2.0	
	平均	15.6	22.8	25.3	26.5	31.1	28.6	21.5	14.6	9.1	7.7	7.4	11.2	18.4	
原水水温 (°C)	最大	19.0	23.0	26.0	25.0	31.5	28.0	26.5	18.5	13.0	11.0	11.0	14.5	31.5	
	最小	12.5	15.5	21.0	20.0	22.0	22.0	18.0	13.5	10.0	9.0	8.5	10.0	8.5	
	平均	15.0	20.1	23.1	22.9	27.1	25.8	21.8	16.0	11.2	9.8	9.7	12.4	17.9	
濁度 (度)	原水	最大	13.4	19.0	17.6	43.3	121.6	24.0	15.3	8.2	6.0	7.4	9.2	15.0	121.6
		最小	4.7	4.2	6.2	3.2	3.0	3.2	5.5	3.8	3.1	2.1	2.5	3.5	2.1
		平均	7.5	8.8	9.2	13.7	16.1	6.7	8.1	5.3	4.3	4.4	5.7	6.7	8.0
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	11.9	17.5	18.1	32.7	85.0	15.3	12.6	5.8	5.8	9.0	9.0	13.4	85.0
		最小	4.0	5.7	5.7	4.3	4.3	2.7	4.7	2.6	3.5	2.7	3.0	3.8	2.6
		平均	6.2	8.2	8.8	10.1	11.9	6.4	7.3	4.1	4.5	4.9	4.8	5.9	6.9
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	8.4	8.3	8.0	7.4	8.1	8.3	8.5	7.8	7.7	7.4	8.4	7.7	8.5
		最小	7.0	7.0	6.8	6.8	7.0	7.0	7.0	7.2	7.4	7.2	7.3	7.2	6.8
		平均	7.4	7.3	7.3	7.1	7.4	7.5	7.3	7.6	7.5	7.4	7.7	7.4	7.4
	浄水	最大	7.3	7.2	7.3	7.2	7.4	7.3	7.3	7.3	7.3	7.4	7.3	7.3	7.4
		最小	7.0	7.0	7.0	7.0	7.1	7.1	7.0	7.1	7.2	7.1	7.1	7.1	7.0
		平均	7.1	7.1	7.1	7.1	7.2	7.2	7.1	7.2	7.2	7.2	7.2	7.3	7.2
総アルカリ度 (mg/l)	原水	最大	34.0	35.0	35.0	31.5	35.0	38.0	37.0	39.0	41.0	38.5	40.5	35.0	41.0
		最小	20.0	18.0	20.0	16.0	17.5	18.5	16.0	27.0	36.5	21.5	22.0	20.5	16.0
		平均	29.3	28.3	29.4	24.3	26.5	31.3	28.9	35.1	38.6	32.0	32.8	29.3	30.5
	浄水	最大	32.0	33.0	34.0	30.0	33.0	36.0	35.5	34.5	39.0	36.5	35.5	32.5	39.0
		最小	20.0	18.0	20.5	17.0	18.5	19.0	17.5	25.5	33.5	21.5	20.0	19.0	17.0
		平均	27.7	26.8	28.1	23.8	26.1	29.8	27.9	31.9	35.4	30.4	30.0	27.2	28.8
KMnO ₄ 消費量 (mg/l)	原水	最大	6.9	6.9	8.5	7.9	9.2	6.3	7.3	4.4	5.1	5.1	4.9	6.6	9.2
		最小	2.5	2.5	2.8	2.2	2.5	2.5	3.2	1.5	2.8	2.2	1.3	2.2	1.3
		平均	4.2	4.1	4.7	4.4	4.5	4.0	4.7	3.3	4.2	3.5	3.6	3.9	4.1
	浄水	最大	1.6	1.6	1.6	1.9	1.6	1.6	1.9	1.6	2.2	2.2	1.3	1.6	2.2
		最小	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.6	0.3	0.3	0.6	0.3
		平均	1.2	0.7	0.8	1.0	0.9	0.8	0.9	0.7	1.2	0.8	0.7	0.9	0.9
残留塩素 (mg/l)	浄水	最大	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.5	0.6	0.8
		最小	0.6	0.6	0.6	0.7	0.6	0.7	0.6	0.6	0.6	0.5	0.5	0.5	0.5
		平均	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.6	0.6	0.6	0.5	0.6	0.6

高蔵寺浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.7	29.4	28.3	33.5	33.7	33.6	28.2	20.9	15.0	12.5	14.4	17.7	33.7	
	最小	6.4	16.9	18.0	22.4	24.6	20.9	14.4	9.5	5.5	5.1	3.5	7.3	3.5	
	平均	15.8	22.6	24.5	26.6	30.6	28.4	21.9	15.8	10.0	8.2	8.5	11.9	18.7	
原水水温 (°C)	最大	15.0	18.0	21.3	21.2	26.0	23.0	22.0	15.9	11.8	8.2	8.8	11.1	26.0	
	最小	10.0	13.7	17.5	18.0	20.3	19.6	15.6	10.5	8.0	7.0	6.1	7.3	6.1	
	平均	12.4	16.4	19.0	19.4	23.1	21.7	19.2	13.1	9.3	7.6	7.5	9.6	14.9	
濁度 (度)	原水	最大	14.0	36.4	18.4	71.0	62.5	11.4	34.6	4.9	3.0	4.6	11.0	10.3	71.0
		最小	1.9	3.4	2.0	3.1	2.0	1.9	1.6	1.5	1.3	1.2	1.4	2.9	1.2
		平均	3.6	8.1	3.9	13.1	14.4	3.8	6.5	2.3	1.9	2.0	3.4	5.4	5.7
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	7.0	23.0	9.0	28.0	31.0	8.0	23.0	5.0	5.0	5.0	7.0	8.0	31.0
		最小	3.0	4.0	3.0	4.0	4.0	3.0	3.0	2.0	2.0	2.0	2.0	3.0	2.0
		平均	3.8	6.4	4.8	8.4	9.7	4.5	6.3	3.5	3.1	3.0	3.3	4.9	5.1
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.4	7.3	7.3	7.2	7.3	7.3	7.3	7.4	7.3	7.3	7.3	7.3	7.4
		最小	7.1	7.1	7.1	6.9	6.9	7.0	7.1	7.1	7.2	7.1	7.1	7.1	6.9
		平均	7.3	7.2	7.2	7.1	7.1	7.2	7.2	7.3	7.3	7.2	7.2	7.2	7.2
	浄水	最大	7.3	7.3	7.3	7.3	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3
		最小	7.2	7.2	7.2	7.1	7.1	7.0	7.1	7.1	7.2	7.2	7.1	7.1	7.0
		平均	7.3	7.3	7.2	7.2	7.1	7.1	7.2	7.2	7.3	7.2	7.2	7.2	7.2
総アルカリ度 (mg/l)	原水	最大	21.5	19.0	18.5	17.0	18.5	18.5	20.0	20.5	20.5	20.0	19.0	19.5	21.5
		最小	16.0	12.0	14.5	9.5	7.5	10.5	10.5	14.5	15.5	14.0	10.5	11.5	7.5
		平均	18.7	16.5	16.7	13.2	13.8	15.9	16.0	18.5	19.0	17.2	16.2	15.8	16.5
	浄水	最大	21.0	18.5	18.0	16.5	17.0	17.5	18.5	19.5	20.0	19.0	18.5	18.5	21.0
		最小	15.5	13.0	14.5	11.0	9.0	10.0	12.0	13.0	15.0	14.0	11.0	13.0	9.0
		平均	18.3	16.3	16.0	13.1	13.4	14.8	15.4	17.5	18.5	16.7	15.8	15.5	15.9
KMnO ₄ 消費量 (mg/l)	原水	最大	5.9	9.4	8.2	15.4	13.9	6.3	8.7	4.3	4.9	4.5	7.7	6.2	15.4
		最小	2.5	3.1	3.1	3.4	3.4	3.1	3.2	2.0	2.1	2.5	2.3	2.5	2.0
		平均	3.6	4.7	4.3	6.2	6.2	3.9	5.1	3.2	3.1	3.3	3.4	3.6	4.2
	浄水	最大	1.3	1.7	1.7	1.7	1.5	1.5	1.7	1.5	1.5	1.4	1.4	1.6	1.7
		最小	0.8	0.8	0.9	0.9	0.9	1.1	0.9	0.7	0.6	0.8	0.6	0.6	0.6
		平均	1.1	1.2	1.4	1.3	1.3	1.2	1.4	1.2	1.1	1.2	1.1	1.2	1.2
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.4	0.5	0.6
		最小	0.4	0.4	0.4	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
		平均	0.4	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4

尾張東部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.3	27.8	27.3	32.0	33.0	32.5	28.0	18.2	13.8	12.7	13.0	17.2	33.0	
	最小	7.8	15.9	17.0	21.6	24.4	21.5	15.0	8.2	6.1	4.4	1.9	5.6	1.9	
	平均	15.3	21.7	23.9	26.1	30.2	27.8	21.2	14.5	9.0	7.5	7.5	10.9	18.0	
原水水温 (°C)	最大	14.5	18.0	21.0	21.5	25.0	23.0	21.5	16.0	11.0	8.5	8.0	10.5	25.0	
	最小	9.5	14.0	17.5	18.5	21.0	20.5	16.0	10.8	8.0	6.5	5.6	7.0	5.6	
	平均	11.8	16.1	19.0	19.7	23.0	21.8	18.9	13.2	9.3	7.5	7.0	8.8	14.7	
濁度 (度)	原水	最大	6.9	41.1	8.6	71.1	86.0	11.5	28.4	4.0	3.5	5.0	13.0	9.9	86.0
		最小	1.7	2.3	1.4	2.4	1.3	1.0	0.7	1.7	1.3	1.5	1.6	2.4	0.7
		平均	3.5	8.4	2.8	11.9	15.2	3.6	5.0	2.5	2.2	2.3	3.4	5.2	5.5
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	6.1	40.0	14.5	37.8	41.0	7.9	21.8	5.5	5.5	5.9	8.6	8.2	41.0
		最小	2.3	2.8	2.7	3.5	3.4	1.0	3.1	3.1	2.5	1.0	1.2	3.1	1.0
		平均	3.6	7.2	4.7	8.2	9.0	4.1	6.4	4.0	3.6	3.4	3.7	5.0	5.2
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	7.7	7.8	7.5	7.4	7.7	7.6	7.7	7.8	7.7	7.5	7.6	7.8
		最小	7.2	7.3	7.2	7.1	7.0	7.3	7.3	7.2	7.3	7.2	7.3	7.2	7.0
		平均	7.4	7.5	7.5	7.3	7.3	7.5	7.4	7.5	7.5	7.4	7.4	7.4	7.4
	浄水	最大	7.2	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.2	7.3	7.3	7.3
		最小	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.0	7.1	7.1	7.1	7.1	7.0
		平均	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2
総アルカリ度 (mg/l)	原水	最大	21.5	19.5	18.5	17.5	18.0	20.0	20.5	22.0	22.0	21.0	19.5	18.5	22.0
		最小	16.0	12.5	14.5	10.5	8.0	11.0	11.0	15.0	16.0	14.0	10.0	12.5	8.0
		平均	18.8	16.8	17.0	13.6	14.0	16.6	16.7	19.0	19.7	17.8	16.6	16.5	16.9
	浄水	最大	19.5	17.0	17.0	16.0	16.0	17.0	18.0	19.0	19.0	18.0	17.5	16.5	19.5
		最小	14.0	12.0	12.5	10.0	10.0	11.5	10.5	13.0	13.5	13.0	11.0	12.5	10.0
		平均	16.6	14.7	14.8	12.7	13.2	14.6	14.9	16.6	17.2	16.2	15.1	14.8	15.1
KMnO ₄ 消費量 (mg/l)	原水	最大	5.4	8.9	6.0	13.1	14.7	6.6	8.8	4.8	4.7	4.2	7.3	6.3	14.7
		最小	2.5	2.5	2.5	2.3	2.5	2.3	2.2	1.9	2.2	2.0	2.2	1.9	
		平均	3.4	4.6	3.8	5.4	5.5	3.5	4.7	3.2	3.1	3.1	3.2	3.1	3.9
	浄水	最大	1.4	1.9	1.4	2.0	1.7	1.2	2.5	1.4	1.4	1.4	1.4	1.1	2.5
		最小	0.6	0.6	0.5	0.5	0.6	0.3	0.5	0.6	0.5	0.6	0.3	0.7	0.3
		平均	1.1	1.0	1.1	1.0	1.1	0.9	1.1	0.9	0.9	1.0	0.9	0.1	0.9
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.7	0.7	0.7	0.7	0.6	0.6	0.6	0.5	0.5	0.5	0.7
		最小	0.5	0.5	0.5	0.6	0.6	0.7	0.6	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.5	0.6	0.6	0.7	0.7	0.6	0.6	0.6	0.5	0.5	0.5	0.6

犬山浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.8	28.8	29.3	32.5	33.8	32.3	28.5	18.1	13.8	11.5	12.6	17.1	33.8	
	最小	5.2	16.0	17.4	21.8	24.2	19.4	14.1	8.8	4.8	4.3	2.4	6.6	2.4	
	平均	14.8	22.1	24.1	26.1	30.1	27.4	21.1	14.5	9.4	7.8	7.4	11.0	18.0	
原水水温 (°C)	最大	14.3	17.7	20.8	21.3	25.7	23.6	22.1	14.9	10.9	7.6	7.4	10.2	25.7	
	最小	8.8	12.9	17.3	17.7	20.2	20.0	14.9	10.3	7.7	6.3	5.5	6.9	5.5	
	平均	11.5	15.9	18.8	19.3	22.7	21.7	18.6	12.5	8.7	6.9	6.7	8.6	14.3	
濁度 (度)	原水	最大	6.8	25.8	16.8	46.1	46.8	9.5	23.1	2.8	2.4	3.9	10.0	8.0	46.8
		最小	1.6	1.9	1.7	3.0	1.7	1.5	1.4	1.3	1.2	1.0	1.2	2.0	1.0
		平均	2.5	5.3	3.6	11.0	11.3	3.1	6.3	1.7	1.7	1.8	3.0	3.4	4.6
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	5.9	27.5	10.0	33.5	19.4	6.2	19.9	4.4	3.7	4.2	5.5	7.8	33.5
		最小	2.6	2.7	2.9	4.2	4.0	3.1	3.3	2.5	2.3	2.0	1.6	2.6	1.6
		平均	3.4	5.0	4.9	7.6	7.1	3.9	7.4	3.1	2.8	2.7	3.1	4.0	4.6
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.4	7.4	7.3	7.3	7.2	7.2	7.3	7.4	7.4	7.4	7.4	7.3	7.4
		最小	7.1	7.0	7.1	6.9	6.9	7.1	7.0	7.3	7.3	7.2	7.1	7.0	6.9
		平均	7.3	7.2	7.2	7.1	7.1	7.2	7.2	7.3	7.3	7.3	7.3	7.2	7.2
	浄水	最大	7.4	7.4	7.3	7.2	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.2	7.2	7.1	7.1	7.1	7.2	7.2	7.3	7.3	7.3	7.4	7.2	7.1
		平均	7.3	7.3	7.3	7.2	7.2	7.3	7.3	7.4	7.4	7.4	7.4	7.3	7.3
総7ℓ初度 (mg/l)	原水	最大	17.5	17.0	16.0	14.0	16.5	17.0	17.5	20.0	21.0	19.0	20.0	17.5	21.0
		最小	14.0	10.0	11.0	7.5	7.5	9.0	10.5	14.5	18.0	14.5	10.5	10.0	7.5
		平均	15.7	14.4	14.5	10.9	11.6	14.0	14.5	18.4	19.5	17.0	16.1	15.6	15.2
	浄水	最大	17.5	17.0	16.0	14.0	16.0	16.0	17.0	20.0	20.0	19.0	19.5	17.5	20.0
		最小	13.0	10.0	12.5	8.0	8.0	8.5	12.0	14.5	17.0	14.0	11.0	10.0	8.0
		平均	15.3	14.1	14.5	10.7	11.6	13.7	14.4	18.0	19.1	16.7	16.1	15.5	15.0
KMnO₄ 消費量 (mg/l)	原水	最大	5.6	12.8	7.3	23.6	14.5	5.4	11.1	3.8	5.1	4.1	6.3	6.1	23.6
		最小	2.8	2.5	3.2	3.5	3.5	2.8	3.1	2.5	2.8	2.5	2.2	2.5	2.2
		平均	3.5	4.2	4.3	6.0	5.4	3.6	5.2	3.2	3.6	3.3	3.3	3.4	4.1
	浄水	最大	1.6	1.6	2.2	1.9	1.6	1.3	1.6	1.6	1.9	1.6	1.3	1.6	2.2
		最小	0.3	0.6	0.6	0.9	0.9	0.9	0.6	0.6	0.3	0.9	0.6	0.9	0.3
		平均	1.0	1.0	1.3	1.3	1.2	1.1	1.3	1.1	1.3	1.1	1.0	1.1	1.2
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.6	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.7	
	最小	0.4	0.5	0.5	0.5	0.6	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	
	平均	0.5	0.5	0.6	0.6	0.6	0.5	0.6	0.5	0.5	0.5	0.5	0.5	0.5	

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.5	29.1	27.2	33.9	34.9	33.9	29.1	21.9	14.3	14.4	13.2	16.2	34.9	
	最小	4.8	14.3	17.3	18.3	24.5	20.1	15.1	11.1	6.1	5.0	2.5	6.3	2.5	
	平均	15.0	21.3	23.3	26.2	29.7	28.3	21.8	16.3	10.2	8.4	8.2	11.1	18.3	
原水水温 (°C)	最大	16.7	20.2	24.1	22.8	28.9	25.7	25.2	16.5	11.6	9.1	8.8	11.8	28.9	
	最小	10.4	14.4	19.2	18.7	21.1	20.9	16.8	10.8	8.8	6.9	6.5	8.2	6.5	
	平均	13.6	18.1	21.3	20.7	24.6	23.7	20.2	13.9	9.9	8.0	7.7	10.0	16.0	
濁度 (度)	原水	最大	3.1	10.9	6.6	48.2	68.1	11.3	19.9	3.4	2.7	5.7	8.0	8.3	68.1
		最小	1.8	1.7	3.0	4.3	2.0	1.6	1.5	0.7	1.1	1.0	1.3	1.3	0.7
		平均	2.3	4.0	4.5	13.5	12.7	3.6	5.5	1.6	1.5	2.0	3.0	3.4	4.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	4.4	7.6	6.4	30.1	24.4	6.5	11.6	4.7	4.9	5.2	6.5	7.1	30.1
		最小	2.5	2.8	3.8	2.3	3.9	3.2	3.1	1.3	2.7	2.2	2.0	2.6	1.3
		平均	3.4	4.4	4.9	7.1	7.7	4.3	5.9	3.3	3.2	3.2	3.4	4.2	4.6
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.3	7.4	7.3	7.3	7.3	7.3	7.6	7.6	7.3	7.5	7.6	7.6
		最小	7.0	6.9	7.0	6.9	6.7	6.9	6.8	7.1	7.1	7.1	7.0	7.0	6.7
		平均	7.3	7.1	7.2	7.1	7.0	7.1	7.0	7.4	7.4	7.2	7.2	7.2	7.2
	浄水	最大	7.4	7.4	7.4	7.4	7.5	7.4	7.5	7.4	7.4	7.4	7.4	7.4	7.5
		最小	7.3	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.1	7.3	7.1
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総7ℓ初度 (mg/l)	原水	最大	24.5	22.0	21.5	19.0	20.0	21.5	21.5	22.5	22.5	22.0	21.5	21.5	24.5
		最小	19.0	14.5	16.5	11.5	11.0	12.0	13.0	16.0	19.5	17.5	12.5	12.5	11.0
		平均	21.0	19.4	19.4	15.0	15.8	18.3	17.8	20.8	21.4	19.7	18.0	17.5	18.7
	浄水	最大	22.5	21.0	22.0	19.0	19.5	20.5	21.0	21.5	21.0	20.5	20.0	18.5	22.5
		最小	18.0	15.5	16.5	13.5	12.5	13.0	14.0	16.5	17.5	16.5	12.5	13.0	12.5
		平均	20.2	18.9	19.4	16.0	16.2	18.1	18.0	19.5	19.9	18.5	17.4	16.7	18.2
KMnO₄ 消費量 (mg/l)	原水	最大	5.0	6.2	6.4	16.5	10.0	6.2	6.6	4.1	4.0	4.7	5.7	5.0	16.5
		最小	2.8	2.9	3.1	3.0	2.2	1.4	1.7	1.8	1.7	1.8	2.1	1.9	1.4
		平均	3.8	4.4	4.2	5.5	4.6	2.9	3.3	3.3	2.9	2.7	3.6	3.0	3.7
	浄水	最大	1.9	2.5	2.2	2.0	1.6	1.5	2.0	1.9	1.9	1.6	1.9	1.3	2.5
		最小	0.6	0.9	0.6	0.5	0.3	0.5	0.5	0.3	0.3	0.1	0.6	0.3	0.1
		平均	1.3	1.5	1.2	1.1	1.0	0.9	0.8	1.4	0.9	0.6	1.2	0.8	1.1
残留塩素 (mg/l)	浄水	最大	0.6	0.7	0.8	0.8	0.8	0.7	0.8	0.6	0.5	0.5	0.5	0.8	
	最小	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	
	平均	0.5	0.6	0.7	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.6	

豊田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.3	29.0	28.1	31.1	34.6	32.4	27.4	18.7	13.5	11.5	12.6	16.5	34.6	
	最小	7.0	15.2	17.4	21.2	24.5	21.9	15.1	7.9	3.8	2.2	2.7	4.9	2.2	
	平均	15.1	21.9	23.9	26.3	30.2	27.4	20.9	14.3	8.6	6.9	7.2	10.9	17.8	
原水水温 (°C)	最大	12.6	18.0	20.5	21.5	24.0	23.0	21.6	15.0	11.0	7.4	7.8	10.0	24.0	
	最小	7.0	13.5	16.5	15.5	21.0	20.4	15.5	10.5	7.5	6.0	5.0	6.5	5.0	
	平均	10.6	15.7	18.6	18.9	22.5	21.7	18.9	12.7	8.9	6.7	5.9	7.9	14.1	
濁度 (度)	原水	最大	3.7	10.4	34.5	14.7	20.1	8.9	22.3	3.7	5.7	6.5	5.0	28.5	34.5
		最小	1.2	1.5	1.9	2.5	1.8	0.4	1.2	1.2	1.4	1.3	1.2	1.2	0.4
		平均	1.8	2.9	3.9	6.9	5.0	2.0	3.8	2.0	2.1	1.9	1.7	3.3	3.1
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	3.8	11.9	28.4	11.9	13.7	9.6	26.3	5.5	8.1	6.7	5.3	21.8	28.4
		最小	1.9	2.7	4.4	4.1	4.0	3.2	1.0	4.0	2.5	2.8	2.5	2.6	1.0
		平均	2.8	4.7	6.3	7.5	6.7	4.7	6.9	4.5	4.3	3.4	3.2	4.3	4.9
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	0.6	<0.5	<0.5	<0.5	<0.5	<0.5	0.6
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.4	7.4	7.3	7.3	7.3	7.4	7.3	7.3	7.5	7.4	7.5	7.5
		最小	7.3	7.1	7.1	7.1	7.1	7.1	7.2	7.1	7.1	7.2	7.3	7.2	7.1
		平均	7.4	7.3	7.2	7.2	7.2	7.2	7.3	7.2	7.2	7.3	7.3	7.3	7.3
	浄水	最大	7.5	7.4	7.5	7.5	7.5	7.4	7.5	7.4	7.4	7.4	7.5	7.4	7.5
		最小	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2	7.3	7.3	7.3	7.2	7.2
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.3	7.4	7.4	7.3	7.4
総アルカリ度 (mg/l)	原水	最大	19.0	20.0	20.0	17.0	18.0	21.0	21.5	18.5	19.0	18.5	18.0	18.5	21.5
		最小	17.5	17.0	17.0	13.5	14.0	15.5	15.5	16.5	16.5	15.5	15.0	14.5	13.5
		平均	18.2	18.3	18.3	15.1	15.5	18.5	18.3	17.7	17.5	17.1	16.8	16.9	17.4
	浄水	最大	17.5	18.5	19.0	17.0	17.0	19.5	20.0	18.0	18.5	17.5	17.0	17.5	20.0
		最小	16.0	16.0	16.0	13.5	13.0	14.0	14.5	15.5	16.0	15.5	14.5	14.0	13.0
		平均	16.8	17.1	17.5	14.7	15.0	17.5	17.2	17.1	17.0	16.5	15.9	16.0	16.5
KMnO ₄ 消費量 (mg/l)	原水	最大	5.1	10.1	19.5	10.1	15.7	6.4	20.4	4.9	5.8	5.1	4.7	16.9	20.4
		最小	2.5	2.0	4.0	4.5	3.7	2.5	2.8	2.8	2.1	1.9	2.0	1.9	1.9
		平均	3.6	4.7	5.9	6.2	6.2	4.2	5.5	3.5	3.1	2.9	2.9	4.1	4.4
	浄水	最大	1.9	1.9	1.8	1.9	1.7	1.9	1.5	1.1	1.1	1.1	1.4	1.4	1.9
		最小	0.3	0.5	0.6	0.6	0.8	0.6	0.4	0.3	0.3	0.3	0.3	0.4	0.3
		平均	1.0	1.0	1.2	1.2	1.2	1.1	0.9	0.7	0.7	0.7	0.7	0.9	0.9
残留塩素 (mg/l)	最大	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.6	
	最小	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	
	平均	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	

幸田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.6	28.1	29.4	32.5	34.6	33.4	30.0	20.5	14.6	14.0	13.0	17.5	34.6	
	最小	9.5	16.8	17.8	23.1	25.6	23.7	16.0	10.2	6.1	4.1	3.9	7.4	3.9	
	平均	16.3	22.3	25.0	27.1	31.0	28.7	22.4	16.0	10.5	8.7	8.6	12.0	19.1	
原水水温 (°C)	最大	17.5	21.0	24.5	25.0	28.5	26.5	24.0	17.5	11.5	10.0	10.0	12.5	28.5	
	最小	10.5	15.5	20.0	21.0	23.0	22.5	17.5	11.5	8.0	6.5	5.5	8.5	5.5	
	平均	14.0	18.8	21.7	22.8	26.3	24.4	20.5	14.1	9.8	8.1	7.7	10.6	16.6	
濁度 (度)	原水	最大	15.0	56.0	25.0	50.0	39.0	8.3	21.0	15.0	21.0	22.0	14.6	31.0	56.0
		最小	1.0	2.3	2.2	2.4	1.1	1.5	1.1	1.1	0.6	0.5	0.5	0.7	0.5
		平均	3.4	8.5	6.4	9.6	6.9	3.3	4.3	2.5	1.9	2.0	1.7	4.1	4.6
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	16.0	59.0	32.0	57.0	37.0	14.0	28.0	11.0	24.0	24.0	16.8	32.0	59.0
		最小	3.2	6.3	6.3	6.5	5.6	5.4	5.0	4.1	3.2	2.9	2.5	3.2	2.5
		平均	6.0	12.4	10.7	13.9	11.1	7.6	9.0	5.6	5.1	4.6	4.5	7.2	8.1
	浄水	最大	<0.5	0.5	0.6	0.7	0.5	0.6	0.5	<0.5	<0.5	<0.5	<0.5	<0.5	0.7
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.6	7.5	7.5	7.5	7.5	7.6	7.6
		最小	7.3	7.1	7.3	7.2	7.2	7.4	7.3	7.4	7.4	7.4	7.4	7.4	7.1
		平均	7.4	7.4	7.5	7.4	7.4	7.5	7.4	7.5	7.5	7.5	7.5	7.5	7.5
	浄水	最大	7.5	7.5	7.5	7.5	7.4	7.4	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.3	7.4	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.3	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アルカリ度 (mg/l)	原水	最大	22.5	22.5	23.0	21.0	20.5	21.5	20.5	20.0	20.5	20.5	20.5	20.5	23.0
		最小	19.0	10.0	16.5	12.5	11.0	18.0	12.0	16.5	17.0	18.5	18.0	13.0	10.0
		平均	21.2	20.3	21.1	18.2	17.9	19.6	17.4	18.7	19.6	19.8	19.6	18.3	19.3
	浄水	最大	21.0	21.0	21.0	19.5	21.5	20.0	19.5	19.0	20.0	20.0	19.5	19.5	21.5
		最小	18.0	13.5	16.0	13.0	10.5	15.0	13.0	15.5	16.5	17.0	17.0	13.5	10.5
		平均	19.7	19.1	19.6	17.2	16.6	18.3	16.2	17.5	18.5	18.9	18.7	17.7	18.2
KMnO ₄ 消費量 (mg/l)	原水	最大	11.1	26.2	18.0	26.4	18.8	11.1	16.2	7.0	10.8	7.5	7.5	13.1	26.4
		最小	3.0	4.6	4.2	5.9	4.5	3.9	4.2	3.5	2.8	2.6	2.7	3.1	2.6
		平均	5.1	8.2	8.0	10.3	8.2	5.8	7.0	4.7	4.0	3.6	3.8	5.0	6.1
	浄水	最大	1.9	2.1	2.5	2.2	1.9	1.9	2.0	1.6	1.7	1.9	1.6	1.7	2.5
		最小	0.8	0.8	1.1	0.9	0.6	0.6	0.9	0.9	0.8	0.8	0.8	0.8	0.6
		平均	1.3	1.5	1.5	1.6	1.2	1.2	1.5	1.2	1.1	1.1	1.1	1.2	1.3
残留塩素 (mg/l)	最大	0.6	0.7	0.8	0.8	0.8	0.8	0.7	0.7	0.6	0.5	0.5	0.5	0.8	
	最小	0.5	0.5	0.6	0.6	0.7	0.7	0.6	0.5	0.5	0.4	0.4	0.5	0.4	
	平均	0.5	0.6	0.7	0.7	0.8	0.7	0.7	0.6	0.5	0.5	0.5	0.5	0.6	

豊橋浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.5	29.0	28.0	33.0	33.0	33.0	29.5	20.0	18.0	14.0	14.0	18.0	33.0	
	最小	9.0	17.0	20.0	21.0	25.0	22.0	16.0	9.5	7.0	5.5	4.0	7.5	4.0	
	平均	16.5	22.4	24.6	26.6	30.2	28.3	22.2	15.8	11.4	8.9	9.0	12.1	19.0	
原水水温 (°C)	最大	19.5	22.0	24.5	24.5	28.0	27.5	24.0	16.5	11.5	10.0	10.0	13.5	28.0	
	最小	10.5	15.5	18.5	20.0	23.5	23.0	16.5	11.0	7.5	6.0	5.0	9.0	5.0	
	平均	15.0	19.1	21.6	21.9	26.1	25.0	20.3	13.8	9.8	7.9	7.8	11.0	16.6	
濁度 (度)	原水	最大	4.6	18.0	5.5	130.0	6.7	3.9	75.0	3.0	13.0	5.2	2.7	40.0	130.0
		最小	1.2	1.5	1.2	1.5	1.4	1.5	1.5	1.0	0.7	0.7	0.5	1.1	0.5
		平均	2.0	3.3	2.3	9.1	2.4	2.1	5.5	1.5	1.7	1.4	1.2	3.8	3.0
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	12.0	13.0	10.0	67.0	9.8	10.0	55.0	6.7	14.0	8.2	6.0	33.0	67.0
		最小	2.8	3.8	3.2	4.0	3.8	4.0	3.4	2.2	2.2	2.2	1.6	2.7	1.6
		平均	4.6	6.0	5.5	9.3	5.3	5.1	7.7	3.5	3.7	3.4	3.3	5.7	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	0.5	0.6	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	0.6
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	8.4	7.4	7.4	7.6	7.4	7.4	7.5	7.6	7.6	7.6	7.7	7.6	8.4
		最小	7.2	7.1	7.2	7.1	7.0	7.3	7.3	7.4	7.4	7.3	7.4	7.2	7.0
		平均	7.8	7.3	7.3	7.3	7.3	7.3	7.4	7.5	7.5	7.5	7.5	7.4	7.4
	浄水	最大	7.4	7.4	7.5	7.4	7.4	7.4	7.5	7.5	7.4	7.4	7.4	7.4	7.5
		最小	7.4	7.4	7.4	7.4	7.4	7.3	7.4	7.4	7.3	7.4	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アルカ度 (mg/l)	原水	最大	29.0	26.0	27.5	28.0	25.0	26.5	33.0	26.5	26.5	26.0	27.0	26.0	33.0
		最小	21.0	13.0	17.0	14.5	11.5	21.0	16.5	22.0	17.5	19.0	21.0	14.0	11.5
		平均	26.2	22.6	23.3	19.2	21.9	24.4	22.2	24.1	24.6	24.3	24.2	22.0	23.3
	浄水	最大	24.5	23.5	25.0	21.0	22.0	23.0	24.0	25.0	24.0	23.5	24.5	24.5	25.0
		最小	20.0	15.0	15.5	14.0	11.0	18.5	14.5	19.0	16.0	17.5	19.0	13.0	11.0
		平均	22.9	20.9	20.9	17.7	19.8	21.4	19.3	21.9	22.2	22.2	22.2	19.8	20.9
KMnO ₄ 消費量 (mg/l)	原水	最大	10.0	9.9	9.5	19.0	8.0	9.5	22.0	5.6	9.0	6.9	6.8	11.0	22.0
		最小	2.8	3.3	2.7	3.4	3.3	3.0	2.5	2.2	1.8	2.5	2.2	2.7	1.8
		平均	5.0	4.9	4.6	6.1	4.8	4.5	5.3	3.3	3.2	3.3	3.4	4.2	4.4
	浄水	最大	2.2	1.5	1.8	1.5	2.2	1.5	2.7	1.5	1.5	1.2	0.9	1.5	2.7
		最小	0.6	0.6	0.6	0.6	0.9	0.9	0.6	0.6	0.3	0.6	0.6	0.3	0.3
		平均	1.2	1.1	1.1	1.1	1.3	1.1	1.1	0.9	0.8	0.9	0.8	0.8	1.0
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.6	
		最小	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	
		平均	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.5

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.5	27.1	28.2	31.5	32.3	32.3	28.2	19.9	18.3	13.7	14.3	17.2	32.3	
	最小	8.2	15.6	19.1	21.0	25.5	22.9	15.7	7.8	7.1	5.9	3.3	7.5	3.3	
	平均	15.3	21.2	24.0	25.9	29.6	27.5	21.5	15.1	10.6	8.5	8.2	11.5	18.3	
原水水温 (°C)	最大	17.0	19.0	21.0	23.0	25.0	25.7	24.3	19.5	14.4	10.5	9.5	12.0	25.7	
	最小	10.6	15.5	18.7	20.0	23.1	24.0	19.5	14.5	10.6	9.0	8.0	9.0	8.0	
	平均	13.8	17.6	19.7	21.0	23.9	24.8	21.7	16.5	12.1	9.6	8.7	10.4	16.7	
濁度 (度)	原水	最大	8.7	11.3	9.9	32.1	2.7	1.6	7.3	2.5	2.0	1.9	1.6	2.9	32.1
		最小	1.1	1.7	1.1	1.2	0.7	0.7	0.6	0.8	0.5	0.6	0.8	0.8	0.5
		平均	2.1	2.9	2.6	3.9	1.6	1.1	1.8	1.6	1.0	1.0	1.1	1.4	1.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	6.8	12.9	9.8	76.4	8.2	7.1	11.4	5.4	8.9	5.1	6.0	8.3	76.4
		最小	3.2	4.6	4.0	5.0	3.9	4.3	3.7	3.6	3.1	3.3	3.1	2.8	2.8
		平均	3.8	5.9	5.7	12.7	5.5	5.3	5.2	4.4	3.9	3.7	3.7	3.9	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	7.4	7.4	7.2	7.2	7.5	7.6	8.3	7.6	7.6	7.7	7.7	8.3
		最小	7.3	7.1	7.1	7.0	6.9	7.1	7.2	7.3	7.4	7.4	7.4	7.3	6.9
		平均	7.5	7.2	7.3	7.0	7.0	7.2	7.4	7.8	7.4	7.5	7.5	7.5	7.4
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.4	7.4	7.4	7.4	7.5	7.5	7.5
		最小	7.3	7.3	7.4	7.3	7.3	7.3	7.4	7.3	7.4	7.3	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アルカ度 (mg/l)	原水	最大	19.0	21.0	27.0	19.0	18.5	19.5	21.0	21.0	21.5	21.5	21.5	21.0	27.0
		最小	16.0	14.5	16.0	15.5	17.0	16.0	14.0	18.0	14.0	18.0	17.5	15.0	14.0
		平均	17.9	17.3	21.1	17.7	17.7	17.8	18.2	19.9	19.8	19.8	19.8	19.0	18.8
	浄水	最大	17.0	22.0	23.5	19.0	19.5	18.5	18.5	19.0	20.0	19.0	20.0	18.5	23.5
		最小	15.0	13.5	15.0	15.0	16.5	16.0	14.5	16.5	14.0	16.0	16.0	14.5	13.5
		平均	16.2	16.6	19.1	17.5	17.8	17.2	16.7	17.7	18.3	18.1	17.8	17.1	17.5
KMnO ₄ 消費量 (mg/l)	原水	最大	11.9	10.1	9.8	11.0	8.0	7.7	10.7	6.4	11.5	6.2	7.3	8.4	11.9
		最小	4.0	4.6	4.2	4.6	4.3	4.0	4.0	3.7	3.1	3.7	4.0	3.7	3.1
		平均	5.5	6.5	5.7	6.6	5.9	5.5	5.4	4.7	4.7	4.5	4.8	4.8	5.4
	浄水	最大	1.6	1.5	1.8	1.9	1.8	1.4	1.4	1.5	1.6	1.6	1.8	1.6	1.9
		最小	0.6	0.6	0.6	0.9	0.9	0.9	0.5	0.6	0.6	0.9	0.6	0.6	0.5
		平均	1.2	1.2	1.1	1.4	1.4	1.0	1.0	1.0	1.2	1.3	1.2	1.2	1.2
残留塩素 (mg/l)	浄水	最大	0.6	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.7
		最小	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5
		平均	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.6

豊川浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.7	29.6	29.8	34.4	35.1	34.6	30.1	20.0	15.7	14.7	14.7	18.3	35.1	
	最小	9.0	17.5	19.5	23.1	25.5	23.4	16.3	8.3	7.1	5.9	4.1	8.3	4.1	
	平均	17.1	23.7	25.4	27.2	31.3	29.0	22.1	15.5	10.7	8.9	9.1	12.9	19.4	
原水水温 (°C)	最大	18.0	20.5	22.3	24.7	27.1	26.5	24.7	19.0	13.5	10.7	10.5	13.5	27.1	
	最小	12.5	16.9	19.5	21.5	25.0	23.8	19.1	13.2	10.5	9.0	8.0	10.5	8.0	
	平均	15.2	19.1	20.7	22.6	26.0	25.0	21.9	15.8	11.8	9.8	9.5	12.1	17.5	
濁度 (度)	原水	最大	2.3	5.2	4.3	4.1	2.9	2.7	5.3	4.7	5.4	2.4	2.1	4.0	5.4
		最小	0.6	0.8	1.2	1.3	0.6	0.8	0.9	0.8	0.9	0.8	0.9	1.0	0.6
		平均	1.4	1.8	2.4	2.2	1.2	1.4	2.3	1.6	1.8	1.5	1.6	2.2	1.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	6.7	10.2	8.6	9.7	7.9	8.3	10.7	5.8	7.8	6.2	5.9	7.9	10.7
		最小	3.4	4.9	4.5	5.3	4.5	4.9	5.6	3.8	2.7	3.2	3.5	3.5	2.7
		平均	4.3	6.7	5.9	7.5	6.4	6.8	7.4	4.8	4.6	4.5	4.3	5.0	5.7
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.4	7.7	7.6	7.5	7.4	7.3	7.4	7.5	7.6	7.6	7.5	7.7
		最小	7.2	7.1	7.2	7.1	7.0	7.1	6.9	7.1	7.3	7.2	7.3	7.2	6.9
		平均	7.4	7.2	7.4	7.2	7.3	7.2	7.1	7.3	7.4	7.4	7.4	7.4	7.3
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.3	6.9	7.3	7.3	7.3	7.3	7.2	7.3	7.3	7.3	7.3	7.3	6.9
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アールカ度 (mg/l)	原水	最大	19.0	22.5	31.5	27.0	17.0	18.0	17.5	23.0	22.5	22.0	23.0	20.0	31.5
		最小	15.0	14.0	16.5	15.5	15.0	14.0	15.0	16.0	18.0	17.0	17.0	15.0	14.0
		平均	17.0	16.4	23.8	17.5	16.0	15.8	16.0	20.5	20.9	20.3	19.5	17.7	18.5
	浄水	最大	19.0	20.0	29.5	27.0	17.0	17.5	18.5	23.0	22.5	22.0	22.0	20.0	29.5
		最小	15.0	13.0	17.0	15.5	15.0	15.0	15.0	17.0	17.5	17.5	16.5	15.0	13.0
		平均	16.7	16.4	22.3	17.5	16.1	16.3	17.0	20.3	20.6	19.7	18.9	17.5	18.3
KMnO ₄ 消費量 (mg/l)	原水	最大	7.0	6.8	5.9	7.3	6.8	7.0	7.3	4.9	6.7	5.6	6.5	6.4	7.3
		最小	3.2	3.5	2.9	4.9	3.7	3.7	4.3	2.3	2.3	2.9	2.3	2.9	2.3
		平均	4.5	5.1	4.3	6.0	5.4	5.3	5.4	3.6	4.1	4.1	4.0	4.0	4.7
	浄水	最大	1.7	2.3	1.4	1.7	1.4	1.4	1.5	1.4	1.8	1.5	1.4	1.1	2.3
		最小	0.5	0.5	0.2	0.5	0.5	0.5	0.4	0.2	0.5	0.8	0.2	0.5	0.2
		平均	1.0	1.0	0.9	1.1	0.9	0.9	0.9	0.8	1.0	1.1	1.0	0.8	0.9
残留塩素 (mg/l)	浄水	最大	0.6	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.6	0.5	0.6	0.6	0.7
		最小	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.6

(2)工業用水毎日検査

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	28.0	28.0	32.5	33.5	32.5	27.0	19.5	13.5	13.5	12.5	16.5	33.5	
	最小	7.5	15.5	17.0	22.0	25.5	21.5	15.5	8.5	6.0	5.5	2.5	6.5	2.5	
	平均	15.1	21.7	24.1	26.6	30.3	28.0	21.6	14.8	9.5	8.1	7.6	10.9	18.2	
原水水温 (°C)	最大	15.0	19.0	22.0	23.0	26.0	24.0	23.0	17.5	11.5	8.5	8.0	11.0	26.0	
	最小	9.5	15.0	19.0	20.5	23.0	22.5	17.5	11.5	8.5	7.0	6.5	8.0	6.5	
	平均	12.6	17.4	20.2	21.2	24.8	23.2	20.4	14.4	9.6	7.8	7.3	9.3	15.7	
濁度 (度)	原水	最大	4.5	12.7	7.4	14.9	22.4	12.4	11.7	5.3	2.9	2.4	4.2	6.5	22.4
		最小	2.8	2.5	2.4	4.1	3.3	4.3	2.5	2.6	1.4	1.5	1.4	3.2	1.4
		平均	3.5	5.3	5.4	7.7	9.7	6.6	5.7	3.5	2.1	1.8	2.4	4.6	4.9
	配水	最大	2.9	4.8	3.5	7.6	6.0	5.2	5.9	4.5	2.9	1.9	2.7	3.7	7.6
		最小	2.0	0.8	2.0	0.8	0.7	0.8	1.2	2.0	1.3	1.3	1.1	1.7	0.7
		平均	2.3	1.9	2.6	3.1	2.9	3.1	4.0	2.9	1.7	1.6	1.8	2.8	2.6
pH値	原水	最大	7.6	7.6	7.6	7.4	7.4	7.5	7.5	7.7	7.6	7.5	7.5	7.6	7.7
		最小	7.4	7.2	7.3	7.1	7.2	7.2	7.2	7.4	7.4	7.4	7.3	7.3	7.1
		平均	7.5	7.4	7.4	7.2	7.3	7.4	7.4	7.5	7.5	7.4	7.4	7.4	7.4
	配水	最大	7.4	7.3	7.3	7.3	7.3	7.4	7.4	7.3	7.3	7.4	7.4	7.4	7.4
		最小	7.2	6.9	7.2	6.9	6.9	7.0	7.0	7.2	7.2	7.2	7.3	7.2	6.9
		平均	7.3	7.3	7.2	7.1	7.1	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
総アルカリ度 (mg/l)	原水	最大	19.0	17.5	16.5	15.5	16.5	17.5	18.0	19.0	19.0	18.0	16.5	19.0	
		最小	17.0	15.0	15.0	13.0	12.0	11.5	14.5	13.0	17.5	16.5	15.0	15.0	11.5
		平均	17.9	16.4	15.9	13.8	13.5	14.5	16.6	17.1	18.6	17.8	16.9	15.8	16.2
	配水	最大	18.0	16.5	15.5	15.5	16.0	16.0	17.5	18.0	18.0	17.5	16.5	15.5	18.0
		最小	16.0	12.0	14.0	10.0	9.5	9.5	12.5	13.5	16.0	15.5	14.0	14.0	9.5
		平均	16.9	15.0	15.0	12.7	12.5	13.8	16.0	16.0	16.9	16.4	15.8	14.8	15.2

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	32.0	29.0	33.0	35.0	34.0	28.0	19.0	13.0	12.0	11.0	18.0	35.0	
	最小	7.0	16.0	20.0	21.0	24.0	21.0	15.0	8.0	5.0	4.0	2.0	7.0	2.0	
	平均	15.6	22.8	25.4	26.5	31.1	28.6	21.5	14.6	9.1	7.7	7.4	11.2	18.4	
原水水温 (°C)	最大	15.0	20.0	22.5	24.0	27.0	25.0	24.0	20.0	12.0	10.0	9.0	11.5	27.0	
	最小	10.5	15.0	19.0	21.0	24.0	23.0	18.5	12.0	9.0	7.5	7.0	8.0	7.0	
	平均	12.8	17.4	20.5	22.0	25.4	23.8	21.4	15.0	10.1	8.1	7.6	9.9	16.2	
濁度 (度)	原水	最大	8.4	39.5	7.4	17.7	19.7	14.1	6.7	4.7	3.3	3.6	4.8	7.6	39.5
		最小	3.2	3.1	3.1	2.8	3.1	3.8	2.1	2.8	1.5	1.2	1.2	2.9	1.2
		平均	5.0	6.9	4.7	7.3	9.3	6.1	4.3	3.5	2.5	2.3	2.8	4.8	5.0
	配水	最大	6.6	3.8	3.5	7.8	3.1	2.5	4.7	3.8	2.7	2.1	2.4	2.8	7.8
		最小	1.8	0.6	1.1	1.1	0.8	0.4	0.6	0.3	0.4	0.5	0.4	0.2	0.2
		平均	3.5	1.8	2.5	2.8	2.0	1.4	2.1	1.1	0.9	1.0	1.1	1.3	1.8
pH値	原水	最大	7.4	7.5	7.4	7.3	7.4	7.5	7.5	7.8	7.7	7.7	7.7	7.6	7.8
		最小	7.2	7.1	7.2	7.1	7.1	7.2	7.2	7.3	7.5	7.5	7.5	7.5	7.1
		平均	7.3	7.3	7.3	7.2	7.2	7.3	7.4	7.6	7.6	7.6	7.6	7.5	7.4
	配水	最大	7.5	7.3	7.4	7.3	7.3	7.3	7.3	7.4	7.4	7.5	7.4	7.4	7.5
		最小	7.2	7.1	7.2	7.0	6.8	7.0	7.2	7.2	7.2	7.3	7.3	7.3	6.8
		平均	7.3	7.2	7.3	7.1	7.1	7.1	7.2	7.3	7.3	7.4	7.4	7.3	7.3
アルカリ度 (mg/l)	原水	最大	20.5	19.5	18.5	18.0	17.5	18.0	19.0	20.0	20.0	19.5	28.0	17.5	28.0
		最小	18.0	15.5	16.0	13.0	13.0	12.0	15.0	15.5	17.0	16.5	14.5	14.5	12.0
		平均	19.1	17.9	17.2	15.3	14.7	15.6	17.8	17.5	18.7	17.9	17.5	16.4	17.1
	配水	最大	20.5	18.5	18.0	17.5	17.0	17.5	18.5	18.0	18.5	18.5	17.0	16.5	20.5
		最小	17.5	15.0	15.5	12.5	11.0	11.5	14.0	14.5	15.5	14.5	13.5	13.5	11.0
		平均	18.9	17.0	16.5	14.6	13.8	14.7	17.1	16.4	17.5	16.8	15.9	15.2	16.2

尾張東部浄水場(東郷)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	30.0	29.0	36.0	37.0	37.0	31.0	22.0	15.5	13.0	14.0	20.0	37.0	
	最小	7.0	16.0	17.0	22.0	24.0	22.0	14.0	9.5	4.0	3.5	6.0	5.5	3.5	
	平均	16.7	22.6	24.8	27.0	31.9	30.0	23.3	16.7	10.8	9.2	9.8	12.9	19.6	
原水水温 (°C)	最大	14.7	18.9	21.7	22.6	26.2	24.0	22.8	17.7	12.0	9.1	8.6	11.1	26.2	
	最小	9.8	14.7	18.9	20.5	22.9	22.5	17.7	11.6	8.4	7.1	6.6	7.6	6.6	
	平均	12.0	17.1	20.1	21.0	24.9	23.4	20.7	14.4	9.6	7.7	7.3	9.1	15.6	
濁度 (度)	原水	最大	4.0	8.0	7.0	15	30	12	12	9.0	3.0	2.0	4.0	30.0	
		最小	2.0	2.0	2.0	3.0	6.0	5.0	5.0	2.0	1.0	1.0	1.0	2.0	1.0
		平均	2.0	3.0	3.0	8.0	12	8.0	8.0	4.0	2.0	1.0	1.0	3.0	4.6
	配水	最大	2.0	6.0	4.0	5.0	5.0	6.0	6.0	4.0	2.0	2.0	2.0	4.0	6.0
		最小	1.0	1.0	2.0	1.0	2.0	1.0	1.0	1.0	1.0	1.0	1.0	< 0.1	< 0.1
		平均	1.0	2.0	2.0	2.0	3.0	3.0	3.0	2.0	1.0	1.0	1.0	2.0	1.9
pH値	原水	最大	7.5	7.4	7.6	7.3	7.3	7.5	7.4	7.8	7.5	7.5	7.5	7.6	7.8
		最小	7.3	7.1	7.1	6.9	6.9	6.9	7.1	7.3	7.4	7.3	7.3	7.3	6.9
		平均	7.4	7.3	7.3	7.1	7.2	7.3	7.2	7.5	7.4	7.4	7.4	7.4	7.3
	配水	最大	7.4	7.4	7.4	7.3	7.2	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.3	7.2	7.2	6.9	6.9	7.0	7.0	7.2	7.3	7.3	7.3	7.2	6.9
		平均	7.3	7.3	7.3	7.1	7.1	7.1	7.1	7.3	7.3	7.4	7.3	7.3	7.2
総アルカリ度 (mg/l)	原水	最大	20.0	19.0	18.5	17.0	18.0	19.0	20.0	20.0	20.5	19.5	18.5	20.5	
		最小	18.0	16.5	16.0	14.5	13.0	12.0	16.0	16.5	19.0	17.5	16.5	16.0	12.0
		平均	19.0	18.1	17.7	15.3	15.0	15.7	18.4	18.6	19.8	18.9	18.1	17.1	17.6
	配水	最大	19.5	18.0	18.0	16.5	17.0	18.0	19.0	19.5	20.0	19.5	19.0	19.0	20.0
		最小	17.0	16.0	16.0	13.0	11.5	11.0	15.0	16.0	18.0	17.5	16.0	15.5	11.0
		平均	18.3	17.5	17.1	14.5	13.9	14.7	17.5	17.7	19.1	18.3	17.6	16.3	16.9

蒲郡浄水場(工水)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	26.0	27.0	32.0	32.0	32.0	28.0	19.5	15.5	14.0	14.0	17.5	32.0	
	最小	7.0	18.0	20.5	23.0	26.0	23.0	18.0	11.0	8.5	8.0	4.5	5.7	4.5	
	平均	16.0	21.6	24.0	26.0	29.7	27.6	22.1	16.2	12.0	10.2	10.0	12.8	19.0	
原水水温 (°C)	最大	15.5	18.9	20.7	23.1	25.7	25.3	23.2	18.7	14.5	12.0	11.2	13.5	25.7	
	最小	11.1	15.2	18.3	19.9	23.2	22.2	18.8	13.3	11.5	9.3	8.6	10.5	8.6	
	平均	13.5	16.9	19.3	21.1	24.5	23.7	20.8	15.9	12.5	10.5	9.8	11.6	16.7	
濁度 (度)	原水	最大	1.5	20.0	4.9	4.1	3.6	3.1	1.7	0.8	1.0	1.5	0.8	4.7	20.0
		最小	0.4	0.4	0.4	0.5	0.6	0.4	0.3	0.3	0.2	0.3	0.3	0.4	0.2
		平均	0.7	2.8	1.7	1.4	1.4	1.0	0.8	0.5	0.5	0.5	0.5	1.4	1.1
	配水	最大	0.2	0.2	0.2	0.4	0.2	0.2	0.2	0.1	0.1	0.1	0.2	0.2	0.4
		最小	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
		平均	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
pH値	原水	最大	7.5	7.4	7.6	7.5	7.3	7.3	7.3	7.5	7.5	7.5	7.5	7.4	7.6
		最小	7.3	7.2	7.3	7.1	7.1	7.2	7.2	7.2	7.3	7.3	7.4	7.3	7.1
		平均	7.4	7.3	7.4	7.3	7.2	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4
	配水	最大	7.3	7.3	7.3	7.2	7.1	7.1	7.3	7.1	7.2	7.1	7.2	7.1	7.3
		最小	6.7	6.6	7.0	6.9	6.9	6.9	6.9	7.0	7.0	7.0	6.9	6.9	6.6
		平均	7.2	7.0	7.2	7.0	7.0	7.0	7.0	7.1	7.1	7.0	7.0	7.0	7.1
総アルカリ度 (mg/l)	原水	最大	24.0	26.0	33.0	31.0	21.0	21.0	25.0	25.0	26.0	27.0	26.0	24.0	33.0
		最小	19.0	18.0	19.0	20.0	17.0	16.0	18.0	19.0	21.0	21.0	19.0	18.0	16.0
		平均	21.0	20.5	24.6	23.1	18.7	18.5	20.1	23.3	23.8	23.3	22.5	20.9	21.7
	配水	最大	20.0	20.0	29.0	28.0	17.0	18.0	21.0	21.0	21.0	20.0	20.0	19.0	29.0
		最小	9.5	9.0	16.0	17.0	15.0	13.0	15.0	16.0	17.0	17.0	15.0	14.0	9.0
		平均	17.5	15.6	21.1	19.8	15.7	15.3	16.8	19.1	19.0	18.1	18.0	16.9	17.7