

浄水場原水 試験結果書

単位：ng/L

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
高蔵寺浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
尾張東部浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
上野浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
知多浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	2	2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
犬山浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
尾張西部浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
豊田浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
幸田浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
豊橋浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
豊橋南部浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
豊川浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						

定量下限値：2ng/L

浄水場浄水 試験結果書

単位：ng/L

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
高蔵寺浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
尾張東部浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
上野浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
知多浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
犬山浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
尾張西部浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
豊田浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
幸田浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
豊橋浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
豊橋南部浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
豊川浄水場浄水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2						

定量下限値：2ng/L

原水主要地点 試験結果書

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
兼山取水口	PFOS	ng/L		< 2			< 2							
	PFOA	ng/L		< 2			< 2							
	PFHxS	ng/L		< 2			< 2							
犬山共同取水口	PFOS	ng/L		< 2			< 2							
	PFOA	ng/L		< 2			< 2							
	PFHxS	ng/L		< 2			< 2							
尾西取水口	PFOS	ng/L		< 2			< 2							
	PFOA	ng/L		< 2			< 2							
	PFHxS	ng/L		< 2			< 2							
長良川取水口	PFOS	ng/L		< 2			< 2							
	PFOA	ng/L		< 2			< 2							
	PFHxS	ng/L		< 2			< 2							
岩倉取水口	PFOS	ng/L		< 2			< 2							
	PFOA	ng/L		< 2			< 2							
	PFHxS	ng/L		< 2			< 2							
細川頭首工	PFOS	ng/L		< 2			< 2							
	PFOA	ng/L		< 2			< 2							
	PFHxS	ng/L		< 2			< 2							
大野頭首工	PFOS	ng/L		< 2			< 2							
	PFOA	ng/L		< 2			< 2							
	PFHxS	ng/L		< 2			< 2							
森岡取水場	PFOS	ng/L		< 2			< 2							
	PFOA	ng/L		< 2			< 2							
	PFHxS	ng/L		< 2			< 2							

定量下限値：2ng/L