

6 浄水場毎日検査

(1)水道用水毎日検査

上野浄水場	210
知多浄水場	210
高蔵寺浄水場	211
尾張東部浄水場	211
犬山浄水場	212
尾張西部浄水場	212

豊田浄水場	213
幸田浄水場	213
豊橋浄水場	214
豊橋南部浄水場	214
豊川浄水場	215

(2)工業用水毎日検査

上野浄水場	216
知多浄水場	216
尾張東部浄水場(東郷)	216
尾張西部浄水場	217
安城浄水場	217
豊橋南部浄水場	217
蒲郡浄水場(工水)	218

(1)水道用水毎日検査

上野浄水場

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (℃)		最大	22.3	24.1	29.6	33.9	33.3	32.3	27.4	21.5	13.5	9.1	10.2	19.0	33.9	
		最小	11.7	16.3	18.3	23.0	23.8	24.3	18.1	9.5	4.9	-0.4	-0.3	4.0	-0.4	
		平均	18.4	20.7	24.6	30.3	31.1	29.2	22.6	15.6	8.2	6.1	5.2	10.9	18.6	
原水水温 (℃)		最大	16.9	19.8	22.4	26.2	28.2	27.0	24.6	19.6	12.9	7.4	8.1	11.3	28.2	
		最小	10.1	16.6	19.1	21.8	25.8	24.4	19.5	13.1	7.2	5.9	5.5	6.7	5.5	
		平均	13.8	18.3	20.9	23.4	27.0	25.7	21.9	16.2	9.7	6.7	6.1	8.6	16.5	
濁度 (度)	原水	最大	16.5	16.1	18.8	19.4	6.1	16.2	5.6	9.1	3.6	3.1	3.4	4.9	19.4	
		最小	4.9	2.8	2.9	2.9	2.6	3.2	2.9	2.2	1.3	1.3	1.8	2.0	1.3	
		平均	8.7	4.6	7.0	7.7	3.7	6.6	3.9	4.0	2.1	1.9	2.8	3.1	4.7	
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	3.4	5.8	6.8	8.3	5.1	6.4	5.0	6.3	3.8	2.1	1.6	2.7	8.3	
		最小	1.0	2.5	3.1	4.4	3.5	4.0	3.4	2.5	2.0	1.1	0.6	1.6	0.6	
		平均	2.3	3.5	4.4	5.6	4.1	5.1	4.2	3.7	2.8	1.8	1.1	2.0	3.4	
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.5	7.5	7.5	7.5	7.6	7.7	7.5	7.5	7.5	7.6	7.6	7.5	7.7	
		最小	7.2	7.2	7.2	7.1	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.3	7.1	
		平均	7.4	7.4	7.3	7.3	7.4	7.5	7.4	7.4	7.5	7.5	7.5	7.5	7.4	
	浄水	最大	7.4	7.4	7.2	7.2	7.1	7.2	7.2	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.3	7.1	7.2	7.0	7.0	7.0	7.1	7.3	7.3	7.4	7.2	7.2	7.0	7.0
		平均	7.4	7.3	7.2	7.1	7.0	7.0	7.2	7.4	7.4	7.4	7.3	7.3	7.3	7.3
総7日平均濃度 (mg/l)	原水	最大	17.5	18.0	17.5	16.0	19.5	17.5	17.5	19.5	21.5	22.0	21.5	22.5	22.5	
		最小	13.5	15.5	14.5	13.5	16.0	16.0	15.5	15.5	19.0	20.5	20.5	17.5	13.5	
		平均	15.2	16.5	15.5	14.2	17.8	16.8	16.6	17.2	20.3	21.1	21.0	19.2	17.6	
	浄水	最大	16.5	16.5	16.0	14.0	16.5	15.0	16.0	18.0	19.5	20.0	19.5	19.5	20.0	20.0
		最小	14.0	14.0	13.5	12.0	13.5	13.0	14.0	15.0	17.5	18.5	18.0	16.0	12.0	12.0
		平均	14.6	15.4	14.4	13.0	14.6	13.8	14.8	16.1	18.7	19.4	18.8	17.4	15.9	15.9
KMnO ₄ 消費量 (mg/l)	原水	最大	5.4	4.4	5.5	6.3	4.4	5.5	4.7	5.4	3.4	2.8	3.2	3.5	6.3	
		最小	3.0	2.8	2.5	3.1	3.0	3.8	3.5	2.8	1.9	1.9	2.0	2.1	1.9	1.9
		平均	4.0	3.5	3.7	4.4	3.5	4.5	4.1	3.8	2.9	2.4	2.7	2.5	3.5	3.5
	浄水	最大	1.3	1.1	1.6	1.2	0.9	0.9	1.1	1.4	0.9	1.1	1.1	0.9	1.6	1.6
		最小	0.5	0.5	0.5	0.5	0.3	0.2	0.3	0.6	0.3	0.3	0.5	0.3	0.2	0.2
		平均	0.9	0.8	0.9	0.9	0.6	0.7	0.8	1.1	0.7	0.7	0.9	0.7	0.8	0.8
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.6
		最小	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.5	0.5	0.4	0.4
		平均	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5

知多浄水場

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (℃)		最大	25.0	26.0	29.0	35.0	35.0	34.0	28.0	20.0	12.0	10.0	10.0	19.0	35.0	
		最小	10.0	16.0	17.0	23.0	24.0	23.0	13.0	10.0	3.0	-1.0	1.0	4.0	-1.0	
		平均	18.3	20.8	24.5	30.8	31.6	29.6	22.1	15.1	7.0	5.2	4.5	10.4	18.3	
原水水温 (℃)		最大	20.2	22.4	26.9	28.8	32.6	29.9	26.7	19.5	13.2	9.4	9.2	14.9	32.6	
		最小	14.0	18.5	19.0	20.7	27.0	24.0	20.3	13.3	8.5	7.5	6.3	9.0	6.3	
		平均	17.3	20.7	23.6	25.2	31.3	27.4	22.8	16.7	10.5	8.4	8.0	11.4	18.6	
濁度 (度)	原水	最大	19.9	82.8	28.3	33.6	8.9	38.0	6.8	16.1	12.2	6.1	7.9	13.3	82.8	
		最小	2.7	3.7	3.9	4.0	3.1	2.9	2.5	1.6	1.7	1.9	1.9	2.4	1.6	
		平均	6.5	8.9	8.9	9.6	6.3	6.6	4.2	3.6	3.4	3.4	3.5	4.4	5.8	
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	12.8	52.1	17.0	18.9	9.3	22.0	9.6	12.2	5.9	4.2	4.9	6.3	52.1	
		最小	2.8	3.9	4.4	3.6	5.5	3.4	2.8	2.5	2.1	2.2	2.5	2.2	2.1	
		平均	5.0	7.4	6.6	6.5	7.1	5.8	4.6	4.0	3.2	3.0	3.0	3.4	4.9	
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.4	8.7	8.7	7.5	8.8	8.2	7.8	7.9	7.7	7.7	7.8	7.7	8.8	
		最小	7.1	6.9	6.9	6.9	7.0	6.9	7.0	7.0	7.2	7.5	7.5	7.1	6.9	
		平均	7.3	7.3	7.5	7.2	7.6	7.3	7.3	7.4	7.5	7.6	7.6	7.4	7.4	
	浄水	最大	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	0.4	7.3	7.3	0.4	0.4
		平均	7.3	7.4	7.3	7.4	7.3	7.4	7.4	7.3	7.3	7.1	7.4	7.3	7.3	7.3
総7日平均濃度 (mg/l)	原水	最大	32.5	35.0	36.5	31.0	38.0	36.0	36.0	38.5	37.5	38.0	37.0	35.5	38.5	
		最小	16.0	14.5	17.0	17.5	27.5	18.0	20.0	18.5	18.5	31.0	31.5	16.5	14.5	
		平均	25.5	28.4	29.3	25.9	33.9	28.3	30.2	31.7	28.6	34.6	34.7	27.5	29.9	
	浄水	最大	32.5	33.5	36.0	32.0	37.0	36.0	34.5	37.5	35.5	36.0	36.5	35.0	37.5	
		最小	18.0	18.0	20.0	20.0	27.0	19.0	22.5	20.0	17.0	30.0	30.0	20.0	17.0	
		平均	25.4	28.1	29.4	27.3	33.4	28.9	30.1	30.9	27.6	33.2	33.1	27.1	29.5	
KMnO ₄ 消費量 (mg/l)	原水	最大	8.9	13.1	7.2	9.2	7.8	10.5	8.1	9.5	5.9	4.3	5.1	6.3	13.1	
		最小	3.8	3.8	3.0	2.8	4.0	3.1	2.8	3.1	2.8	2.8	3.2	2.5	2.5	
		平均	5.1	5.9	5.2	5.1	5.8	5.1	4.4	4.1	4.3	3.5	4.0	4.0	4.7	
	浄水	最大	1.9	2.2	1.9	1.9	1.6	2.2	1.9	1.9	1.9	1.6	1.6	1.9	2.2	
		最小	1.0	0.6	0.0	0.3	0.3	0.6	0.9	0.9	0.6	0.6	0.6	0.9	0.0	
		平均	1.5	1.4	1.0	1.1	1.1	1.3	1.2	1.2	1.2	1.0	1.3	1.2	1.2	
残留塩素 (mg/l)	浄水	最大	0.6	0.8	0.7	0.7	0.8	0.8	0.7	0.6	0.6	0.5	0.5	0.5	0.8	
		最小	0.4	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.4	0.4	0.4	0.4	
		平均	0.5	0.6	0.6	0.6	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.6	

高蔵寺浄水場

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)		最大	24.6	25.2	29.6	34.9	34.8	33.2	28.9	21.8	14.2	10.3	11.4	20.5	34.9
		最小	13.2	16.3	18.1	22.6	23.1	25.2	17.0	8.3	3.1	-0.2	-1.2	4.0	-1.2
		平均	19.3	21.4	25.0	30.5	31.5	29.9	23.1	16.1	7.8	6.7	5.6	11.6	19.0
原水水温 (℃)		最大	15.8	18.3	21.8	24.0	26.8	25.5	22.2	17.2	11.2	7.0	7.0	10.9	26.8
		最小	10.9	11.8	16.7	18.5	23.0	22.0	17.3	10.7	6.3	5.2	5.0	6.0	5.0
		平均	13.1	16.5	19.0	21.0	25.4	23.6	19.3	14.2	8.4	6.2	5.8	8.1	15.0
濁度 (度)	原水	最大	84.3	142.2	53.1	68.8	5.3	71.0	8.2	54.7	3.2	4.2	4.6	16.2	142.2
		最小	4.2	3.8	4.0	3.1	2.2	2.2	2.0	1.8	1.2	1.1	1.6	1.8	1.1
		平均	13.0	12.3	11.1	12.7	3.4	9.1	3.7	6.0	1.8	2.0	2.5	3.8	6.8
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	25.3	40.3	18.0	28.0	4.9	20.7	7.2	22.4	3.7	2.3	3.4	6.8	40.3
		最小	1.9	2.3	1.6	2.3	2.6	2.5	2.4	1.4	1.5	1.6	1.4	1.7	1.4
		平均	4.7	5.1	4.6	5.8	3.4	6.0	3.9	3.9	2.2	1.8	2.0	2.9	3.9
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.5	7.5	7.5
		最小	7.0	6.9	7.1	7.0	7.2	7.0	7.2	7.0	7.2	7.3	7.3	7.2	6.9
		平均	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.4	7.3	7.3
	浄水	最大	7.4	7.4	7.4	7.3	7.2	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.4
		最小	7.2	7.3	7.2	7.2	7.1	7.1	7.2	7.2	7.3	7.3	7.3	7.3	7.1
		平均	7.3	7.3	7.3	7.3	7.2	7.2	7.3	7.3	7.4	7.4	7.4	7.3	7.3
総7日削減度 (mg/l)	原水	最大	16.5	17.5	17.5	16.5	20.0	18.0	18.0	20.0	21.5	21.5	21.5	21.5	21.5
		最小	9.0	8.5	9.5	9.5	15.0	12.0	11.5	11.5	17.0	18.5	19.0	12.5	8.5
		平均	13.9	15.1	14.6	13.6	17.6	15.6	15.4	17.0	19.7	20.0	19.9	17.1	16.6
	浄水	最大	16.0	17.5	17.0	15.5	17.5	17.0	16.5	19.5	21.0	21.0	20.5	20.5	21.0
		最小	10.0	10.0	11.0	10.5	14.5	13.5	12.0	11.0	16.5	18.0	17.5	14.5	10.0
		平均	13.7	15.1	14.3	12.9	16.1	14.9	14.7	16.4	19.3	19.6	19.3	17.0	16.1
KMnO ₄ 消費量 (mg/l)	原水	最大	21.4	23.6	22.4	19.5	6.7	11.8	8.7	16.8	4.2	3.6	4.0	6.3	23.6
		最小	3.1	2.9	2.9	3.4	3.4	2.6	3.2	2.6	2.2	2.3	2.8	2.5	2.2
		平均	5.4	5.5	5.9	6.3	4.3	6.1	4.6	4.3	3.1	2.9	3.2	3.5	4.6
	浄水	最大	1.4	1.5	1.7	1.4	1.5	1.9	1.7	1.5	1.2	1.2	1.5	1.4	1.9
		最小	0.8	0.9	0.8	0.8	0.9	0.9	0.9	0.9	0.8	0.9	0.9	0.9	0.8
		平均	1.0	1.1	1.2	1.0	1.2	1.3	1.2	1.1	1.0	1.0	1.1	1.1	1.1
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
		最小	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.4	0.4	0.4	0.4
		平均	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5

尾張東部浄水場

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)		最大	20.4	22.8	26.9	31.6	31.9	30.1	25.5	18.7	10.6	7.9	9.0	16.1	31.9
		最小	11.8	14.7	19.3	23.6	24.0	23.5	16.8	7.7	3.3	0.1	0.1	5.3	0.1
		平均	16.8	19.1	23.1	28.6	29.6	27.6	21.0	13.9	6.0	4.7	3.8	9.8	17.0
原水水温 (℃)		最大	16.6	19.2	21.0	23.5	26.5	25.0	22.6	18.0	12.0	12.0	10.3	12.7	26.5
		最小	10.5	15.5	17.0	18.5	23.0	22.0	18.0	12.0	7.0	7.0	5.5	7.5	5.5
		平均	13.4	17.0	19.1	20.8	25.2	23.7	19.9	15.1	9.5	9.5	6.7	9.1	15.7
濁度 (度)	原水	最大	54.7	136.0	84.6	90.9	7.1	86.1	7.0	46.4	3.2	4.4	4.3	6.4	136.0
		最小	4.5	4.0	3.7	2.5	1.2	1.3	1.8	1.5	1.1	1.1	1.5	1.0	1.0
		平均	13.8	12.6	12.6	12.1	3.3	8.8	2.8	5.2	2.0	2.0	2.3	3.2	6.7
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	18.5	38.0	32.1	44.3	4.4	32.8	6.8	16.7	3.6	2.6	3.1	3.8	44.3
		最小	1.8	1.6	1.8	1.6	2.1	2.0	2.1	1.9	1.5	1.3	< 0.5	1.0	< 0.5
		平均	4.1	4.9	5.4	5.0	3.3	5.7	3.5	3.2	2.1	1.7	1.6	2.4	3.6
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	0.6	1.1	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	1.1
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.6	7.7	7.5	7.5	7.7	7.6	7.6	7.6	7.6	7.6	7.5	7.5	7.7
		最小	7.1	7.1	7.0	7.1	7.3	7.2	7.2	7.1	7.3	7.4	7.4	7.3	7.0
		平均	7.4	7.5	7.4	7.4	7.5	7.4	7.4	7.4	7.5	7.5	7.5	7.4	7.4
	浄水	最大	7.3	7.3	7.3	7.3	7.3	7.2	7.3	7.3	7.3	7.3	7.2	7.2	7.3
		最小	7.2	7.1	7.1	7.1	7.1	7.1	7.0	7.1	7.1	7.1	7.1	7.1	7.0
		平均	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2
総7日削減度 (mg/l)	原水	最大	17.0	19.5	19.5	17.5	20.0	18.0	18.0	20.5	21.5	21.5	22.0	22.0	22.0
		最小	9.0	10.0	9.0	10.0	15.5	11.5	11.5	10.5	16.5	18.0	18.0	14.0	9.0
		平均	13.8	15.5	15.0	13.8	17.8	15.7	15.4	16.8	19.5	19.7	20.0	17.5	16.7
	浄水	最大	15.0	16.0	16.5	15.5	18.5	17.0	16.5	18.5	19.5	19.5	20.0	20.0	20.0
		最小	9.5	10.0	10.5	10.5	14.0	12.0	11.5	11.0	14.5	16.0	16.5	13.0	9.5
		平均	12.7	14.1	13.9	13.0	16.2	14.5	14.0	15.3	17.6	17.8	18.1	15.9	15.3
KMnO ₄ 消費量 (mg/l)	原水	最大	10.5	14.1	21.6	20.8	5.2	12.5	8.6	11.6	4.4	3.8	3.8	4.4	21.6
		最小	1.7	3.5	3.3	2.3	2.9	2.7	2.3	1.8	2.2	1.4	2.0	1.8	1.4
		平均	4.7	5.4	5.9	5.6	3.9	5.2	3.9	3.7	3.2	2.9	3.0	2.8	4.2
	浄水	最大	1.6	1.4	1.7	1.5	1.9	2.0	1.6	1.7	1.6	2.0	1.2	1.1	2.0
		最小	0.6	0.8	0.8	0.3	0.6	0.6	0.8	0.6	0.5	0.3	0.6	0.3	0.3
		平均	1.1	1.1	1.1	0.9	1.1	1.1	1.0	0.9	1.0	1.0	1.0	0.8	1.0
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.7	0.7	0.7	0.8	0.8	0.7	0.6	0.6	0.5	0.5	0.8
		最小	0.5	0.5	0.6	0.6	0.7	0.7	0.7	0.7	0.6	0.6	0.5	0.5	0.5
		平均	0.5	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.6	0.6	0.5	0.5	0.6

犬山浄水場

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (℃)		最大	23.7	24.6	28.7	33.6	34.6	31.7	26.8	20.7	13.0	9.7	9.6	19.5	34.6	
		最小	11.2	16.4	17.8	21.9	23.6	24.5	16.6	7.1	3.4	-0.1	-0.3	4.0	-0.3	
		平均	18.4	20.8	24.0	29.4	30.7	29.0	22.0	15.2	7.3	6.0	4.8	11.2	18.2	
原水水温 (℃)		最大	15.5	18.2	21.3	24.1	27.1	25.5	22.8	17.1	11.3	6.7	6.6	11.8	27.1	
		最小	10.4	14.8	16.1	18.0	22.8	22.3	17.3	11.1	6.2	4.8	5.1	6.5	4.8	
		平均	12.7	16.3	18.8	21.1	25.7	23.7	19.4	14.3	8.6	5.9	5.7	8.4	15.1	
濁度 (度)	原水	最大	99.5	139.0	82.0	75.2	4.4	46.1	14.1	78.9	1.8	2.7	3.1	8.0	139.0	
		最小	2.6	1.9	2.7	1.9	1.6	1.6	1.5	1.0	0.9	1.1	1.1	1.2	0.9	
		平均	10.7	9.7	11.1	10.4	2.3	6.0	3.7	5.9	1.2	1.6	1.7	2.5	5.6	
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	32.8	37.5	34.8	23.4	5.9	11.3	7.0	25.9	3.4	3.3	2.7	5.5	37.5	
		最小	2.9	2.8	3.1	2.3	3.1	1.7	2.3	2.3	1.9	1.9	1.5	1.6	1.5	
		平均	4.9	5.6	6.0	5.8	4.1	4.8	4.1	4.1	2.5	2.3	2.0	2.9	4.1	
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.4	7.4	7.4	7.4	7.4	7.3	7.4	7.4	7.4	7.5	7.4	7.4	7.5	
		最小	7.2	7.0	7.1	7.1	7.1	7.1	7.2	7.0	7.3	7.3	7.2	7.2	7.0	
		平均	7.3	7.3	7.3	7.3	7.2	7.2	7.3	7.3	7.4	7.4	7.3	7.3	7.3	
	浄水	最大	7.4	7.4	7.4	7.3	7.2	7.2	7.4	7.4	7.4	7.4	7.4	7.4	7.4	
		最小	7.3	7.3	7.2	7.2	7.1	7.1	7.1	7.3	7.3	7.3	7.3	7.3	7.1	
		平均	7.3	7.3	7.3	7.2	7.1	7.1	7.3	7.3	7.4	7.3	7.3	7.3	7.3	
総7ℓり度 (mg/l)	原水	最大	15.8	17.2	17.4	16.4	19.0	18.4	17.7	20.2	21.9	21.7	21.4	20.9	21.9	
		最小	8.6	8.1	8.6	9.3	15.2	13.3	10.6	9.3	17.7	19.5	18.6	12.6	8.1	
		平均	13.5	15.1	14.3	13.2	17.5	15.4	15.2	16.9	20.1	20.7	20.4	16.7	16.6	
	浄水	最大	15.0	16.8	16.0	14.6	17.1	16.2	17.1	19.4	20.6	20.6	20.8	20.6	20.8	
		最小	8.9	9.6	10.0	9.1	14.0	12.3	10.4	10.6	16.8	18.6	18.0	12.3	8.9	
		平均	12.8	14.8	13.9	12.2	15.5	14.1	14.4	16.1	19.0	19.6	19.5	16.0	15.7	
KMnO ₄ 消費量 (mg/l)	原水	最大	17.0	28.2	22.2	13.3	5.8	7.6	9.0	20.1	4.8	4.0	4.0	5.1	28.2	
		最小	2.9	3.4	3.2	3.2	3.3	3.2	3.1	3.1	2.9	2.9	2.9	2.5	2.5	
		平均	4.1	5.0	5.0	4.8	4.3	5.0	4.7	4.2	3.6	3.6	3.6	3.2	4.3	
	浄水	最大	1.2	1.8	1.4	1.2	1.7	1.6	1.6	1.6	1.6	1.8	1.6	1.4	1.8	
		最小	0.3	0.6	0.5	0.5	0.9	1.0	1.0	0.5	0.8	0.8	0.8	0.4	0.3	
		平均	0.9	1.3	0.9	0.8	1.2	1.3	1.3	1.0	1.3	1.3	1.3	0.8	1.1	
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.6	0.6	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.7	
		最小	0.4	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.4	0.4	
		平均	0.5	0.5	0.6	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	

尾張西部浄水場

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)		最大	25.2	26.0	29.0	34.8	36.0	35.3	29.5	23.5	15.9	12.7	11.5	20.5	36.0
		最小	11.7	16.0	17.8	22.1	25.7	24.4	18.9	9.7	4.2	2.5	1.5	6.1	1.5
		平均	19.0	21.2	24.5	30.1	32.2	30.5	23.9	16.8	9.0	8.0	7.3	12.2	19.6
原水水温 (℃)		最大	18.0	20.4	23.5	26.5	30.3	28.1	24.9	17.9	12.4	8.5	8.9	11.8	30.3
		最小	10.9	16.0	17.4	18.9	25.1	23.3	17.6	10.8	6.3	3.0	4.7	6.8	3.0
		平均	14.2	18.1	20.6	22.7	28.4	25.7	20.6	14.9	9.2	6.8	6.9	9.4	16.5
濁度 (度)	原水	最大	90.6	93.1	45.3	118.0	5.2	23.3	11.0	45.5	2.7	7.3	4.8	6.3	118.0
		最小	2.0	1.8	1.7	1.6	0.9	2.2	1.8	1.2	1.0	1.0	1.3	0.7	0.7
		平均	11.3	8.8	10.1	12.6	3.5	5.6	4.1	5.9	1.5	1.8	2.5	2.5	5.9
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	25.8	29.4	17.9	37.0	5.5	8.9	6.7	22.4	3.9	3.7	3.5	3.9	37.0
		最小	2.7	2.4	2.7	2.4	2.8	3.0	2.1	1.8	1.6	1.5	1.8	1.8	1.5
		平均	5.3	5.1	5.5	6.6	4.1	4.7	3.8	4.2	2.4	2.4	2.4	2.6	4.1
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.5	7.7	7.4	7.3	7.4	7.3	7.5	7.7	7.8	7.7	7.6	7.5	7.8
		最小	7.0	6.9	7.0	7.0	7.1	7.0	6.9	7.0	7.4	7.4	7.4	7.2	6.9
		平均	7.3	7.3	7.2	7.2	7.2	7.2	7.3	7.4	7.6	7.5	7.5	7.4	7.3
	浄水	最大	7.4	7.5	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.3	7.4	7.4	7.5
		最小	7.3	7.3	7.3	7.2	7.3	7.3	7.3	7.3	7.2	7.3	7.2	7.3	7.2
		平均	7.4	7.3	7.4	7.4	7.3	7.4	7.3	7.3	7.3	7.3	7.3	7.4	7.3
総7ℓり度 (mg/l)	原水	最大	18.0	19.5	19.0	18.0	21.5	20.0	19.0	22.0	24.0	24.0	24.0	21.5	24.0
		最小	9.5	9.0	10.0	10.0	17.0	14.5	11.5	11.0	20.5	22.0	20.5	15.0	9.0
		平均	14.9	16.3	15.6	14.8	19.5	16.8	16.4	18.5	22.5	22.8	22.1	18.0	18.2
	浄水	最大	18.0	18.0	18.5	17.5	19.5	19.0	19.5	21.0	22.5	22.5	22.0	21.5	22.5
		最小	10.5	10.5	11.5	11.5	17.0	15.0	12.0	11.5	18.5	20.0	19.0	15.5	10.5
		平均	14.8	15.9	15.7	15.0	18.4	16.8	16.1	17.9	20.4	21.0	20.6	17.7	17.5
KMnO ₄ 消費量 (mg/l)	原水	最大	17.1	15.6	14.8	14.2	5.6	6.5	8.4	13.6	4.8	5.3	7.0	5.0	17.1
		最小	3.2	3.2	3.0	2.9	3.3	3.6	2.5	3.0	2.9	2.7	3.7	2.3	2.3
		平均	4.6	4.7	4.9	5.1	4.1	4.8	4.1	4.3	3.7	3.7	4.5	3.7	4.4
	浄水	最大	2.0	1.8	1.8	1.9	1.8	2.1	2.1	2.1	1.9	2.3	2.5	2.0	2.5
		最小	0.8	0.9	0.6	0.7	0.7	0.6	0.6	1.0	1.1	0.8	1.2	0.9	0.6
		平均	1.4	1.3	1.0	1.2	1.2	1.2	1.2	1.4	1.5	1.5	2.0	1.4	1.4
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.7	0.6	0.8	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.8
		最小	0.4	0.5	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.4	0.3	0.4	0.3
		平均	0.5	0.5	0.6	0.6	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5

豊田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)	最大	23.6	25.0	28.1	33.3	34.5	32.4	28.1	23.3	12.0	9.5	10.0	20.2	34.5
	最小	11.4	13.2	17.9	19.2	24.0	23.2	15.6	8.1	1.8	-1.3	0.2	3.7	-1.3
	平均	18.3	20.4	24.2	29.6	30.7	28.7	22.0	15.0	5.9	4.5	4.5	10.9	17.9
原水水温 (℃)	最大	16.2	16.9	20.2	23.8	25.4	24.6	22.8	17.7	11.5	6.6	5.8	10.7	25.4
	最小	9.3	14.9	16.1	19.0	22.0	22.1	17.4	10.8	6.1	4.4	4.0	4.9	4.0
	平均	13.1	16.0	18.4	21.4	23.8	23.4	19.7	14.6	8.4	5.4	4.6	7.2	14.7
濁度 (度)	原水	最大	8.8	18.6	16.0	27.1	40.7	17.1	24.5	24.3	3.0	3.2	5.4	40.7
		最小	2.0	1.8	2.0	1.9	1.2	1.5	1.7	1.9	1.6	1.7	2.7	1.9
		平均	3.9	4.6	4.7	6.0	4.7	4.0	5.3	3.9	2.1	2.4	3.2	2.9
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	5.8	20.1	8.3	12.0	20.5	9.6	21.0	9.5	4.9	4.3	3.0	21.0
		最小	2.8	2.4	2.7	3.6	3.8	4.0	1.9	4.1	2.6	2.0	1.6	1.6
		平均	3.6	4.3	5.0	5.4	5.5	5.5	6.1	5.5	3.6	2.5	2.4	2.6
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.5	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.5	7.5	7.4
		最小	7.2	7.2	7.2	7.2	7.1	7.2	7.1	7.2	7.3	7.4	7.3	7.1
		平均	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.3
	浄水	最大	7.4	7.3	7.4	7.4	7.4	7.3	7.4	7.4	7.4	7.4	7.3	7.4
		最小	7.3	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2
		平均	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
総トリカド度 (mg/l)	原水	最大	18.5	18.5	18.5	17.5	21.5	21.0	20.5	20.0	19.5	19.5	20.0	19.5
		最小	14.0	13.5	13.5	12.5	15.5	14.0	15.5	16.0	18.0	17.5	18.0	16.5
		平均	15.7	16.6	15.6	15.9	18.9	18.5	18.7	18.3	18.6	18.5	18.9	17.7
	浄水	最大	17.0	17.5	17.0	16.5	20.0	20.0	19.0	18.5	18.0	18.0	18.5	20.0
		最小	12.5	14.0	14.0	14.0	14.5	13.5	15.5	16.0	16.5	16.0	17.0	12.5
		平均	14.0	15.8	15.2	15.2	17.7	17.4	17.2	17.4	17.4	16.9	17.4	16.5
KMnO ₄ 消費量 (mg/l)	原水	最大	5.8	10.9	8.9	12.3	13.5	8.6	17.4	11.1	5.1	5.6	3.6	17.4
		最小	2.8	1.8	3.0	2.2	2.3	3.2	4.4	3.1	2.2	2.1	2.0	2.1
		平均	3.9	4.9	4.8	5.2	5.0	5.2	6.5	4.8	3.0	3.1	2.7	3.3
	浄水	最大	1.5	1.8	1.9	2.3	1.6	2.6	2.2	2.2	1.6	1.4	1.5	1.7
		最小	0.1	0.3	0.1	0.3	0.1	0.3	0.4	0.6	0.1	0.4	0.1	0.1
		平均	0.7	0.9	0.7	1.1	0.8	1.0	1.4	1.2	0.6	1.1	0.8	0.9
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.6	0.7
		最小	0.5	0.5	0.5	0.5	0.5	0.6	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.6

幸田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)	最大	23.7	25.5	30.5	35.1	34.4	33.5	29.1	23.0	15.1	10.0	11.4	21.0	35.1
	最小	13.8	15.0	18.6	23.8	24.3	25.8	18.1	10.4	3.5	0.9	-0.3	3.3	-0.3
	平均	19.5	21.6	25.4	31.3	31.8	30.2	23.4	16.6	9.0	7.1	6.6	12.0	19.5
原水水温 (℃)	最大	18.0	20.5	24.0	28.5	29.5	27.0	23.0	18.5	11.0	6.5	7.0	13.5	29.5
	最小	11.5	16.5	18.0	21.0	23.5	23.0	18.0	11.5	6.0	4.5	4.0	6.5	4.0
	平均	14.5	18.0	20.8	24.8	27.7	25.2	20.4	15.0	8.2	5.6	5.1	9.2	16.2
濁度 (度)	原水	最大	17.0	31.0	38.0	23.0	22.0	68.0	38.0	37.0	1.9	3.7	1.2	68.0
		最小	1.8	3.3	2.8	2.9	2.5	2.7	2.1	1.0	0.6	0.5	0.6	0.7
		平均	7.3	10.7	9.3	7.2	6.6	9.9	6.4	4.6	1.0	0.9	0.8	2.5
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	18.0	30.0	33.0	23.0	33.0	43.0	34.0	28.0	4.4	7.0	3.7	43.0
		最小	4.1	5.3	4.8	5.5	5.3	5.5	4.4	3.3	2.5	2.3	2.1	2.2
		平均	7.2	10.3	9.2	8.1	8.8	10.2	7.8	6.1	3.2	2.9	2.7	4.9
	浄水	最大	< 0.5	0.5	< 0.5	< 0.5	0.7	0.5	0.6	0.7	< 0.5	< 0.5	0.6	0.7
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.2	7.2	7.2	7.3	7.3	7.1	7.2	7.3	7.4	7.4	7.5	7.4
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.5	7.5	7.5	7.5	7.4
	浄水	最大	7.5	7.4	7.4	7.5	7.5	7.5	7.4	7.5	7.5	7.5	7.5	7.5
		最小	7.4	7.4	7.4	7.4	7.4	7.3	7.4	7.4	7.4	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総トリカド度 (mg/l)	原水	最大	19.0	20.5	19.5	20.5	20.0	20.5	19.5	19.5	20.0	21.0	21.5	21.5
		最小	12.0	12.0	13.0	14.0	14.0	12.5	11.0	13.0	18.5	18.0	19.5	11.0
		平均	17.2	17.4	17.4	18.4	18.2	16.1	17.4	18.0	19.5	20.5	20.5	18.4
	浄水	最大	18.0	19.0	19.0	20.0	18.5	18.5	18.5	18.5	19.5	20.0	20.5	20.5
		最小	12.5	13.0	14.0	14.5	14.0	12.0	13.0	13.0	17.0	18.0	18.5	12.0
		平均	16.3	16.4	16.5	17.2	17.1	15.5	16.3	16.9	18.6	19.5	19.5	17.4
KMnO ₄ 消費量 (mg/l)	原水	最大	12.7	23.2	22.6	18.4	24.1	23.2	26.2	18.4	4.3	9.0	4.6	26.2
		最小	3.3	5.1	4.9	5.2	5.6	5.5	4.0	3.3	2.7	2.1	2.4	2.1
		平均	7.0	8.7	9.1	8.2	9.5	9.5	7.6	5.6	3.1	3.0	3.1	6.6
	浄水	最大	1.5	2.1	1.8	1.8	2.8	2.2	2.2	2.7	1.5	2.5	1.2	2.8
		最小	0.6	1.2	0.9	0.6	0.9	0.6	1.2	0.9	0.6	0.6	0.6	1.1
		平均	1.3	1.4	1.4	1.3	1.6	1.3	1.6	1.2	0.9	0.9	1.1	1.3
残留塩素 (mg/l)	浄水	最大	0.6	0.7	0.7	0.8	0.8	0.8	0.7	0.7	0.6	0.5	0.5	0.8
		最小	0.5	0.6	0.6	0.7	0.8	0.6	0.6	0.6	0.5	0.4	0.4	0.4
		平均	0.6	0.6	0.6	0.7	0.8	0.7	0.6	0.6	0.5	0.5	0.5	0.6

豊橋浄水場

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)		最大	22.3	24.6	28.9	34.4	33.6	32.8	27.9	23.0	13.6	9.7	11.1	19.9	34.4
		最小	13.8	15.3	17.9	23.0	24.1	24.7	16.9	9.6	4.9	1.9	0.3	2.8	0.3
		平均	18.9	20.9	24.5	30.9	30.4	29.2	22.7	16.2	8.5	6.5	5.7	11.6	18.8
原水水温 (℃)		最大	19.3	21.0	24.0	29.5	30.1	27.5	24.0	19.3	11.0	6.6	7.6	15.6	30.1
		最小	13.2	16.3	18.1	21.1	22.6	23.1	18.5	11.0	5.6	4.6	4.0	7.5	4.0
		平均	16.0	18.4	21.1	25.6	28.1	25.1	20.9	15.4	7.7	5.7	5.5	10.7	16.7
濁度 (度)	原水	最大	16.0	26.0	32.0	8.0	233.0	85.0	95.0	83.0	1.5	2.3	2.0	7.0	233.0
		最小	1.8	1.9	1.5	1.8	1.7	4.1	3.6	1.1	0.6	0.6	0.7	1.5	0.6
		平均	3.7	4.2	4.9	2.9	20.3	11.3	12.4	6.9	0.9	1.1	1.3	2.2	6.0
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	15.0	20.0	16.0	10.0	85.0	34.0	45.0	37.0	3.0	4.0	2.6	8.1	85.0
		最小	2.8	3.3	2.6	3.3	3.7	3.7	1.3	2.2	1.4	1.4	1.4	1.8	1.3
		平均	4.3	5.5	5.4	4.6	12.0	7.4	8.7	5.3	1.8	1.9	1.9	3.9	5.2
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.5	7.4	7.5	7.5	7.7	7.5	7.6	7.6	7.9	8.0	7.7	7.6	8.0
		最小	7.2	7.1	7.2	7.3	7.3	7.3	7.3	7.2	7.5	7.4	7.5	7.3	7.1
		平均	7.4	7.3	7.4	7.4	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.5	7.5
	浄水	最大	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.3	7.3	7.4	7.4	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総7日総度 (mg/l)	原水	最大	25.5	26.0	27.0	27.5	38.0	31.5	32.5	29.0	29.0	29.0	28.5	29.0	38.0
		最小	14.0	13.0	15.5	16.0	17.0	19.0	18.5	16.0	25.0	25.0	26.0	23.5	13.0
		平均	21.2	21.2	22.2	24.1	26.7	25.3	24.5	24.4	26.7	27.0	27.3	26.5	24.8
	浄水	最大	22.5	23.0	23.0	23.0	24.5	24.0	26.0	24.5	24.0	26.0	25.0	26.5	26.5
		最小	13.5	13.5	15.0	15.0	16.5	16.0	17.5	14.0	20.5	21.0	23.0	21.0	13.5
		平均	18.8	19.3	19.4	20.7	21.8	21.2	21.2	21.5	22.6	23.5	24.1	23.4	21.5
KMnO ₄ 消費量 (mg/l)	原水	最大	10.0	15.0	18.0	8.8	25.0	14.0	17.0	17.0	3.0	4.4	3.3	8.6	25.0
		最小	2.9	2.6	2.0	2.8	3.4	2.8	2.6	2.3	1.3	1.4	1.5	2.4	1.3
		平均	4.2	4.6	5.1	4.4	6.8	5.1	5.6	4.4	2.3	2.5	2.3	4.6	4.3
	浄水	最大	1.4	1.4	1.7	1.4	1.9	1.3	1.4	1.4	1.2	1.2	1.2	1.8	1.9
		最小	0.5	0.2	0.2	0.4	0.4	0.4	0.5	0.5	0.2	0.1	0.6	0.6	0.1
		平均	1.0	0.8	0.7	0.9	1.1	0.8	0.9	0.9	0.8	0.7	0.9	1.3	0.9
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.6
		最小	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5

豊橋南部浄水場

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)		最大	22.4	24.0	28.9	33.5	33.0	32.7	27.7	22.6	13.5	10.1	10.8	19.3	33.5
		最小	13.1	15.3	17.5	22.3	23.2	25.2	16.7	9.5	5.1	2.1	1.0	3.3	1.0
		平均	18.4	20.3	24.1	30.3	30.3	28.9	22.5	15.9	8.5	6.7	5.8	11.5	18.6
原水水温 (℃)		最大	14.0	18.0	20.0	23.7	24.5	25.7	23.8	20.0	13.7	9.0	7.6	11.9	25.7
		最小	10.5	13.0	16.7	19.8	21.4	23.6	19.0	14.2	9.0	7.2	6.0	6.6	6.0
		平均	12.7	15.5	18.6	22.2	23.3	24.7	21.2	16.9	11.0	7.9	6.6	8.8	15.8
濁度 (度)	原水	最大	7.3	2.2	9.6	2.9	13.8	10.0	40.7	15.0	1.5	1.4	1.5	3.6	40.7
		最小	0.8	0.9	1.0	0.9	0.8	0.7	0.9	0.5	0.7	0.9	0.9	1.0	0.5
		平均	1.5	1.3	1.8	1.5	3.2	2.5	4.1	1.8	1.0	1.1	1.2	1.4	1.9
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	7.3	8.3	8.9	7.1	14.3	14.0	23.9	8.9	5.3	4.4	4.2	5.6	23.9
		最小	2.8	2.7	2.5	2.8	3.6	3.6	2.6	2.8	3.5	3.6	3.1	3.2	2.5
		平均	3.8	4.3	4.6	4.2	6.1	5.6	6.9	4.6	4.1	3.9	3.8	3.6	4.6
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.4	7.3	7.2	7.2	7.2	7.3	7.5	7.6	7.7	7.5	7.5	7.6	7.7
		最小	7.2	7.0	6.9	6.9	6.8	7.0	7.1	7.3	7.4	7.3	7.3	7.3	6.8
		平均	7.3	7.2	7.1	7.0	7.0	7.1	7.3	7.5	7.5	7.4	7.4	7.4	7.3
	浄水	最大	7.4	7.4	7.4	7.5	7.5	7.4	7.5	7.5	7.5	7.4	7.5	7.5	7.5
		最小	7.3	7.3	7.4	7.4	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総7日総度 (mg/l)	原水	最大	18.0	17.5	17.5	23.0	24.5	18.5	21.0	21.5	18.5	17.0	18.0	21.0	24.5
		最小	13.5	14.0	13.5	13.0	12.0	13.0	13.5	14.0	16.0	14.0	14.5	16.0	12.0
		平均	16.2	15.9	15.5	16.0	15.2	16.5	17.5	17.9	17.5	15.4	15.4	18.3	16.4
	浄水	最大	17.0	17.5	18.0	20.0	24.5	18.0	20.0	19.5	17.5	16.5	17.0	19.0	24.5
		最小	13.5	14.0	14.5	15.0	13.0	14.0	13.0	14.0	16.0	14.0	14.0	15.5	13.0
		平均	15.6	15.7	16.3	16.8	16.3	16.5	17.0	17.1	16.8	15.0	14.6	17.4	16.3
KMnO ₄ 消費量 (mg/l)	原水	最大	5.3	7.9	9.6	7.5	13.3	6.6	8.7	7.1	5.5	5.3	5.9	6.6	13.3
		最小	3.3	2.7	3.4	3.8	4.3	3.3	2.2	3.0	3.1	3.4	4.1	3.4	2.2
		平均	4.1	4.5	5.0	5.2	6.4	4.4	4.7	4.3	4.2	4.6	4.6	4.5	4.7
	浄水	最大	1.5	1.2	1.2	1.9	1.5	1.2	0.9	1.1	1.2	1.2	1.9	1.6	1.9
		最小	0.3	0.3	0.3	0.6	0.3	0.3	0.3	0.3	0.5	0.6	0.3	0.9	0.3
		平均	1.0	0.8	0.9	1.1	1.0	0.7	0.5	0.5	0.8	1.0	0.9	1.2	0.9
残留塩素 (mg/l)	浄水	最大	0.6	0.7	0.7	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.6	0.7	
		最小	0.5	0.6	0.6	0.6	0.6	0.7	0.5	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.6	0.6	0.6	0.6	0.6	0.7	0.6	0.5	0.5	0.5	0.5	0.5	0.6

豊川浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)	最大	25.3	28.0	30.8	36.4	36.5	34.6	30.4	23.2	14.7	10.6	12.5	21.6	36.5
	最小	13.5	14.8	17.8	22.1	23.2	25.2	17.4	10.0	5.7	2.0	0.2	4.7	0.2
	平均	20.3	22.2	25.7	32.0	32.2	30.7	23.2	16.5	9.4	7.6	7.2	13.2	20.0
原水水温 (℃)	最大	18.5	19.5	22.0	36.0	26.0	26.3	24.0	20.0	13.4	8.7	8.3	14.5	36.0
	最小	11.5	18.0	19.0	21.0	21.0	23.2	19.8	13.7	8.5	7.1	6.7	8.4	6.7
	平均	15.7	18.6	20.6	24.5	23.4	24.7	22.3	17.2	10.3	7.9	7.4	10.8	16.9
濁度 (度)	原水	最大	3.7	3.2	2.7	2.9	6.6	7.2	4.0	3.0	2.3	2.0	2.4	7.2
		最小	1.6	1.0	1.1	1.3	1.4	1.1	0.9	1.1	1.3	1.5	1.6	0.9
		平均	2.2	1.8	1.7	1.9	2.4	2.6	1.7	2.0	1.8	1.8	1.9	2.1
	浄水	最大	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		最小	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
		平均	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
色度 (度)	原水	最大	4.6	6.6	6.9	6.8	10.7	10.2	6.9	5.3	4.7	4.2	4.7	10.7
		最小	2.9	3.3	3.3	3.8	4.8	3.6	3.6	3.2	3.4	3.6	3.4	2.9
		平均	3.9	4.5	5.0	5.5	6.7	5.4	4.9	4.1	4.0	3.9	4.2	4.7
	浄水	最大	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		最小	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
		平均	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
pH値	原水	最大	7.5	7.5	7.5	7.4	7.5	7.5	7.4	7.5	7.5	7.6	7.5	7.6
		最小	7.2	7.1	7.2	7.1	7.0	7.0	7.1	7.1	7.3	7.3	7.2	7.0
		平均	7.3	7.3	7.3	7.3	7.2	7.3	7.2	7.3	7.4	7.4	7.4	7.3
	浄水	最大	7.4	7.4	7.5	7.5	7.5	7.4	7.4	7.5	7.5	7.5	7.5	7.5
		最小	7.3	7.3	7.2	7.2	7.2	7.3	7.0	7.3	7.3	7.3	7.3	7.0
		平均	7.3	7.4	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4
総硬度 (mg/l)	原水	最大	18.0	18.0	17.5	23.0	26.0	19.5	20.0	20.0	20.0	19.0	16.0	26.0
		最小	15.0	14.5	14.5	14.0	12.0	12.5	16.0	17.0	17.5	15.0	14.5	12.0
		平均	16.7	16.6	15.9	16.3	15.3	17.1	18.0	18.6	18.8	16.7	15.1	17.0
	浄水	最大	18.0	17.5	17.0	22.5	25.0	19.0	20.0	20.0	19.5	18.5	16.0	25.0
		最小	15.0	15.0	14.0	14.0	13.0	14.0	16.5	16.5	17.5	15.5	14.5	13.0
		平均	16.5	16.1	15.5	16.1	15.5	16.8	18.2	18.4	18.4	16.6	15.3	16.8
KMnO ₄ 消費量 (mg/l)	原水	最大	5.0	6.3	7.2	7.4	8.7	8.4	5.6	5.1	5.4	5.7	5.9	8.7
		最小	2.9	3.0	2.8	2.8	4.7	2.9	3.9	2.7	3.7	4.2	4.2	2.7
		平均	3.8	4.5	4.6	5.2	6.5	4.4	4.6	3.9	4.7	5.1	5.0	4.8
	浄水	最大	1.5	1.3	1.3	1.5	1.8	1.3	1.3	1.4	1.5	1.8	1.8	1.8
		最小	0.2	0.4	0.1	0.7	0.1	0.3	0.4	0.3	0.9	0.9	0.8	0.1
		平均	0.7	0.7	0.7	1.0	1.2	0.8	1.0	0.9	1.1	1.4	1.3	1.0
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.6	0.7	0.8	0.7	0.7	0.6	0.5	0.6	0.6	0.8
		最小	0.5	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.5	0.5	0.6	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.6

(2)工業用水毎日検査

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (℃)	最大	22.3	24.1	29.6	33.9	33.3	32.3	27.4	21.5	13.5	9.1	10.2	19.0	33.9	
	最小	11.7	16.3	18.3	23.0	23.8	24.3	18.1	9.5	4.9	-0.4	-0.3	4.0	-0.4	
	平均	18.4	20.7	24.6	30.3	31.1	29.2	22.6	15.6	8.2	6.1	5.2	10.9	18.6	
原水水温 (℃)	最大	16.9	19.8	22.4	26.2	28.2	27.0	24.6	19.6	12.9	7.4	8.1	11.3	28.2	
	最小	10.1	16.6	19.1	21.8	25.8	24.4	19.5	13.1	7.2	5.9	5.5	6.7	5.5	
	平均	13.8	18.3	20.9	23.4	27.0	25.7	21.9	16.2	9.7	6.7	6.1	8.6	16.5	
濁度 (度)	原水	最大	16.5	16.1	18.8	19.4	6.1	16.2	5.6	9.1	3.6	3.1	3.4	4.9	19.4
		最小	4.9	2.8	2.9	2.9	2.6	3.2	2.9	2.2	1.3	1.3	1.8	2.0	1.3
		平均	8.7	4.6	7.0	7.7	3.7	6.6	3.9	4.0	2.1	1.9	2.8	3.1	4.7
	配水	最大	11.8	2.9	4.7	4.5	6.4	7.8	3.7	5.8	2.8	1.4	2.0	2.9	11.8
		最小	0.8	0.7	0.7	0.8	2.5	0.5	0.2	0.6	1.1	0.9	1.0	0.7	0.2
		平均	4.5	1.3	1.3	2.5	4.4	2.7	1.0	2.3	1.5	1.1	1.4	1.8	2.2
pH値	原水	最大	7.5	7.5	7.5	7.5	7.6	7.7	7.5	7.5	7.5	7.6	7.6	7.5	7.7
		最小	7.2	7.2	7.2	7.1	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.3	7.1
		平均	7.4	7.4	7.3	7.3	7.4	7.5	7.4	7.4	7.5	7.5	7.5	7.5	7.4
	配水	最大	7.3	7.2	7.4	7.3	7.3	7.4	7.3	7.3	7.4	7.3	7.3	7.3	7.4
		最小	7.0	7.1	6.9	6.9	7.2	6.9	6.9	7.0	7.2	7.2	7.3	7.3	6.9
		平均	7.2	7.1	7.1	7.2	7.3	7.1	7.1	7.3	7.3	7.3	7.3	7.3	7.2
総アルカリ度 (mg/l)	原水	最大	17.5	18.0	17.5	16.0	19.5	17.5	17.5	19.5	21.5	22.0	21.5	22.5	22.5
		最小	13.5	15.5	14.5	13.5	16.0	16.0	15.5	15.5	19.0	20.5	20.5	17.5	13.5
		平均	15.2	16.5	15.5	14.2	17.8	16.8	16.6	17.2	20.3	21.1	21.0	19.2	17.6
	配水	最大	16.0	15.0	16.0	15.0	18.5	16.5	16.5	17.5	19.0	20.5	19.5	20.0	20.5
		最小	11.5	12.5	11.5	10.5	15.0	11.5	11.5	12.0	17.0	18.0	18.0	16.0	10.5
		平均	13.4	13.8	13.2	12.9	16.9	13.8	13.1	15.6	18.1	19.2	18.8	17.4	15.5

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (℃)	最大	25.0	26.0	29.0	35.0	35.0	34.0	28.0	20.0	12.0	10.0	10.0	19.0	35.0	
	最小	10.0	16.0	17.0	23.0	24.0	23.0	13.0	10.0	3.0	-1.0	1.0	4.0	-1.0	
	平均	18.3	20.8	24.4	30.8	31.6	29.6	22.1	15.1	7.0	5.2	4.5	10.4	18.3	
原水水温 (℃)	最大	17.2	20.6	23.3	27.1	38.8	28.5	26.5	20.6	13.8	8.8	7.2	11.6	38.8	
	最小	10.2	17.4	20.6	23.3	27.3	26.4	20.7	14.4	8.0	6.6	6.1	7.4	6.1	
	平均	14.5	19.3	22.2	24.9	29.2	27.5	23.6	17.5	10.7	7.2	6.6	9.1	17.7	
濁度 (度)	原水	最大	7.6	6.2	6.9	6.1	7.9	6.2	4.3	4.8	3.5	4.2	5.0	4.8	7.9
		最小	4.6	3.6	3.1	3.8	3.2	2.9	2.5	2.7	2.0	1.5	1.0	2.5	1.0
		平均	6.0	4.8	4.5	4.5	4.7	4.4	3.3	3.6	2.8	2.8	4.2	3.4	4.1
	配水	最大	2.2	2.8	5.3	5.6	5.3	5.5	2.8	2.6	2.0	3.2	2.0	2.0	5.6
		最小	0.6	0.5	1.8	3.2	2.0	2.1	1.0	1.2	0.9	1.1	1.4	0.8	0.5
		平均	1.4	1.4	2.9	4.4	3.6	3.3	1.6	1.9	1.4	1.5	1.8	1.3	2.2
pH値	原水	最大	7.6	7.3	7.2	7.2	7.4	7.4	7.5	7.6	7.7	7.7	7.7	7.7	7.7
		最小	7.2	7.1	7.0	6.8	7.0	7.0	7.1	7.2	7.4	7.5	7.6	7.5	6.8
		平均	7.4	7.2	7.1	6.9	7.1	7.1	7.3	7.4	7.5	7.6	7.7	7.6	7.3
	配水	最大	7.3	7.2	7.2	7.2	7.3	7.3	7.3	7.4	7.3	7.3	7.4	7.3	7.4
		最小	7.1	7.1	7.0	6.8	6.9	7.0	7.1	7.2	7.2	7.3	7.3	7.2	6.8
		平均	7.2	7.1	7.1	6.9	7.1	7.1	7.2	7.3	7.3	7.3	7.3	7.3	7.2
アルカリ度 (mg/l)	原水	最大	18.5	19.0	19.5	17.0	21.0	20.0	19.5	18.5	20.5	22.5	23.5	23.0	23.5
		最小	15.5	16.0	15.5	15.0	15.5	17.0	16.0	16.5	18.0	19.5	20.0	18.0	15.0
		平均	16.6	17.0	16.7	15.8	17.9	18.2	17.4	17.5	19.2	20.6	20.8	20.1	18.1
	配水	最大	17.0	18.0	18.5	17.0	19.5	19.0	18.5	18.5	19.5	21.5	21.0	21.0	21.5
		最小	14.0	15.5	15.5	15.0	15.0	16.5	15.5	15.5	17.0	18.0	18.0	17.0	14.0
		平均	15.3	16.4	16.4	15.7	17.8	17.9	16.8	17.0	18.1	19.6	19.1	18.6	17.4

尾張東部浄水場(東郷)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (℃)	最大	20.4	22.8	26.9	31.6	31.9	30.1	25.5	18.7	10.6	7.9	9.0	16.1	31.9	
	最小	11.8	14.7	19.3	23.6	24.0	23.5	16.8	7.7	3.3	0.1	0.1	5.3	0.1	
	平均	16.8	19.1	23.1	28.6	29.6	27.6	21.0	13.9	6.0	4.7	3.8	9.8	17.0	
原水水温 (℃)	最大	9.8	9.8	9.8	9.8	26.5	25.1	22.3	17.5	11.3	8.1	9.9	11.1	26.5	
	最小	9.8	9.8	9.8	9.8	9.8	22.0	17.7	11.2	7.0	5.7	5.7	7.0	5.7	
	平均	9.8	9.8	9.8	9.8	23.2	23.7	19.7	14.6	8.8	6.8	6.3	8.6	12.6	
濁度 (度)	原水	最大	11.8	11.0	8.8	10.2	6.0	12.8	6.7	6.0	3.9	2.2	2.4	3.2	12.8
		最小	4.4	3.2	3.6	4.1	2.9	3.9	3.0	1.9	1.3	1.3	1.7	1.6	1.3
		平均	7.0	5.0	6.0	6.0	4.0	7.0	5.0	3.0	2.0	2.0	2.0	2.0	4.3
	配水	最大	4.6	4.5	5.4	7.2	6.2	6.8	5.0	5.8	3.4	2.7	2.9	3.0	7.2
		最小	0.7	0.6	2.0	2.8	2.1	0.8	1.3	2.2	1.4	1.4	1.5	1.5	0.6
		平均	2.0	3.5	3.0	4.0	4.0	3.0	3.0	4.0	2.0	2.0	2.0	2.0	2.9
pH値	原水	最大	8.2	7.5	7.4	7.5	7.4	7.5	7.5	7.6	7.6	7.6	7.7	8.2	
		最小	7.4	7.3	7.2	7.0	7.3	7.3	7.3	7.4	7.5	7.5	7.5	7.5	7.0
		平均	7.6	7.4	7.3	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.5	7.4
	配水	最大	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.1	7.2	7.1	7.0	7.2	7.1	7.2	7.3	7.3	7.3	7.3	7.3	7.0
		平均	7.3	7.3	7.3	7.2	7.3	7.2	7.3	7.3	7.4	7.4	7.4	7.4	7.3
総アルカリ度 (mg/l)	原水	最大	17.0	17.5	17.5	16.5	20.0	18.0	18.5	19.0	21.0	21.0	21.0	21.0	21.0
		最小	13.5	14.5	14.0	13.0	16.5	15.5	15.5	15.5	18.5	19.5	19.0	17.0	13.0
		平均	14.8	16.3	15.6	14.2	17.9	16.7	16.5	17.3	19.6	20.2	20.2	18.8	17.3
	配水	最大	16.5	17.0	17.0	16.5	20.0	17.0	18.0	18.0	20.0	20.5	20.0	19.5	20.5
		最小	12.0	14.0	13.0	12.0	15.5	14.5	14.0	14.5	17.5	17.5	18.0	16.5	12.0
		平均	13.4	15.4	15.1	13.7	17.6	15.5	15.7	16.2	18.6	19.0	18.6	17.7	16.4

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)	最大	25.2	26.0	29.0	34.8	36.0	35.3	29.5	23.5	15.9	12.7	11.5	20.5	36.0
	最小	11.7	16.0	17.8	22.1	25.7	24.4	18.9	9.7	4.2	2.5	1.5	6.1	1.5
	平均	19.0	21.2	24.5	30.2	32.2	30.5	23.9	16.8	9.0	8.0	7.3	12.2	19.5
原水水温 (℃)	最大	16.9	19.8	23.6	27.2	29.9	28.0	24.1	17.8	12.2	7.9	8.9	11.6	29.9
	最小	11.2	16.3	17.0	18.9	25.0	23.8	17.1	12.0	7.2	6.1	5.5	7.3	5.5
	平均	13.8	17.9	20.4	22.8	28.3	25.5	20.6	15.0	9.4	7.1	7.0	9.7	16.5
濁度 (度)	原水	最大	68.1	40.0	43.0	74.1	4.9	7.8	4.1	25.3	3.8	2.8	3.4	74.1
		最小	0.7	0.3	1.0	0.6	0.6	0.8	0.7	0.9	0.8	0.7	0.9	0.3
		平均	9.8	4.7	8.4	9.0	1.6	2.8	1.7	3.6	1.5	1.4	1.9	4.0
	配水	最大	0.3	0.3	0.4	0.3	0.4	0.6	0.4	0.5	0.4	0.5	0.5	0.6
		最小	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.2	0.1	0.1	0.1	0.1
		平均	0.2	0.2	0.2	0.2	0.3	0.3	0.2	0.3	0.2	0.2	0.2	0.2
pH値	原水	最大	7.5	7.4	7.3	7.1	7.3	7.2	7.3	7.6	7.7	7.6	7.7	7.7
		最小	6.8	6.9	6.7	6.6	6.7	6.9	7.0	7.0	7.4	7.4	7.1	6.6
		平均	7.2	7.2	7.0	6.9	7.1	7.0	7.2	7.4	7.6	7.5	7.4	7.2
	配水	最大	7.5	7.4	7.4	7.2	7.2	7.3	7.3	7.5	7.4	7.4	7.3	7.5
		最小	7.1	7.1	7.1	7.0	7.0	7.1	7.0	7.2	7.3	7.3	7.1	7.0
		平均	7.3	7.3	7.2	7.1	7.2	7.2	7.2	7.3	7.3	7.3	7.2	7.2
総7μl加度 (mg/l)	原水	最大	21.0	21.0	21.0	21.5	22.5	24.5	21.0	26.0	26.5	26.0	24.5	26.5
		最小	9.5	10.5	11.5	10.5	17.0	15.0	14.0	12.5	22.5	22.5	16.5	9.5
		平均	16.9	17.5	16.7	16.1	20.4	18.1	18.0	20.4	24.6	24.3	23.9	19.7
	配水	最大	18.0	21.0	23.0	22.0	23.0	23.0	21.5	22.0	25.0	26.5	26.0	26.5
		最小	11.5	10.0	12.0	13.5	16.0	13.5	13.5	13.0	17.5	19.5	16.0	10.0
		平均	15.2	17.1	16.6	16.1	19.8	16.9	17.3	18.4	21.2	22.4	19.6	18.6

安城浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)	最大	23.9	26.8	31.2	36.3	36.2	34.8	29.9	22.7	15.8	11.4	12.3	21.1	36.3
	最小	13.5	17.8	18.7	23.4	24.1	24.8	18.4	11.1	5.0	1.2	1.0	3.3	1.0
	平均	20.0	22.2	26.1	32.0	32.8	30.9	23.9	17.4	9.9	7.9	7.5	12.6	20.3
原水水温 (℃)	最大	17.5	20.0	22.6	27.0	27.9	26.9	24.0	18.4	11.0	7.0	7.0	13.3	27.9
	最小	10.7	16.0	16.5	19.7	23.2	22.6	18.4	11.8	6.3	4.9	4.8	7.3	4.8
	平均	14.3	17.8	19.9	22.8	26.7	24.8	20.7	15.1	8.2	6.1	5.8	9.8	16.0
濁度 (度)	原水	最大	22.0	83.0	86.0	116.0	17.0	32.0	11.0	8.0	6.0	2.0	13.0	116.0
		最小	2.0	2.0	2.0	3.0	2.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	4.0	8.0	8.0	9.0	3.0	4.0	4.0	3.0	2.0	2.0	3.0	4.3
	配水	最大	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	2.0	2.0
		最小	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
pH値	原水	最大	7.6	7.5	7.4	7.4	7.5	7.4	7.5	7.6	7.7	7.7	7.8	7.8
		最小	7.2	7.0	7.2	7.1	7.2	7.1	7.3	7.2	7.4	7.4	7.5	7.3
		平均	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.4	7.5	7.5	7.5	7.4
	配水	最大	7.1	7.1	7.1	7.1	7.1	7.0	7.1	7.2	7.3	7.3	7.2	7.3
		最小	6.8	6.8	6.8	6.8	6.9	6.8	6.9	7.1	7.0	7.1	7.0	6.8
		平均	7.0	7.0	7.0	6.9	7.0	7.0	7.1	7.2	7.2	7.2	7.1	7.1
総7μl加度 (mg/l)	原水	最大	20.0	20.0	19.5	21.0	22.5	21.5	21.0	23.0	25.0	24.5	25.0	25.0
		最小	14.5	14.0	14.5	16.0	16.0	14.0	17.5	17.5	21.0	21.0	21.5	14.0
		平均	17.8	18.4	17.7	17.9	20.3	18.9	19.0	20.6	23.4	23.5	23.5	20.4
	配水	最大	16.5	17.0	16.5	16.5	18.0	17.0	16.5	19.0	20.0	21.0	20.5	21.0
		最小	12.0	12.0	12.0	12.0	13.0	12.0	12.5	14.5	16.5	17.5	18.0	12.0
		平均	14.2	15.0	13.9	13.9	16.4	14.5	14.5	16.7	18.8	19.5	19.6	16.4

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計
気温 (℃)	最大	22.4	24.0	28.9	33.5	33.0	32.7	27.7	22.6	13.5	10.1	10.8	19.3	33.5
	最小	13.1	15.3	17.5	22.3	23.2	25.2	16.7	9.5	5.1	2.1	1.0	3.3	1.0
	平均	18.4	20.3	24.1	30.3	30.3	28.9	22.5	15.9	8.5	6.7	5.8	11.5	18.6
原水水温 (℃)	最大	14.0	18.0	20.0	23.7	24.5	25.7	23.8	20.0	13.7	9.0	7.6	11.9	25.7
	最小	10.5	13.0	16.7	19.8	21.4	23.6	19.0	14.2	9.0	7.2	6.0	6.6	6.0
	平均	12.7	15.5	18.6	22.2	23.3	24.7	21.2	16.9	11.0	7.9	6.6	8.8	15.8
濁度 (度)	原水	最大	7.3	2.2	9.6	2.9	13.8	10.0	40.7	15.0	1.5	1.4	1.5	40.7
		最小	0.8	0.9	1.0	0.9	0.8	0.7	0.9	0.5	0.7	0.9	1.0	0.5
		平均	1.5	1.3	1.8	1.5	3.2	2.5	4.1	1.8	1.1	1.2	1.4	1.9
	配水	最大	0.5	0.4	0.5	0.4	0.5	0.5	0.4	0.4	0.4	0.4	0.3	0.5
		最小	0.1	< 0.1	0.1	< 0.1	0.1	0.1	< 0.1	0.1	< 0.1	0.1	< 0.1	< 0.1
		平均	0.3	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.3	0.2	0.2
pH値	原水	最大	7.4	7.3	7.2	7.2	7.2	7.3	7.5	7.6	7.7	7.5	7.6	7.7
		最小	7.2	7.0	6.9	6.9	6.8	7.0	7.1	7.3	7.4	7.3	7.3	6.8
		平均	7.3	7.2	7.1	7.0	7.0	7.1	7.3	7.5	7.5	7.4	7.4	7.3
	配水	最大	7.1	7.1	7.0	7.1	7.0	7.1	7.2	7.1	7.1	7.1	7.1	7.2
		最小	6.9	6.9	6.9	6.8	6.8	6.7	7.0	6.9	6.9	6.9	7.0	6.7
		平均	7.0	7.0	6.9	6.9	6.9	6.9	7.1	7.1	7.0	7.0	7.1	7.0
総7μl加度 (mg/l)	原水	最大	18.0	17.5	17.5	23.0	24.5	18.5	21.0	21.5	18.5	17.0	18.0	24.5
		最小	13.5	14.0	13.5	13.0	12.0	13.0	13.5	14.0	16.0	14.5	16.0	12.0
		平均	16.2	15.9	15.5	16.0	15.2	16.5	17.5	17.9	17.5	15.4	15.4	16.4
	配水	最大	13.0	13.5	13.5	15.0	19.0	14.5	15.0	15.5	13.5	13.5	15.0	19.0
		最小	10.5	10.0	10.0	10.5	8.5	9.0	9.5	9.0	11.0	10.5	12.0	8.5
		平均	12.2	11.9	11.9	12.5	11.5	12.2	12.6	12.8	12.6	11.3	11.2	12.2

蒲郡浄水場(工水)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (℃)	最大	22.2	26.2	29.6	36.0	35.5	34.2	29.6	23.2	16.0	11.8	11.9	20.1	36.0	
	最小	14.6	13.9	12.3	16.0	24.7	25.8	18.4	11.5	6.6	2.4	0.5	4.1	0.5	
	平均	19.4	21.4	24.6	31.1	31.9	30.2	23.6	17.4	10.3	8.3	7.7	12.5	19.9	
原水水温 (℃)	最大	17.0	19.5	21.4	25.9	25.8	25.2	23.3	20.0	15.1	11.2	10.3	14.0	25.9	
	最小	11.0	16.3	18.9	20.9	22.0	22.8	19.8	14.5	10.0	8.7	7.7	9.5	7.7	
	平均	14.6	17.8	20.3	23.6	23.9	24.1	21.7	17.6	12.1	9.7	8.8	11.2	17.1	
濁度 (度)	原水	最大	8.4	7.1	3.6	4.5	6.2	8.6	3.3	1.6	1.7	1.8	2.1	1.8	8.6
		最小	0.9	0.8	0.9	1.1	2.0	1.0	0.9	0.4	0.4	0.4	0.5	0.6	0.4
		平均	1.6	2.2	2.1	2.3	3.4	2.8	1.6	1.0	0.7	0.9	0.9	1.0	1.7
	配水	最大	0.4	0.4	0.4	1.6	2.2	2.6	0.4	0.4	0.3	0.4	0.5	0.3	2.6
		最小	0.1	0.1	0.1	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1
		平均	0.1	0.2	0.2	1.0	1.2	1.0	0.2	0.2	0.1	0.2	0.2	0.1	0.4
pH値	原水	最大	7.5	7.4	7.3	7.3	7.4	7.3	7.4	7.5	7.6	7.5	7.5	7.6	
		最小	7.3	7.3	7.2	7.1	7.0	7.1	7.2	7.3	7.4	7.4	7.3	7.2	7.0
		平均	7.4	7.4	7.3	7.2	7.2	7.2	7.3	7.3	7.4	7.4	7.4	7.4	7.3
	配水	最大	7.2	7.2	7.3	7.2	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3
		最小	7.0	7.0	7.0	6.9	7.0	7.0	7.0	7.1	7.1	7.1	7.1	7.0	6.9
		平均	7.1	7.1	7.1	7.1	7.1	7.2	7.1	7.2	7.2	7.2	7.2	7.2	7.2
総硬度 (mg/l)	原水	最大	22.0	23.0	23.0	22.0	26.0	23.0	25.0	25.0	24.0	21.0	27.0	27.0	
		最小	19.0	18.0	18.0	17.0	15.0	16.0	19.0	20.0	20.0	17.0	17.0	18.0	15.0
		平均	20.6	20.4	19.7	19.3	17.8	19.8	21.8	21.9	22.0	19.7	18.9	21.4	20.3
	配水	最大	19.0	20.0	21.0	21.0	24.0	21.0	23.0	23.0	22.0	20.0	18.0	23.0	24.0
		最小	16.0	16.0	16.0	17.0	14.0	16.0	18.0	18.0	18.0	15.0	15.0	16.0	14.0
		平均	17.8	17.7	17.4	18.4	16.6	18.8	20.0	19.5	19.3	17.3	16.6	18.7	18.2